APPENDICES

CONTENTS

Appendix A NSPS Subpart A, Identification of General Provisions

Appendix AA NESHAP Subpart A, Identification of General Provisions

Appendix BD Final BACT Determinations and Emissions Standards

Appendix CF Citation Format and Definitions

Appendix CP-1 Compliance Plan for Alternate Method of Operation

Appendix Da NSPS Subpart Da Requirements for Duct Burners

Appendix GG NSPS Subpart GG Requirements for Gas Turbines

Appendix H-1 Permit History

Appendix SC Standard Conditions

Appendix DDDDD National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, or Institutional Boilers or Process Heaters

Appendix ZZZZ National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE)

APPENDIX A

NSPS SUBPART A, IDENTIFICATION OF GENERAL PROVISIONS

Emissions units subject to a New Source Performance Standard of 40 CFR 60 are also subject to the applicable requirements of Subpart A, the General Provisions, including:

§ 60.1 Applicability.

§ 60.2 Definitions.

§ 60.3 Units and abbreviations.

§ 60.4 Address.

§ 60.5 Determination of construction or modification.

§ 60.6 Review of plans.

§ 60.7 Notification and Record Keeping.

§ 60.8 Performance Tests.

§ 60.9 Availability of information.

§ 60.10 State Authority.

§ 60.11 Compliance with Standards and Maintenance Requirements.

§ 60.12 Circumvention.

§ 60.13 Monitoring Requirements.

§ 60.14 Modification.

§ 60.15 Reconstruction.

§ 60.16 Priority List.

§ 60.17 Incorporations by Reference.

§ 60.18 General Control Device Requirements.

§ 60.19 General Notification and Reporting Requirements.

Individual subparts may exempt specific equipment or processes from some or all of these requirements. The general provisions may be provided in full upon request.

APPENDIX AA

NESHAP SUBPART A, IDENTIFICATION OF GENERAL PROVISIONS

Emissions units subject to a National Emissions Standards for Hazardous Air Pollutants for Source Category of 40 CFR 63 are also subject to the applicable requirements of Subpart A, the General Provisions, including:

§ 63.1 Applicability.

§ 63.2 Definitions.

§ 63.3 Units and abbreviations.

§ 63.4 Prohibit activities and circumvention .

§ 63.5 Preconstruction review and notification requirements.

§ 63.6 Compliance with standards and maintenance requirements.

§ 63.7 Performance testing requirements.

§ 63.8 Monitoring Requirements.

§ 63.9 Notification Requirements

§ 63.10 Recordkeeping and reporting requirements.

§ 63.11 Control device requirements.

§ 63.12 State authority and delegations.

§ 63.13 Addresses of State air pollution control agencies and EPA Regional Offices.

§ 63.14 Incorporation by reference.

§ 63.15 Availability of information and confidentiality.

Individual subparts may exempt specific equipment or processes from some or all of these requirements. The general provisions may be provided in full upon request.

APPENDIX BD

FINAL BACT DETERMINATION

OVERVIEW

The project added an 1150 MW "4-on-1" combined cycle gas turbine system to the existing FPL Martin Power Plant. PSD-significant emissions increases required determinations of the Best Available Control Technology (BACT) for carbon monoxide (CO), nitrogen oxides (NOx), particulate matter (PM/PM_{10}), sulfuric acid mist (SAM), and sulfur dioxide (SO_2), and volatile organic compounds (VOC).

BACT CONTROL TECHNOLOGIES

The Department reviewed available control technologies for each pollutant resulting in a PSD-significant increase. The Department's technical review and rationale for the BACT determinations are presented in the "Technical Evaluation and Preliminary Determination" as revised prior to the siting hearing. The following summarizes the control technologies upon which the Department's final BACT determinations are based.

BACT for CO and VOC Emissions

Good Combustion and Operating Practices: BACT for CO and VOC emissions is the efficient combustion of fuels at high temperatures associated with good combustion design and operating practices. General Electric's dual-fuel combustors have demonstrated very low CO and VOC emissions while simultaneously reducing NOx emissions for gas and oil firing.

BACT for NOx Emissions

DLN Combustion: When firing natural gas under simple cycle mode, BACT for NOx emissions is the operation of General Electric's dry low-NOx (DLN) combustion system. The efficient fuel combustion and thorough mixing of the gas stream reduces hot and cold spots surrounding the combustion zone. The full lean premix combustion results in NOx emissions less than 9 ppmvd when firing natural gas. The Speedtronic™ control system continuously monitors performance parameters and adjusts for efficient operation. The control system also provides for quick automated startups, lean pre-mix combustion performance, and controlled shutdowns.

Wet Injection: When firing distillate oil under simple cycle mode, BACT for NOx emissions is the operation of General Electric's dual-fuel combustor with wet injection designed to reduce the flame temperature and lower NOx emissions.

SCR: When firing natural gas or distillate oil in combined cycle mode, BACT for NOx emissions is the operation of the selective catalytic reduction (SCR) system in conjunction with DLN combustion and wet injection. Ammonia injected into the exhaust gas stream combines with NOx in a reduction action across a catalyst bed to form nitrogen and water. The catalyst bed is located after the HRSG, which reduces exhaust temperatures to the appropriate operating range of the catalyst material. The SCR system will achieve about a 70% reduction with an initial ammonia slip of no more than 5 ppmvd.

BACT for PM, SAM, and SO_2 Emissions

Fuel Specifications: BACT for PM, SAM, and SO_2 emissions is the use of natural gas as the primary fuel (≤ 2.0 grains of sulfur per 100 standard cubic feet of natural gas) and restricted use of very low sulfur distillate oil (≤ 0.05% sulfur by weight). These fuels are readily combustible and contain little ash, sulfur, or other contaminants.

BACT STANDARDS

The following summarizes the final Best Available Control Technology determinations for this project in accordance with Rule 62-212.400(BACT), F.A.C.

Gas-Fired Fuel Heaters: BACT for emissions of CO, NOx, PM/PM_{10}, SAM, SO_2, and VOC from the gas-fired fuel heaters is the efficient combustion of natural gas and the following visible emissions criteria, "If visible emissions are greater than 5% opacity, the permittee shall investigate the cause, take appropriate corrective actions, and document the incident. This condition does not impose any initial or periodic testing." This condition is similar to that for the previously permitted gas-fired fuel heaters under Permit No. PSD-FL-286.

Cooling Tower: BACT for emissions of PM/PM_{10} from the cooling tower is a design drift rate of no more than 0.001 percent of the circulating water flow rate.

Gas Turbines/HRSG Systems

Pollutant	Fuel	Method of Operation	Stack Test, 3-Run Average		CEMS Block Average
			ppmvd @ 15% O_2	lb/hour	ppmvd @ 15% O_2
CO [a]	Oil	Simple or Combined Cycle	14.4	64.7	15.0, 24-hr
	Gas	Simple Cycle	7.4	27.5	8.0, 24-hr
		Simple Cycle w/PA	12.0	45.0	12.0, 24-hr
		Combined Cycle, Normal	7.4	27.5	10.0, 24-hr
		Combined Cycle, All Modes	NA	NA	
NOx [b]	Oil	Simple Cycle	42.0	319.2	42.0, 3-hr
		Combined Cycle w/SCR	10.0	76.0	10.0, 24-hr
	Gas	Simple Cycle	9.0	58.7	9.0, 24-hr
		Simple Cycle w/PA	12.0	76.2	12.0, 24-hr
		Simple Cycle w/Peaking	15.0	95.3	15.0, 24-hr
		Combined Cycle w/SCR, Normal	2.5	16.3	2.5, 24-hr
		Combined Cycle w/SCR and DB	2.5	23.6	
		Combined Cycle w/SCR, All Modes	NA	NA	
PM/PM_{10} [c]	Oil/Gas	Simple or Combined Cycle	Fuel Specifications		
		Simple or Combined Cycle	Visible emissions shall not exceed 10% opacity for each 6-minute block average.		
SAM/SO_2 [d]	Oil/Gas	Simple or Combined Cycle	Fuel Specifications		
VOC [e]	Oil	Simple or Combined Cycle	2.5	6.0	NA
	Gas	Simple or Normal Combined Cycle	1.3	2.8	NA
		Combined Cycle, w/DB and/or PA	4.0	10.5	NA
Ammonia [f]	Oil/Gas	Combined Cycle w/SCR	5.0	NA	NA

a. Compliance with the CO standards shall be demonstrated based on data collected by the required CEMS. Compliance may also be determined by EPA Method 10. Compliance with the 24-hour CO CEMS standards shall be determined separately for each method of operation based on the hours of operation for each method. *{Permitting Note: A 24-hour compliance average may be based on as little as 1-hour of CEMS data or as much as 24-hours of CEMS data.}*

b. Compliance with the NOx standards shall be demonstrated based on data collected by the required CEMS. Compliance may also be determined by EPA Method 7E or 20. NOx mass emission rates are defined as oxides of nitrogen expressed as NO_2. Compliance with the 24-hour NOx CEMS standards during simple cycle operation shall be determined separately for each method of operation based on the hours of operation for each method. *{Permitting Note: A 24-hour compliance average may be based on as little as 1-hour of CEMS data or as much as 24-hours of CEMS data.}*

c. The fuel specifications established above combined with the efficient combustion design and operation of each gas turbine represents the Best Available Control Technology (BACT) determination for PM/PM_{10} emissions. Compliance with the fuel specifications, CO standards, and visible emissions standards shall serve as indicators of good combustion. Compliance with the fuel specifications shall be demonstrated by keeping records of the fuel sulfur content. Compliance with the visible emissions standard shall be demonstrated by conducting tests in accordance with EPA Method 9. *{Permitting Note: PM10 emissions for gas firing are estimated at 9 lb/hour for simple cycle operation, 11 lb/hour for combined cycle operation, and 17 lb/hour for combined cycle operation with duct burning. PM_{10}*

emissions for oil firing are estimated at 17 lb/hour for simple cycle operation and 37 lb/hour for combined cycle operation.}

d. The fuel sulfur specifications effectively limit the potential emissions of SAM and SO_2 from the gas turbines and represent the Best Available Control Technology (BACT) determination for these pollutants. *{Permitting Note: SO_2 emissions for gas firing are estimated at 9.8 lb/hour for simple and combined cycle operation and 12.8 lb/hour for combined cycle operation with duct burning. SO_2 emissions for oil firing are estimated at 99 lb/hour for simple and combined cycle operation. SAM emissions are estimated to be less than 10% of the SO_2 emissions.}*

e. Compliance with the VOC standards shall be demonstrated by conducting tests in accordance with EPA Method 25A. Optionally, EPA Method 18 may also be performed to deduct emissions of methane and ethane. The emission standards are based on VOC measured as methane.

f. Subject to the following testing requirements, each SCR system shall be designed and operated for an initial ammonia slip target of no more than 5.0 ppmvd corrected to 15% oxygen based on the average of three test runs. Compliance with the ammonia slip standard shall be demonstrated by conducting tests in accordance with EPA Method CTC-027.

   Additional Ammonia Slip Testing: If the tested ammonia slip rate for a gas turbine exceeds 5.0 ppmvd corrected to 15% oxygen when firing natural gas during the annual test, the permittee shall:

   a. Begin testing and reporting the ammonia slip for each subsequent calendar quarter;

   b. Before the ammonia slip exceeds 7 ppmvd corrected to 15% oxygen, take corrective actions that result in lowering the ammonia slip to less than 5 ppmvd corrected to 15% oxygen; and

   c. Test and demonstrate that the ammonia slip is less than 5 ppmvd corrected to 15% oxygen within 15 days after completing the corrective actions.

   Corrective actions may include, but are not limited to, adding catalyst, replacing catalyst, or other SCR system maintenance or repair. After demonstrating that the ammonia slip level is less than 5 ppmvd corrected to 15% oxygen, testing and reporting shall resume on an annual basis. [Rules 62-4.070(3) and 62-297.310(7)(b), F.A.C.]

{Permitting Notes: "DB" means duct burning. "PA" means power augmentation. "SCR" means selective catalytic reduction. "NA" means not applicable. The mass emission rate standards are based on a turbine inlet condition of 59° F and may be adjusted to actual test conditions in accordance with the performance curves and/or equations on file with the Department. Initial compliance tests under normal conditions for gas and oil firing have already been conducted for the existing Unit 8 gas turbines.}

APPENDIX CF

CITATION FORMAT AND DEFINITIONS

The following examples illustrate the format used in the permit to identify applicable permitting actions and regulations.

REFERENCES TO PREVIOUS PERMITTING ACTIONS

Old Permit Numbers

Example: Permit No. AC50-123456 or Air Permit No. AO50-123456

Where: "AC" identifies the permit as an Air Construction Permit
"AO" identifies the permit as an Air Operation Permit
"123456" identifies the specific permit project number

New Permit Numbers

Example: Permit Nos. 099-2222-001-AC, 099-2222-001-AF, 099-2222-001-AO, or 099-2222-001-AV

Where: "099" represents the specific county ID number in which the project is located
"2222" represents the specific facility ID number
"001"identifies the specific permit project
"AC" identifies the permit as an air construction permit
"AF" identifies the permit as a minor federally enforceable state operation permit
"AO" identifies the permit as a minor source air operation permit
"AV" identifies the permit as a Title V Major Source Air Operation Permit

PSD Permit Numbers

Example: Permit No. PSD-FL-317

Where: "PSD" means issued pursuant to the Prevention of Significant Deterioration of Air Quality
"FL" means that the permit was issued by the State of Florida
"317" identifies the specific permit project

RULE CITATION FORMATS

Florida Administrative Code (F.A.C.)

Example: [Rule 62-213.205, F.A.C.]

Means: Title 62, Chapter 213, Rule 205 of the Florida Administrative Code

Code of Federal Regulations (CFR)

Example: [40 CFR 60.7]

Means: Title 40, Part 60, Section 7

DEFINITIONS [RULE 62-210.200, F.A.C.]

(119) Excess Emissions - Emissions of pollutants in excess of those allowed by any applicable air pollution rule of the Department, or by a permit issued pursuant to any such rule or Chapter 62-4, F.A.C. The term applies only to conditions which occur during startup, shutdown, soot blowing, load changing or malfunction.

(179) Malfunction - Any unavoidable mechanical and/or electrical failure of air pollution control equipment or process equipment or of a process resulting in operation in an abnormal or unusual manner.

(258) Shutdown - The cessation of the operation of an emissions unit for any purpose.

(275) Startup - The commencement of operation of any emissions unit which has shut down or ceased operation for a period of time sufficient to cause temperature, pressure, chemical or pollution control device imbalances, which result in excess emissions.

NSPS SUBPART Da REQUIREMENTS FOR DUCT BURNERS

The HRSG duct burners are part of the Unit 8 gas turbine/HRSG systems, which are regulated as Emissions Units 011, 012, 017, and 018.

§ 60.40a Applicability and Designation of Affected Facility.

The HRSG duct burner systems are part of an electric utility steam generating unit that is capable of combusting more than 250 MMBtu per hour heat input of fossil fuel for which construction or modification is commenced after September 18, 1978. Therefore, the requirements of NSPS Subpart Da apply to the HRSG duct burners systems. Only emissions resulting from combustion of fuels in the steam generating unit are subject to this subpart. Emissions from the gas turbines are subject to the requirements of NSPS Subpart GG. The HRSG duct burner systems are also subject to the applicable requirements of the General Provisions in Subpart A.

§ 60.41a Definitions.

"Duct burner" means a device that combusts fuel and that is placed in the exhaust duct from another source, such as a stationary gas turbine, internal combustion engine, kiln, etc., to allow the firing of additional fuel to heat the exhaust gases before the exhaust gases enter a heat recovery steam generating unit.

"Electric utility combined cycle gas turbine" means any combined cycle gas turbine used for electric generation that is constructed for the purpose of supplying more than one-third of its potential electric output capacity and more than 25 MW electrical output to any utility power distribution system for sale. Any steam distribution system that is constructed for the purpose of providing steam to a steam electric generator that would produce electrical power for sale is also considered in determining the electrical energy output capacity of the affected facility.

"Electric utility steam generating unit" means any steam electric generating unit that is constructed for the purpose of supplying more than one-third of its potential electric output capacity and more than 25 MW electrical output to any utility power distribution system for sale. Any steam supplied to a steam distribution system for the purpose of providing steam to a steam-electric generator that would produce electrical energy for sale is also considered in determining the electrical energy output capacity of the affected facility.

"Fossil fuel" means natural gas, petroleum, coal, and any form of solid, liquid, or gaseous fuel derived from such material for the purpose of creating useful heat.

"Gross output" means the gross useful work performed by the steam generated. For units generating only electricity, the gross useful work performed is the gross electrical output from the turbine/generator set. For cogeneration units, the gross useful work performed is the gross electrical output plus one half the useful thermal output (i.e., steam delivered to an industrial process).

"Potential electrical output capacity" is defined as 33 percent of the maximum design heat input capacity of the steam generating unit (e.g., a steam generating unit with a 100–MW (340 million Btu/hr) fossil-fuel heat input capacity would have a 33–MW potential electrical output capacity). For electric utility combined cycle gas turbines the potential electrical output capacity is determined on the basis of the fossil-fuel firing capacity of the steam generator exclusive of the heat input and electrical power contribution by the gas turbine.

"Steam generating unit" means any furnace, boiler, or other device used for combusting fuel for the purpose of producing steam (including fossil-fuel-fired steam generators associated with combined cycle gas turbines; nuclear steam generators are not included).

§ 60.42a Standard for Particulate Matter.

§ 60.42a(a)(1) establishes a particulate matter limit of 0.03 lb/MMBtu heat input from the combustion of gaseous fuel and an opacity limit of 20 percent opacity (6-minute average), except for one 6-minute period per hour of not more than 27 percent opacity. Natural gas is the primary fuel for the gas turbines with very low sulfur distillate oil as a backup fuel. Natural gas is the exclusive fuel for the duct burner systems. As the worst case, the maximum PM/PM_{10} emissions are expected to be less than 0.01 lb/MMBtu heat input from firing distillate oil in the gas turbine and natural gas in the duct burners. The stack opacity is limited by permit to 10% or less. Therefore, the Department determines that compliance with the conditions of the PSD permit ensure compliance with the requirements of NSPS Subpart Da.

§ 60.43a Standard for Sulfur Dioxide.

In accordance with § 60.43a(b)(2), sulfur dioxide emissions shall not exceed 0.20 lb/MMBtu heat input from the combustion of gaseous fuel for uncontrolled sources. Natural gas is the primary fuel for the gas turbines with very low sulfur distillate oil (≤ 0.05% sulfur by weight) as a backup fuel. Natural gas is the exclusive fuel for the duct burner systems. As the worst case, the maximum SO_2 emissions are expected to be less than 0.05 lb/MMBtu heat input from firing distillate oil in the gas turbine and natural gas in the duct burners. Therefore, the Department determines that compliance with the conditions of the PSD permit ensure compliance with the requirements of NSPS Subpart Da.

§ 60.44a Standard for Nitrogen Oxides.

In accordance with § 60.44a(d)(1), nitrogen oxides (expressed as NO_2) from a gas turbine/HRSG system with duct burners shall not exceed 1.6 pounds per megawatt-hour gross energy output. The permittee shall demonstrate compliance with this requirement based upon an initial test. Thereafter, compliance with the BACT standards of the PSD permit will demonstrate compliance with the NSPS Subpart Da limit. After investigation, if there is good reason to believe that this standard is being violated, the Department may require subsequent compliance testing in accordance with Rule 62-297.310(7)(b), F.A.C.

§ 60.46a Compliance Provisions.

The HRSG duct burner systems are restricted to the exclusive firing of natural gas. The maximum expected emissions of particulate matter and sulfur dioxide are much lower than the limits established by this subpart. Therefore, no testing is required to demonstrate compliance with the standards specified in § 60.42a (particulate matter) and § 60.43a (sulfur dioxide). Compliance with the opacity limit of 10% established in the PSD permit ensures compliance with the NSPS opacity standard.

In accordance with § 60.46a(k)(1), compliance with the nitrogen oxides (NOx) standard specified in § 60.44a(d)(1) for duct burners used in combined cycle systems shall be determined as follows:

$$E = [(Csg \times Qsg) - (Cte \times Qte)]/(Osg \times h) \qquad \text{(Equation 1)}$$

Where:

E	=	Emission rate of NOx from the duct burner, ng/J (lb/Mwh) gross output
Csg	=	Average hourly concentration of NOx exiting the steam generating unit, ng/ dscm (lb/dscf)
Cte	=	Average hourly concentration of NOx in the turbine exhaust upstream from duct burner, ng/dscm (lb/dscf)
Qsg	=	Average hourly volumetric flow rate of exhaust gas from steam generating unit, dscm/hr (dscf/hr)
Qte	=	Average hourly volumetric flow rate of exhaust gas from combustion turbine, dscm/hr (dscf/hr)
Osg	=	Average hourly gross energy output from steam generating unit, J (Mwh)
h	=	Average hourly fraction of the total heat input to the steam generating unit de-rived from the combustion of fuel in the affected duct burner

Method 7E of Appendix A of Part 60 shall be used to determine the NOx concentrations (Csg and Cte). Method 2, 2F or 2G of Appendix A of Part 60, as appropriate, shall be used to determine the volumetric flow rates (Qsg and Qte) of the exhaust gases. The volumetric flow rate measurements shall be taken at the same time as the concentration measurements.

The owner or operator shall develop, demonstrate, and provide information satisfactory to the Administrator to determine the average hourly gross energy output from the steam generating unit, and the average hourly percentage of the total heat input to the steam generating unit derived from the combustion of fuel in the affected duct burner.

Compliance with the emissions limits under § 60.44a(d)(1) is determined by the three-run average (nominal 1- hour runs) for the initial performance tests. Thereafter, compliance with the NOx limits established in the PSD permit shall demonstrate compliance with NOx limit specified in NSPS Subpart Da.

In accordance with § 60.46a(k)(3), when an affected duct burner steam generating unit utilizes a common steam turbine with one or more affected duct burner steam generating units, the owner or operator shall either:

Determine compliance with the applicable NOx emissions limits by measuring the emissions combined with the emissions from the other units utilizing the common steam turbine; or

Develop, demonstrate, and provide information satisfactory to the Administrator on methods for apportioning the combined gross energy output from the steam turbine for each of the affected duct burners. The Administrator may approve such demonstrated substitute methods for apportioning the combined gross energy output measured at the steam turbine whenever the demonstration ensures accurate estimation of emissions regulated under Part 60.

§ 60.47a Emission Monitoring.

In accordance with § 60.47a(o), the owner or operator of a duct burner, as described in § 60.41a, which is subject to the NOx standards of § 60.44a(a)(1) or (d)(1) is not required to install or operate a continuous emissions monitoring system to measure NOX emissions; a wattmeter to measure gross electrical output; meters to measure steam flow, temperature, and pressure; and a continuous flow monitoring system to measure the flow of exhaust gases discharged to the atmosphere.

§ 60.48a Compliance Determination Procedures and Methods.

In accordance with § 60.48a (d)(1), EPA Method 19 shall be used to determine the NOx emission rate when demonstrating compliance with the NOx standard specified in § 60.44a. In accordance with § 60.48a(f), electric utility combined cycle gas turbines are performance tested for particulate matter, sulfur dioxide, and nitrogen oxides using the procedures of Method 19. The sulfur dioxide and nitrogen oxides emission rates from the gas turbine used in Method 19 calculations are determined when the gas turbine is performance tested under subpart GG. The potential uncontrolled particulate matter emission rate from a gas turbine is defined as 17 ng/J (0.04 lb/million Btu) heat input.

§ 60.49a Reporting requirements.

Compliance with reporting requirements of the PSD permit ensure compliance with the requirements of NSPS Subpart Da.

The Unit 8 gas turbines are regulated as Emissions Units 011, 012, 017, and 018.

The Unit 3 and 4 gas turbines are regulated as Emissions Units 003, 004, 005 and 006.

Updated 4/27/06

Source [44 FR 52798, Sept. 10, 1979, as amended at 52 FR 42434, Nov. 5, 1987; 65 FR 61759, Oct. 17, 2000; 69 FR 41346, July 8, 2004]

Subpart GG-Standards of Performance for Stationary Gas Turbines

§ 60.330 Applicability and designation of affected facility.

(a) The provisions of this subpart are applicable to the following affected facilities: All stationary gas turbines with a heat input at peak load equal to or greater than 10.7 gigajoules (10 million Btu) per hour, based on the lower heating value of the fuel fired.

(b) Any facility under paragraph (a) of this section which commences construction, modification, or reconstruction after October 3, 1977, is subject to the requirements of this part except as provided in paragraphs (e) and (j) of § 60.332.

§ 60.331 Definitions.

As used in this subpart, all terms not defined herein shall have the meaning given them in the Act and in subpart A of this part.

(a) Stationary gas turbine means any simple cycle gas turbine, regenerative cycle gas turbine or any gas turbine portion of a combined cycle steam/electric generating system that is not self propelled. It may, however, be mounted on a vehicle for portability.

(b) Simple cycle gas turbine means any stationary gas turbine which does not recover heat from the gas turbine exhaust gases to preheat the inlet combustion air to the gas turbine, or which does not recover heat from the gas turbine exhaust gases to heat water or generate steam.

(c) Regenerative cycle gas turbine means any stationary gas turbine which recovers heat from the gas turbine exhaust gases to preheat the inlet combustion air to the gas turbine.

(d) Combined cycle gas turbine means any stationary gas turbine which recovers heat from the gas turbine exhaust gases to heat water or generate steam.

(e) Emergency gas turbine means any stationary gas turbine which operates as a mechanical or electrical power source only when the primary power source for a facility has been rendered inoperable by an emergency situation.

(f) Ice fog means an atmospheric suspension of highly reflective ice crystals.

(g) ISO standard day conditions means 288 degrees Kelvin, 60 percent relative humidity and 101.3 kilopascals pressure.

(h) Efficiency means the gas turbine manufacturer's rated heat rate at peak load in terms of heat input per unit of power output based on the lower heating value of the fuel.

(i) Peak load means 100 percent of the manufacturer's design capacity of the gas turbine at ISO standard day conditions.

(j) Base load means the load level at which a gas turbine is normally operated.

(k) Fire-fighting turbine means any stationary gas turbine that is used solely to pump water for extinguishing fires.

(l) Turbines employed in oil/gas production or oil/gas transportation means any stationary gas turbine used to provide power to extract crude oil/natural gas from the earth or to move crude oil/natural gas, or products refined from these substances through pipelines.

(m) A Metropolitan Statistical Area or MSA as defined by the Department of Commerce.

(n) Offshore platform gas turbines means any stationary gas turbine located on a platform in an ocean.

(o) Garrison facility means any permanent military installation.

(p) Gas turbine model means a group of gas turbines having the same nominal air flow, combuster inlet pressure, combuster inlet temperature, firing temperature, turbine inlet temperature and turbine inlet pressure.

(q) Electric utility stationary gas turbine means any stationary gas turbine constructed for the purpose of supplying more than one-third of its potential electric output capacity to any utility power distribution system for sale.

(r) Emergency fuel is a fuel fired by a gas turbine only during circumstances, such as natural gas supply curtailment or breakdown of delivery system, that make it impossible to fire natural gas in the gas turbine.

(s) Unit operating hour means a clock hour during which any fuel is combusted in the affected unit. If the unit combusts fuel for the entire clock hour, it is considered to be a full unit operating hour. If the unit combusts fuel for only part of the clock hour, it is considered to be a partial unit operating hour.

(t) Excess emissions means a specified averaging period over which either:

(1) The NO_X emissions are higher than the applicable emission limit in Sec. 60.332;

(2) The total sulfur content of the fuel being combusted in the affected facility exceeds the limit specified in Sec. 60.333; or

(3) The recorded value of a particular monitored parameter is outside the acceptable range specified in the parameter monitoring plan for the affected unit.

(u) Natural gas means a naturally occurring fluid mixture of hydrocarbons (e.g., methane, ethane, or propane) produced in geological formations beneath the Earth's surface that maintains a gaseous state at standard atmospheric temperature and pressure under ordinary conditions. Natural gas contains 20.0 grains or less of total sulfur per 100 standard cubic feet. Equivalents of this in other units are as follows: 0.068 weight percent total sulfur, 680 parts per million by weight (ppmw) total sulfur, and 338 parts per million by volume (ppmv) at 20 degrees Celsius total sulfur. Additionally, natural gas must either be composed of at least 70 percent methane by volume or have a gross calorific value between 950 and 1100 British thermal units (Btu) per standard cubic foot. Natural gas does not include the following gaseous fuels: landfill gas, digester gas, refinery gas, sour gas, blast furnace gas, coal-derived gas, producer gas, coke oven gas, or any gaseous fuel produced in a process which might result in highly variable sulfur content or heating value.

(v) Duct burner means a device that combusts fuel and that is placed in the exhaust duct from another source, such as a stationary gas turbine, internal combustion engine, kiln, etc., to allow the firing of additional fuel to heat the exhaust gases before the exhaust gases enter a heat recovery steam generating unit.

(w) Lean premix stationary combustion turbine means any stationary combustion turbine where the air and fuel are thoroughly mixed to form a lean mixture for combustion in the combustor. Mixing may occur before or in the combustion chamber. A unit which is capable of operating in both lean premix and diffusion flame modes is considered a lean premix stationary combustion turbine when it is in the lean premix mode, and it is considered a diffusion flame stationary combustion turbine when it is in the diffusion flame mode.

(x) Diffusion flame stationary combustion turbine means any stationary combustion turbine where fuel and air are injected at the combustor and are mixed only by diffusion prior to ignition. A unit which is capable of operating in both lean premix and diffusion flame modes is considered a lean premix stationary combustion turbine when it is in the lean premix mode, and it is considered a diffusion flame stationary combustion turbine when it is in the diffusion flame mode.

(y) Unit operating day means a 24-hour period between 12:00 midnight and the following midnight during which any fuel is combusted at any time in the unit. It is not necessary for fuel to be combusted continuously for the entire 24-hour period.

§ 60.332 Standard for nitrogen oxides.

(a) On and after the date on which the performance test required by § 60.8 is completed, every owner or operator subject to the provisions of this subpart as specified in paragraphs (b), (c), and (d) of this section shall comply with one of the following, except as provided in paragraphs (e), (f), (g), (h), (i), (j), (k), and (l) of this section.

(1) No owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any stationary gas turbine, any gases which contain nitrogen oxides in excess of:

$$STD = 0.0075\frac{(14.4)}{Y} - F$$

where:

STD = allowable ISO corrected (if required as given in Sec. 60.335(b)(1)) NO_X emission concentration (percent by volume at 15 percent oxygen and on a dry basis),
Y = manufacturer's rated heat rate at manufacturer's rated load (kilojoules per watt hour) or, actual measured heat rate based on lower heating value of fuel as measured at actual peak load for the facility. The value of Y shall not exceed 14.4 kilojoules per watt hour, and
F = NO_X emission allowance for fuel-bound nitrogen as defined in paragraph (a)(4) of this section.

(2) No owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any stationary gas turbine, any gases which contain nitrogen oxides in excess of:

$$STD = 0.0150\frac{(14.4)}{Y} - F$$

where:
STD = allowable ISO corrected (if required as given in Sec. 60.335(b)(1)) NO_X emission concentration (percent by volume at 15 percent oxygen and on a dry basis),
Y = manufacturer's rated heat rate at manufacturer's rated peak load (kilojoules per watt hour), or actual measured heat rate based on lower heating value of fuel as measured at actual peak load for the facility. The value of Y shall not exceed 14.4 kilojoules per watt hour, and
F = NOX emission allowance for fuel-bound nitrogen as defined in paragraph (a)(4) of this section.

(3) The use of F in paragraphs (a)(1) and (2) of this seciton is optional. That is, the owner or operator may choose to apply a NO_X allowance for fuel-bound nitrogen and determine the appropriate F-value in accordance with paragraph (a)(4) of this section or may accept an F-value of zero.

(4) If the owner or operator elects to apply a NO_X emission allowance for fuel-bound nitrogen, F shall be defined according to the nitrogen content of the fuel during the most recent performance test required under Sec. 60.8 as follows:

Fuel-bound nitrogen (% by weight)	F (NO_X% by volume)

$N \leq 0.015$.....	0
$0.015 < N \leq 0.1$.....	0.04(N)
$0.1 < N \leq 0.25$.....	0.004+0.0067(N-0.1)
$N > 0.25$.....	0.005

Where:
N = the nitrogen content of the fuel (percent by weight).or:
Manufacturers may develop and submit to EPA custom fuel-bound nitrogen allowances for each gas turbine model they manufacture. These fuel-bound nitrogen allowances shall be substantiated with data and must be approved for use by the Administrator before the initial performance
test required by Sec. 60.8. Notices of approval of custom fuel-bound nitrogen allowances will be published in the Federal Register.

(b) Electric utility stationary gas turbines with a heat input at peak load greater than 107.2 gigajoules per hour (100 million Btu/hour) based on the lower heating value of the fuel fired shall comply with the provisions of paragraph (a)(1) of this section.

(c) Stationary gas turbines with a heat input at peak load equal to or greater than 10.7 gigajoules per hour (10 million Btu/hour) but less than or equal to 107.2 gigajoules per hour (100 million Btu/hour) based on the lower heating value of the fuel fired, shall comply with the provisions of paragraph (a)(2) of this section.

(d) Stationary gas turbines with a manufacturer's rated base load at ISO conditions of 30 megawatts or less except as provided in § 60.332(b) shall comply with paragraph (a)(2) of this section.

(e) Stationary gas turbines with a heat input at peak load equal to or greater than 10.7 gigajoules per hour (10 million Btu/hour) but less than or equal to 107.2 gigajoules per hour (100 million Btu/hour) based on the lower heating value of the fuel fired and that have commenced construction prior to October 3, 1982 are exempt from paragraph (a) of this section.

(f) Stationary gas turbines using water or steam injection for control of NO_X emissions are exempt from paragraph (a) when ice fog is deemed a traffic hazard by the owner or operator of the gas turbine.

(g) Emergency gas turbines, military gas turbines for use in other than a garrison facility, military gas turbines installed for use as military training facilities, and fire fighting gas turbines are exempt from paragraph (a) of this section.

(h) Stationary gas turbines engaged by manufacturers in research and development of equipment for both gas turbine emission control techniques and gas turbine efficiency improvements are exempt from paragraph (a) on a case-by-case basis as determined by the Administrator.

(i) Exemptions from the requirements of paragraph (a) of this section will be granted on a case-by-case basis as determined by the Administrator in specific geographical areas where mandatory water restrictions are required by governmental agencies because of drought conditions. These exemptions will be allowed only while the mandatory water restrictions are in effect.

(j) Stationary gas turbines with a heat input at peak load greater than 107.2 gigajoules per hour that commenced construction, modification, or reconstruction between the dates of October 3, 1977, and January 27, 1982, and were required in the September 10, 1979, Federal Register (44 FR 52792) to comply with paragraph (a)(1) of this section, except electric utility stationary gas turbines, are exempt from paragraph (a) of this section.

(k) Stationary gas turbines with a heat input greater than or equal to 10.7 gigajoules per hour (10 million Btu/hour) when fired with natural gas are exempt from paragraph (a)(2) of this section when being fired with an emergency fuel.

(l) Regenerative cycle gas turbines with a heat input less than or equal to 107.2 gigajoules per hour (100 million Btu/hour) are exempt from paragraph (a) of this section.

§ 60.333 Standard for sulfur dioxide.

On and after the date on which the performance test required to be conducted by § 60.8 is completed, every owner or operator subject to the provision of this subpart shall comply with one or the other of the following conditions:

(a) No owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any stationary gas turbine any gases which contain sulfur dioxide in excess of 0.015 percent by volume at 15 percent oxygen and on a dry basis.

(b) No owner or operator subject to the provisions of this subpart shall burn in any stationary gas turbine any fuel which contains total sulfur in excess of 0.8 percent by weight (8000 ppmw).

§ 60.334 Monitoring of operations.

(a) Except as provided in paragraph (b) of this section, the owner or operator of any stationary gas turbine subject to the provisions of this subpart and using water or steam injection to control NO_X emissions shall install, calibrate, maintain and operate a continuous monitoring system to monitor and record the fuel consumption and the ratio of water or steam to fuel being fired in the turbine.

(b) The owner or operator of any stationary gas turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and which uses water or steam injection to control NO_X emissions may, as an alternative to operating the continuous monitoring system described in paragraph (a) of this section, install, certify, maintain, operate, and quality-assure a continuous emission monitoring system (CEMS) consisting of NO_X and O2 monitors. As an alternative, a CO2 monitor may be used to adjust the measured NO_X concentrations to 15 percent O2 by either converting the CO2 hourly averages to equivalent O2 concentrations using Equation F-14a or F-14b in appendix F to part 75 of this chapter and making the adjustments to 15 percent O2, or by using the CO2 readings directly to make the adjustments, as described in Method 20. If the option to use a CEMS is chosen, the CEMS shall be installed, certified, maintained and operated as follows:

(1) Each CEMS must be installed and certified according to PS 2 and 3 (for diluent) of 40 CFR part 60, appendix B, except the 7-day calibration drift is based on unit operating days, not calendar days. Appendix F, Procedure 1 is not required. The relative accuracy test audit (RATA) of the NO_X and diluent monitors may be performed individually or on a combined basis, i.e., the relative accuracy tests of the CEMS may be performed either:

(i) On a ppm basis (for NO_X) and a percent O2 basis for oxygen; or

(ii) On a ppm at 15 percent O2 basis; or

(iii) On a ppm basis (for NO_X) and a percent CO2 basis (for a CO2 monitor that uses the procedures in Method 20 to correct the NO_X data to 15 percent O2).

(2) As specified in Sec. 60.13(e)(2), during each full unit operating hour, each monitor must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each 15-minute quadrant of the hour, to validate the hour. For partial unit operating hours, at least one valid data point must be obtained for each quadrant of the hour in which the unit operates. For unit operating hours in which required quality assurance and maintenance activities are performed on the CEMS, a minimum of two valid data points (one in each of two quadrants) are required to validate the hour.

(3) For purposes of identifying excess emissions, CEMS data must be reduced to hourly averages as specified in Sec. 60.13(h).

(i) For each unit operating hour in which a valid hourly average, as described in paragraph (b)(2) of this section, is obtained for both NO_X and diluent, the data acquisition and handling system must calculate and record the hourly NO_X emissions in the units of the applicable NO_X emission standard under Sec. 60.332(a), i.e., percent NO_X by volume, dry basis, corrected to 15 percent O2 and International Organization for Standardization (ISO) standard conditions (if required as given in Sec. 60.335(b)(1)). For any hour in which the hourly average O2 concentration exceeds 19.0 percent O2, a diluent cap value of 19.0 percent O2 may be used in the emission calculations.

(ii) A worst case ISO correction factor may be calculated and applied using historical ambient data. For the purpose of this calculation, substitute the maximum humidity of ambient air (Ho), minimum ambient temperature (Ta), and minimum combustor inlet absolute pressure (Po) into the ISO correction equation.

(iii) If the owner or operator has installed a NO_X CEMS to meet the requirements of part 75 of this chapter, and is continuing to meet the ongoing requirements of part 75 of this chapter, the CEMS may be used to meet the requirements of this section, except that the missing data substitution methodology provided for at 40 CFR part 75, subpart D, is not required for purposes of identifying excess emissions. Instead, periods of missing CEMS data are to be reported as monitor downtime in the excess emissions and monitoring performance report required in Sec. 60.7(c).

(c) For any turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and which does not use steam or water injection to control NOX emissions, the owner or operator may, but is not required to, for purposes of determining excess emissions, use a CEMS that meets the requirements of paragraph (b) of this section. Also, if the owner or operator has previously submitted and received EPA, State, or local permitting authority approval of a procedure for monitoring compliance with the applicable NOX emission limit under Sec. 60.332, that approved procedure may continue to be used.

(d) The owner or operator of any new turbine constructed after July 8, 2004, and which uses water or steam injection to control NO_X emissions may elect to use either the requirements in
paragraph (a) of this section for continuous water or steam to fuel ratio monitoring or may use a NO_X CEMS installed, certified, operated, maintained, and quality-assured as described in paragraph (b) of this section.

(e) The owner or operator of any new turbine that commences construction after July 8, 2004, and which does not use water or steam injection to control NOX emissions, may, but is not required to, elect to use a NOX CEMS installed, certified, operated, maintained, and quality-assured as described in paragraph (b) of this section. Other acceptable monitoring approaches include periodic testing approved by EPA or the State or local permitting authority or continuous parameter monitoring as described in paragraph (f) of this section.

(f) The owner or operator of a new turbine that commences construction after July 8, 2004, which does not use water or steam injection to control NOX emissions may, but is not required to, perform continuous parameter monitoring as follows:

(1) For a diffusion flame turbine without add-on selective catalytic reduction controls (SCR), the owner or operator shall define at least four parameters indicative of the unit's NO_X formation characteristics and shall monitor these parameters continuously.

(2) For any lean premix stationary combustion turbine, the owner or operator shall continuously monitor the appropriate parameters to determine whether the unit is operating in low-NOX mode.

(3) For any turbine that uses SCR to reduce NO_X emissions, the owner or operator shall continuously monitor appropriate parameters to verify the proper operation of the emission controls.

(4) For affected units that are also regulated under part 75 of this chapter, if the owner or operator elects to monitor NO_X emission rate using the methodology in appendix E to part 75 of this chapter, or the low mass emissions methodology in Sec. 75.19 of this chapter, the requirements of this paragraph (f) may be met by performing the parametric monitoring described in section 2.3 of appendix E or in Sec. 75.19(c)(1)(iv)(H) of this chapter.

(g) The steam or water to fuel ratio or other parameters that are continuously monitored as described in paragraphs (a), (d) or (f) of this section shall be monitored during the performance test required under Sec. 60.8, to establish acceptable values and ranges. The owner or operator may supplement the performance test data with engineering analyses, design specifications, manufacturer's recommendations and other relevant information to define the acceptable parametric ranges more precisely. The owner or operator shall develop and keep on-site a parameter monitoring plan which explains the procedures used to document proper operation of the NO_X emission controls. The plan shall include the parameter(s) monitored and the acceptable range(s) of the parameter(s) as well as the basis for designating the parameter(s) and acceptable range(s). Any supplemental data such as engineering analyses, design specifications, manufacturer's recommendations and other relevant information shall be included in the monitoring plan. For affected units that are also subject to part 75 of this chapter and that use the low mass emissions methodology in Sec. 75.19 of this chapter or the NO_X emission measurement methodology in appendix E to part 75, the owner or operator may meet the requirements of this paragraph by developing and keeping on-site (or at a central location for unmanned facilities) a quality-assurance plan, as described in Sec. 75.19 (e)(5) or in section 2.3 of appendix E and section 1.3.6 of appendix B to part 75 of this chapter.

(h) The owner or operator of any stationary gas turbine subject to the provisions of this subpart:

(1) Shall monitor the total sulfur content of the fuel being fired in the turbine, except as provided in paragraph (h)(3) of this section. The sulfur content of the fuel must be determined using total sulfur methods described in Sec. 60.335(b)(10). Alternatively, if the total sulfur content of the gaseous fuel during the most recent performance test was less than 0.4 weight percent (4000 ppmw), ASTM D4084-82, 94, D5504-01, D6228-98, or Gas Processors Association Standard 2377-86 (all of which are incorporated by reference-see Sec. 60.17), which measure the major sulfur compounds may be used; and

(2) Shall monitor the nitrogen content of the fuel combusted in the turbine, if the owner or operator claims an allowance for fuel bound nitrogen (i.e., if an F-value greater than zero is being or will be used by the owner or operator to calculate STD in Sec. 60.332). The nitrogen content of the fuel shall be determined using methods described in Sec. 60.335(b)(9) or an approved alternative.

(3) Notwithstanding the provisions of paragraph (h)(1) of this section, the owner or operator may elect not to monitor the total sulfur content of the gaseous fuel combusted in the turbine, if the gaseous fuel is demonstrated to meet the definition of natural gas in Sec. 60.331(u), regardless of whether an existing custom schedule approved by the administrator for subpart GG requires such monitoring. The owner or operator shall use one of the following sources of information to make the required demonstration:

(i) The gas quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the gaseous fuel, specifying that the maximum total sulfur content of the fuel is 20.0 grains/100 scf or less; or

(ii) Representative fuel sampling data which show that the sulfur content of the gaseous fuel does not exceed 20 grains/100 scf. At a minimum, the amount of fuel sampling data specified in section 2.3.1.4 or 2.3.2.4 of appendix D to part 75 of this chapter is required.

(4) For any turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and for which a custom fuel monitoring schedule has previously been approved, the owner or operator may, without submitting a special petition to the Administrator, continue monitoring on this schedule.

(i) The frequency of determining the sulfur and nitrogen content of the fuel shall be as follows:

(1) Fuel oil. For fuel oil, use one of the total sulfur sampling options and the associated sampling frequency described in sections 2.2.3, 2.2.4.1, 2.2.4.2, and 2.2.4.3 of appendix D to part 75 of this chapter (i.e., flow proportional sampling, daily sampling, sampling from the unit's storage tank after each addition of fuel to the tank, or sampling each delivery prior to combining it with fuel oil already in the intended storage tank). If an emission allowance is being claimed for fuel-bound nitrogen, the nitrogen content of the oil shall be determined and recorded once per unit operating day.

(2) Gaseous fuel. Any applicable nitrogen content value of the gaseous fuel shall be determined and recorded once per unit operating day. For owners and operators that elect not to demonstrate sulfur content using options in paragraph (h)(3) of this section, and for which the fuel is supplied without intermediate bulk storage, the sulfur content value of the gaseous fuel shall be determined and recorded once per unit operating day.

(3) Custom schedules. Notwithstanding the requirements of paragraph (i)(2) of this section, operators or fuel vendors may develop custom schedules for determination of the total sulfur content of gaseous fuels, based on the design and operation of the affected facility and the characteristics of the fuel supply. Except as provided in paragraphs (i)(3)(i) and (i)(3)(ii) of this section, custom schedules shall be substantiated with data and shall be approved by the Administrator before they can be used to comply with the standard in Sec. 60.333.

(i) The two custom sulfur monitoring schedules set forth in paragraphs (i)(3)(i)(A) through (D) and in paragraph (i)(3)(ii) of this section are acceptable, without prior Administrative approval:

(A) The owner or operator shall obtain daily total sulfur content measurements for 30 consecutive unit operating days, using the applicable methods specified in this subpart. Based on the results of the 30 daily samples, the required frequency for subsequent monitoring of the fuel's total sulfur content shall be as specified in paragraph (i)(3)(i)(B), (C), or (D) of this section, as applicable.

(B) If none of the 30 daily measurements of the fuel's total sulfur content exceeds 0.4 weight percent (4000 ppmw), subsequent sulfur content monitoring may be performed at 12 month intervals. If any of the samples taken at 12-month intervals has a total sulfur content between 0.4 and 0.8 weight percent (4000 and 8000 ppmw), follow the procedures in paragraph (i)(3)(i)(C) of this section. If any measurement exceeds 0.8 weight percent (8000 ppmw), follow the procedures in paragraph (i)(3)(i)(D) of this section.

(C) If at least one of the 30 daily measurements of the fuel's total sulfur content is between 0.4 and 0.8 weight percent (4000 and 8000 ppmw), but none exceeds 0.8 weight percent (8000 ppmw), then:

(1) Collect and analyze a sample every 30 days for three months. If any sulfur content measurement exceeds 0.8 weight percent (8000 ppmw), follow the procedures in paragraph (i)(3)(i)(D) of this section. Otherwise, follow the procedures in paragraph (i)(3)(i)(C)(2) of this section.

(2) Begin monitoring at 6-month intervals for 12 months. If any sulfur content measurement exceeds 0.8 weight percent (8000 ppmw), follow the procedures in paragraph (i)(3)(i)(D) of this section. Otherwise, follow the procedures in paragraph (i)(3)(i)(C)(3) of this section.

(3) Begin monitoring at 12-month intervals. If any sulfur content measurement exceeds 0.8 weight percent (8000 ppmw), follow the procedures in paragraph (i)(3)(i)(D) of this section. Otherwise, continue to monitor at this frequency.

(D) If a sulfur content measurement exceeds 0.8 weight percent (8000 ppmw), immediately begin daily monitoring according to paragraph (i)(3)(i)(A) of this section. Daily monitoring shall continue until 30 consecutive daily samples, each having a sulfur content no greater than 0.8 weight percent (8000 ppmw), are obtained. At that point, the applicable procedures of paragraph (i)(3)(i)(B) or (C) of this section shall be followed.

(ii) The owner or operator may use the data collected from the 720-hour sulfur sampling demonstration described in section 2.3.6 of appendix D to part 75 of this chapter to determine a custom sulfur sampling schedule, as follows:

(A) If the maximum fuel sulfur content obtained from the 720 hourly samples does not exceed 20 grains/100 scf (i.e., the maximum total sulfur content of natural gas as defined in Sec. 60.331(u)), no additional monitoring of the sulfur content of the gas is required, for the purposes of this subpart.

(B) If the maximum fuel sulfur content obtained from any of the 720 hourly samples exceeds 20 grains/100 scf, but none of the sulfur content values (when converted to weight percent sulfur) exceeds 0.4 weight percent (4000 ppmw), then the minimum required sampling frequency shall be one sample at 12 month intervals.

(C) If any sample result exceeds 0.4 weight percent sulfur (4000 ppmw), but none exceeds 0.8 weight percent sulfur (8000 ppmw), follow the provisions of paragraph (i)(3)(i)(C) of this section.

(D) If the sulfur content of any of the 720 hourly samples exceeds 0.8 weight percent (8000 ppmw), follow the provisions of paragraph (i)(3)(i)(D) of this section.

(j) For each affected unit that elects to continuously monitor parameters or emissions, or to periodically determine the fuel sulfur content or fuel nitrogen content under this subpart, the owner or operator shall submit reports of excess emissions and monitor downtime, in accordance with Sec. 60.7(c). Excess emissions shall be reported for all periods of unit operation, including startup, shutdown and malfunction. For the purpose of reports required under Sec. 60.7(c), periods of excess emissions and monitor downtime that shall be reported are defined as follows:

(1) Nitrogen oxides.

(i) For turbines using water or steam to fuel ratio monitoring:

(A) An excess emission shall be any unit operating hour for which the average steam or water to fuel ratio, as measured by the continuous monitoring system, falls below the acceptable steam or water to fuel ratio needed to demonstrate compliance with Sec. 60.332, as established during the performance test required in Sec. 60.8. Any unit operating hour in which no water or steam is injected into the turbine shall also be considered an excess emission.

(B) A period of monitor downtime shall be any unit operating hour in which water or steam is injected into the turbine, but the essential parametric data needed to determine the steam or water to fuel ratio are unavailable or invalid.

(C) Each report shall include the average steam or water to fuel ratio, average fuel consumption, ambient conditions (temperature, pressure, and humidity), gas turbine load, and (if applicable) the nitrogen content of the fuel during each excess emission. You do not have to report ambient conditions if you opt to use the worst case ISO correction factor as specified in Sec. 60.334(b)(3)(ii), or if you are not using the ISO correction equation under the provisions of Sec. 60.335(b)(1).

(ii) If the owner or operator elects to take an emission allowance for fuel bound nitrogen, then excess emissions and periods of monitor downtime are as described in paragraphs (j)(1)(ii)(A) and (B) of this section.

(A) An excess emission shall be the period of time during which the fuel-bound nitrogen (N) is greater than the value measured during the performance test required in Sec. 60.8 and used to determine the allowance. The excess emission begins on the date and hour of the sample which shows that N is greater than the

performance test value, and ends with the date and hour of a subsequent sample which shows a fuel nitrogen content less than or equal to the performance test value.

(B) A period of monitor downtime begins when a required sample is not taken by its due date. A period of monitor downtime also begins on the date and hour that a required sample is taken, if invalid results are obtained. The period of monitor downtime ends on the date and hour of the next valid sample.

(iii) For turbines using NO_X and diluent CEMS:

(A) An hour of excess emissions shall be any unit operating hour in which the 4-hour rolling average NO_X concentration exceeds the applicable emission limit in Sec. 60.332(a)(1) or (2). For the purposes of this subpart, a ``4-hour rolling average NO_X concentration" is the arithmetic average of the average NO_X concentration measured by the CEMS for a given hour (corrected to 15 percent O2 and, if required under Sec. 60.335(b)(1), to ISO standard conditions) and the three unit operating hour average NO_X concentrations immediately preceding that unit operating hour.

(B) A period of monitor downtime shall be any unit operating hour in which sufficient data are not obtained to validate the hour, for either NO_X concentration or diluent (or both).

(C) Each report shall include the ambient conditions (temperature, pressure, and humidity) at the time of the excess emission period and (if the owner or operator has claimed an emission allowance for fuel bound nitrogen) the nitrogen content of the fuel during the period of excess emissions. You do not have to report ambient conditions if you opt to use the worst case ISO correction factor as specified in Sec. 60.334(b)(3)(ii), or if you are not using the ISO correction equation under the provisions of Sec. 60.335(b)(1).

(iv) For owners or operators that elect, under paragraph (f) of this section, to monitor combustion parameters or parameters that document proper operation of the NOX emission controls:

(A) An excess emission shall be a 4-hour rolling unit operating hour average in which any monitored parameter does not achieve the target value or is outside the acceptable range defined in the parameter monitoring plan for the unit.

(B) A period of monitor downtime shall be a unit operating hour in which any of the required parametric data are either not recorded or are invalid.

(2) Sulfur dioxide. If the owner or operator is required to monitor the sulfur content of the fuel under paragraph (h) of this section:

(i) For samples of gaseous fuel and for oil samples obtained using daily sampling, flow proportional sampling, or sampling from the unit's storage tank, an excess emission occurs each unit operating hour included in the period beginning on the date and hour of any sample for which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8 weight percent and ending on the date and hour that a subsequent sample is taken that demonstrates compliance with the sulfur limit.

(ii) If the option to sample each delivery of fuel oil has been selected, the owner or operator shall immediately switch to one of the other oil sampling options (i.e., daily sampling, flow proportional sampling, or sampling from the unit's storage tank) if the sulfur content of a delivery exceeds 0.8 weight percent. The owner or operator shall continue to use one of the other sampling options until all of the oil from the delivery has been combusted, and shall evaluate excess emissions according to paragraph (j)(2)(i) of this section. When all of the fuel from the delivery has been burned, the owner or operator may resume using the as-delivered sampling option.

(iii) A period of monitor downtime begins when a required sample is not taken by its due date. A period of monitor downtime also begins on the date and hour of a required sample, if invalid results are obtained. The period of monitor downtime shall include only unit operating hours, and ends on the date and hour of the next valid sample.

(3) *Ice fog.* Each period during which an exemption provided in § 60.332(f) is in effect shall be reported in writing to the Administrator quarterly. For each period the ambient conditions existing during the period, the date and time the air pollution control system was deactivated, and the date and time the air pollution control system was reactivated shall be reported. All quarterly reports shall be postmarked by the 30th day following the end of each calendar quarter.

(4) *Emergency fuel.* Each period during which an exemption provided in § 60.332(k) is in effect shall be included in the report required in § 60.7(c). For each period, the type, reasons, and duration of the firing of the emergency fuel shall be reported.

(5) All reports required under Sec. 60.7(c) shall be postmarked by the 30th day following the end of each 6-month period.

Sec. 60.335 Test methods and procedures.

(a) The owner or operator shall conduct the performance tests required in Sec. 60.8, using either

(1) EPA Method 20,

(2) ASTM D6522-00 (incorporated by reference, see Sec. 60.17), or

(3) EPA Method 7E and either EPA Method 3 or 3A in appendix A to this part, to determine NO_X and diluent concentration.

(4) Sampling traverse points are to be selected following Method 20 or Method 1, (non-particulate procedures) and sampled for equal time intervals. The sampling shall be performed with a traversing single-hole probe or, if feasible, with a stationary multi-hole probe that samples each of the points sequentially. Alternatively, a multi-hole probe designed and documented to sample equal volumes from each hole may be used to sample simultaneously at the required points.

(5) Notwithstanding paragraph (a)(4) of this section, the owner or operator may test at few points than are specified in Method 1 or Method 20 if the following conditions are met:

(i) You may perform a stratification test for NO_X and diluent pursuant to

(A) [Reserved]

(B) The procedures specified in section 6.5.6.1(a) through (e) appendix A to part 75 of this chapter.

(ii) Once the stratification sampling is completed, the owner or operator may use the following alternative sample point selection criteria for the performance test:

(A) If each of the individual traverse point NO_X concentrations, normalized to 15 percent O2, is within 10 percent of the mean normalized concentration for all
traverse points, then you may use 3 points (located either 16.7, 50.0, and 83.3 percent of the way across the stack or duct, or, for circular stacks or ducts greater than 2.4 meters (7.8 feet) in diameter, at 0.4, 1.2, and 2.0 meters from the wall). The 3 points shall be located along the measurement line that exhibited the highest average normalized NO_X concentration during the stratification test; or

(B) If each of the individual traverse point NO_X concentrations, normalized to 15 percent O2, is within 5 percent of the mean normalized concentration for all
traverse points, then you may sample at a single point, located at least 1 meter from the stack wall or at the stack centroid.

(6) Other acceptable alternative reference methods and procedures are given in paragraph (c) of this section.

(b) The owner or operator shall determine compliance with the applicable nitrogen oxides emission limitation in Sec. 60.332 and shall meet the performance test requirements of Sec. 60.8 as follows:

(1) For each run of the performance test, the mean nitrogen oxides emission concentration (NO_{Xo}) corrected to 15 percent O2 shall be corrected to ISO standard conditions using the following equation. Notwithstanding this requirement, use of the ISO correction equation is optional for: Lean premix stationary combustion turbines; units used in association with heat recovery steam generators (HRSG) equipped with duct burners; and units equipped with add-on emission control devices:

$$NO_X=(NO_{Xo})(P_r/P_o)^{0.5}\, e^{19\,(H_o-0.00633)}\,(288[\mathrm{deg}]K/Ta)^{1.53}$$

Where:
NO_X = emission concentration of NO_X at 15 percent O2 and ISO standard ambient conditions, ppm by volume, dry basis,
NO_{Xo} = mean observed NO_X concentration, ppm by volume, dry basis, at 15 percent O2,
P_r = reference combustor inlet absolute pressure at 101.3 kilopascals ambient pressure, mm Hg,
P_o = observed combustor inlet absolute pressure at test, mm Hg,
H_o = observed humidity of ambient air, g H2O/g air,
e = transcendental constant, 2.718, and
T_a = ambient temperature, [deg]K.

(2) The 3-run performance test required by Sec. 60.8 must be performed within 5 percent at 30, 50, 75, and 90-to-100 percent of peak load or at four evenly-spaced load points in the normal operating range of the gas turbine, including the minimum point in the operating range and 90-to-100 percent of peak load, or at the highest achievable load point if 90-to-100 percent of peak load cannot be physically achieved in practice. If the turbine combusts both oil and gas as primary or

backup fuels, separate performance testing is required for each fuel. Notwithstanding theserequirements, performance testing is not required for any emergency
fuel (as defined in Sec. 60.331).

(3) For a combined cycle turbine system with supplemental heat (duct burner), the owner or operator may elect to measure the turbine NO_X emissions after the duct burner rather than directly after the turbine. If the owner or operator elects to use this alternative sampling location, the applicable NO_X emission limit in Sec. 60.332 for the combustion turbine must still be met.

(4) If water or steam injection is used to control NO_X with no additional post-combustion NO_X control and the owner or operator chooses to monitor the steam or water to fuel ratio in accordance with Sec. 60.334(a), then that monitoring system must be operated concurrently with each EPA Method 20, ASTM D6522-00 (incorporated by reference, see Sec. 60.17), or EPA Method 7E run and shall be used to determine the fuel consumption and the steam or water to fuel ratio necessary to comply with the applicable Sec. 60.332 NO_X emission limit.

(5) If the owner operator elects to claim an emission allowance for fuel bound nitrogen as described in Sec. 60.332, then concurrently with each reference method run, a representative sample of the fuel used shall be collected and analyzed, following the applicable procedures described in Sec. 60.335(b)(9). These data shall be used to determine the maximum fuel nitrogen content for which the established water (or steam) to fuel ratio will be valid.

(6) If the owner or operator elects to install a CEMS, the performance evaluation of the CEMS may either be conducted separately (as described in paragraph (b)(7) of this section) or as part of the initial performance test of the affected unit.

(7) If the owner or operator elects to install and certify a NO_X CEMS under Sec. 60.334(e), then the initial performance test required under Sec. 60.8 may be done in the following alternative manner:

(i) Perform a minimum of 9 reference method runs, with a minimum time per run of 21 minutes, at a single load level, between 90 and 100 percent of peak (or the highest physically achievable) load.

(ii) Use the test data both to demonstrate compliance with the applicable NO_X emission limit under Sec. 60.332 and to provide the required reference method data for the RATA of the CEMS described under Sec. 60.334(b).

(iii) The requirement to test at three additional load levels is waived.

(8) If the owner or operator elects under Sec. 60.334(f) to monitor combustion parameters or parameters indicative of proper operation of NOX emission controls, the appropriate parameters shall be continuously monitored and recorded during each run of the initial performance test, to establish acceptable operating ranges, for purposes of the parameter monitoring plan for the affected unit, as specified in Sec. 60.334(g).

(9) To determine the fuel bound nitrogen content of fuel being fired (if an emission allowance is claimed for fuel bound nitrogen), the owner or operator may use equipment and procedures meeting the requirements of:

(i) For liquid fuels, ASTM D2597-94 (Reapproved 1999), D6366-99, D4629-02, D5762-02 (all of which are incorporated by reference, see Sec. 60.17); or

(ii) For gaseous fuels, shall use analytical methods and procedures that are accurate to within 5 percent of the instrument range and are approved by the Administrator.

(10) If the owner or operator is required under Sec. 60.334(i)(1) or (3) to periodically determine the sulfur content of the fuel combusted in the turbine, a minimum of three fuel samples shall be collected during the performance test. Analyze the samples for the total sulfur content of the fuel using:

(i) For liquid fuels, ASTM D129-00, D2622-98, D4294-02, D1266-98, D5453-00 or D1552-01 (all of which are incorporated by reference, see Sec. 60.17); or

(ii) For gaseous fuels, ASTM D1072-80, 90 (Reapproved 1994); D3246-81, 92, 96; D4468-85 (Reapproved 2000); or D6667-01 (all of which are incorporated by reference, see Sec. 60.17). The applicable ranges of some ASTM methods mentioned above are not adequate to measure the levels of sulfur in some fuel gases. Dilution of samples before analysis (with verification of the dilution ratio) may be used, subject to the prior approval of the Administrator.

(11) The fuel analyses required under paragraphs (b)(9) and (b)(10) of this section may be performed by the owner or operator, a service contractor retained by the owner or operator, the fuel vendor, or any other qualified agency.

(c) The owner or operator may use the following as alternatives to the reference methods and procedures specified in this section:

(1) Instead of using the equation in paragraph (b)(1) of this section, manufacturers may develop ambient condition correction factors to adjust the nitrogen oxides emission level measured by the performance test as provided in Sec. 60.8 to ISO standard day conditions.

PSD-FL-327 Permit Monitoring of Operations

The PSD permit requires keeping monthly records of the fuel sulfur content of natural gas. Appropriate test methods are also specified in the PSD permit. These requirements constitute a custom fuel monitoring schedule that ensures compliance with the NSPS requirements for monitoring the nitrogen and sulfur contents of the fuels. The requirement to monitor the nitrogen contents of these fuels is waived due to negligible concentrations and the PSD conditions that require compliance with the NOx standards to be demonstrated by CEMS. The CEMS shall be installed, operated, and maintained in accordance with the requirements of the PSD permit.

For the purpose of reports required under § 60.7(c), periods of excess emissions that shall be reported are: any 1-hour period of NOx emissions greater than the NSPS standard; and any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8% sulfur by weight (for sulfur dioxide emissions). The permittee shall submit a semiannual report of emissions in excess of the NSPS standards.

PSD-FL-327 Permit Test Methods and Procedures

Tests for nitrogen oxides emissions shall be conducted in accordance with the schedule and methods specified in the PSD permit. The permittee is allowed to conduct initial performance tests at a single load because a NOx monitor shall be used to demonstrate compliance with the specified NOx limits. The permittee is allowed to make the initial compliance demonstration for NOx emissions using certified CEMS data, provided that compliance is based on a minimum of three test runs representing a total of at least three hours of data, and that the CEMS be calibrated in accordance with the procedure in section 6.2.3 of Method 20 following each run. Alternatively, initial compliance may be demonstrated using data collected during the initial relative accuracy test audit (RATA) performed on the NOx monitor. The permittee is not required to have the NOx monitor continuously correct NOx emissions concentrations to ISO conditions. However, the permittee shall make the correction when required by the Department or Administrator.

The permittee shall use the methods specified in the PSD permit to demonstrate compliance with the fuel sulfur specification, which will ensure compliance with the NSPS standard.

APPENDIX SC

STANDARD CONDITIONS

Unless otherwise specified in the permit, the following conditions apply to all emissions units and activities at this facility.

EMISSIONS AND CONTROLS

1. Plant Operation - Problems: If temporarily unable to comply with any of the conditions of the permit due to breakdown of equipment or destruction by fire, wind or other cause, the permittee shall notify each Compliance Authority as soon as possible, but at least within one working day, excluding weekends and holidays. The notification shall include: pertinent information as to the cause of the problem; steps being taken to correct the problem and prevent future recurrence; and, where applicable, the owner's intent toward reconstruction of destroyed facilities. Such notification does not release the permittee from any liability for failure to comply with the conditions of this permit or the regulations. [Rule 62-4.130, F.A.C.]

2. Circumvention: The permittee shall not circumvent the air pollution control equipment or allow the emission of air pollutants without this equipment operating properly. [Rule 62-210.650, F.A.C.]

3. Excess Emissions Allowed: Excess emissions resulting from startup, shutdown or malfunction of any emissions unit shall be permitted providing (1) best operational practices to minimize emissions are adhered to and (2) the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration. [Rule 62-210.700(1), F.A.C.]

4. Excess Emissions Prohibited: Excess emissions caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. [Rule 62-210.700(4), F.A.C.]

5. Excess Emissions - Notification: In case of excess emissions resulting from malfunctions, the permitee shall notify the Department or the appropriate Local Program in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department. [Rule 62-210.700(6), F.A.C.]

6. VOC or OS Emissions: No person shall store, pump, handle, process, load, unload or use in any process or installation, volatile organic compounds or organic solvents without applying known and existing vapor emission control devices or systems deemed necessary and ordered by the Department. [Rule 62-296.320(1), F.A.C.]

7. Objectionable Odor Prohibited: No person shall cause, suffer, allow or permit the discharge of air pollutants, which cause or contribute to an objectionable odor. An "objectionable odor" means any odor present in the outdoor atmosphere which by itself or in combination with other odors, is or may be harmful or injurious to human health or welfare, which unreasonably interferes with the comfortable use and enjoyment of life or property, or which creates a nuisance. [Rules 62-296.320(2) and62-210.200(203), F.A.C.]

8. General Visible Emissions: No person shall cause, let, permit, suffer or allow to be discharged into the atmosphere the emissions of air pollutants from any activity equal to or greater than 20 percent opacity. [Rule 62-296.320(4)(b)1, F.A.C.]

9. Unconfined Particulate Emissions: During the construction period, unconfined particulate matter emissions shall be minimized by dust suppressing techniques such as covering and/or application of water or chemicals to the affected areas, as necessary. [Rule 62-296.320(4)(c), F.A.C.]

TESTING REQUIREMENTS

10. Required Number of Test Runs: For mass emission limitations, a compliance test shall consist of three complete and separate determinations of the total air pollutant emission rate through the test section of the stack or duct and three complete and separate determinations of any applicable process variables corresponding to the three distinct time periods during which the stack emission rate was measured; provided, however, that three complete and separate determinations shall not be required if the process variables are not subject to variation during a compliance test, or if three determinations are not necessary in order to calculate the unit's emission rate. The three required test runs shall be completed within one consecutive five-day period. In the event that a sample is lost or one of the three runs must be discontinued because of circumstances beyond the control of the owner or operator, and a valid third run cannot be obtained within the five-day period allowed for the test, the Secretary or his or her designee may accept the results of two complete runs as proof of compliance, provided that the arithmetic mean of the two complete runs is at least 20% below the allowable emission limiting standard. [Rule 62-297.310(1), F.A.C.]

11. Operating Rate During Testing: Testing of emissions shall be conducted with the emissions unit operating at permitted capacity. Permitted capacity is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. If it is impractical to test at permitted capacity, an emissions unit may be tested at less than the maximum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test rate until a new test is conducted. Once the unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity. [Rule 62-297.310(2), F.A.C.]

12. Calculation of Emission Rate: For each emissions performance test, the indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the three separate test runs unless otherwise specified in a particular test method or applicable rule. [Rule 62-297.310(3), F.A.C.]

13. Test Procedures: Tests shall be conducted in accordance with all applicable requirements of Chapter 62-297, F.A.C.

    a. Required Sampling Time. Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes. The minimum observation period for a visible emissions compliance test shall be thirty (30) minutes. The observation period shall include the period during which the highest opacity can reasonably be expected to occur.

    b. Minimum Sample Volume. Unless otherwise specified in the applicable rule or test method, the minimum sample volume per run shall be 25 dry standard cubic feet.

    c. Calibration of Sampling Equipment. Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1, F.A.C.

    [Rule 62-297.310(4), F.A.C.]

14. Determination of Process Variables

    a. Required Equipment. The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.

    b. Accuracy of Equipment. Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.

    [Rule 62-297.310(5), F.A.C.]

15. Sampling Facilities: The permittee shall install permanent stack sampling ports and provide sampling facilities that meet the requirements of Rule 62-297.310(6), F.A.C.

16. Test Notification: The owner or operator shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator. [Rule 62-297.310(7)(a)9, F.A.C.]

17. Special Compliance Tests: When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it shall require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department. [Rule 62-297.310(7)(b), F.A.C.]

18. Test Reports: The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department on the results of each such test. The required test report shall be filed with the Department as soon as practical but no later than 45 days after the last sampling run of each test is completed. The test report shall provide

sufficient detail on the emissions unit tested and the test procedures used to allow the Department to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report, other than for an EPA or DEP Method 9 test, shall provide the following information:

1) The type, location, and designation of the emissions unit tested.
2) The facility at which the emissions unit is located.
3) The owner or operator of the emissions unit.
4) The normal type and amount of fuels used and materials processed, and the types and amounts of fuels used and material processed during each test run.
5) The means, raw data and computations used to determine the amount of fuels used and materials processed, if necessary to determine compliance with an applicable emission limiting standard.
6) The type of air pollution control devices installed on the emissions unit, their general condition, their normal operating parameters (pressure drops, total operating current and GPM scrubber water), and their operating parameters during each test run.
7) A sketch of the duct within 8 stack diameters upstream and 2 stack diameters downstream of the sampling ports, including the distance to any upstream and downstream bends or other flow disturbances.
8) The date, starting time and duration of each sampling run.
9) The test procedures used, including any alternative procedures authorized pursuant to Rule 62-297.620, F.A.C. Where optional procedures are authorized in this chapter, indicate which option was used.
10) The number of points sampled and configuration and location of the sampling plane.
11) For each sampling point for each run, the dry gas meter reading, velocity head, pressure drop across the stack, temperatures, average meter temperatures and sample time per point.
12) The type, manufacturer and configuration of the sampling equipment used.
13) Data related to the required calibration of the test equipment.
14) Data on the identification, processing and weights of all filters used.
15) Data on the types and amounts of any chemical solutions used.
16) Data on the amount of pollutant collected from each sampling probe, the filters, and the impingers, are reported separately for the compliance test.
17) The names of individuals who furnished the process variable data, conducted the test, analyzed the samples and prepared the report.
18) All measured and calculated data required to be determined by each applicable test procedure for each run.
19) The detailed calculations for one run that relate the collected data to the calculated emission rate.
20) The applicable emission standard, and the resulting maximum allowable emission rate for the emissions unit, plus the test result in the same form and unit of measure.
21) A certification that, to the knowledge of the owner or his authorized agent, all data submitted are true and correct. When a compliance test is conducted for the Department or its agent, the person who conducts the test shall provide the certification with respect to the test procedures used. The owner or his authorized agent shall certify that all data required and provided to the person conducting the test are true and correct to his knowledge.

[Rule 62-297.310(8), F.A.C.]

RECORDS AND REPORTS

19. Records Retention: All measurements, records, and other data required by this permit shall be documented in a permanent, legible format and retained for at least five (5) years following the date on which such measurements, records, or data are recorded. Records shall be made available to the Department upon request. [Rules 62-4.160(14) and 62-213.440(1)(b)2, F.A.C.]

20. Annual Operating Report: The permittee shall submit an annual report that summarizes the actual operating rates and emissions from this facility. Annual operating reports shall be submitted to the Compliance Authority by March 1st of each year. [Rule 62-210.370(2), F.A.C.]

APPENDIX DDDDD

NESHAPS REQUIREMENTS FOR INDUSTRIAL, COMMERCIAL, AND INSTITUTIONAL BOILERS AND PROCESS HEATERS

The auxiliary boiler is subject to the applicable requirements of this 40 CFR 63, Subpart DDDDD. The provisions of this Subpart may be provided in full upon request.

Source: Federal Register Dated 9/12/04

What This Subpart Covers
63.7480 What is the purpose of this subpart?
63.7485 Am I subject to this subpart?
63.7490 What is the affected source of this subpart?
63.7491 Are any boilers or process heaters not subject to this subpart?
63.7495 When do I have to comply with this subpart?

Emission Limits and Work Practice Standards
63.7499 What are the subcategories of boilers and process heaters?
63.7500 What emission limits, work practice standards, and operating limits must I meet?

General Compliance Requirements
63.7505 What are my general requirements for complying with this subpart?
63.7506 Do any boilers or process heaters have limited requirements?
63.7507 What are the health-based compliance alternatives for the hydrogen chloride (HCl) and total selected metals (TSM) standards?

Testing, Fuel Analyses, and Initial Compliance Requirements
63.7510 What are my initial compliance requirements and by what date must I conduct them?
63.7515 When must I conduct subsequent performance tests or fuel analyses?
63.7520 What performance tests and procedures must I use?
63.7521 What fuel analyses and procedures must I use?
63.7522 Can I use emission averaging to comply with this subpart?
63.7525 What are my monitoring, installation, operation, and maintenance requirements?
63.7530 How do I demonstrate initial compliance with the emission limits and work practice standards?

Continuous Compliance Requirements
63.7535 How do I monitor and collect data to demonstrate continuous compliance?
63.7540 How do I demonstrate continuous compliance with the emission limits and work practice standards?
63.7541 How do I demonstrate continuous compliance under the emission averaging provision?

Notifications, Reports, and Records
63.7545 What notifications must I submit and when?
63.7550 What reports must I submit and when?
63.7555 What records must I keep?
63.7560 In what form and how long must I keep my records?

Other Requirements and Information
63.7565 What parts of the General Provisions apply to me?
63.7570 Who implements and enforces this subpart?
63.7575 What definitions apply to this subpart?

Tables to Subpart DDDDD of Part 63

Table 1 to Subpart DDDDD of Part 63--Emission Limits and Work Practice Standards
Table 2 to Subpart DDDDD of Part 63--Operating Limits for Boilers and Process Heaters With Particulate Matter Emission Limits
Table 3 to Subpart DDDDD of Part 63--Operating Limits for Boilers and Process Heaters With Mercury Emission Limits and Boilers and Process Heaters That Choose to Comply With the Alternative Total Selected Metals Emission Limits
Table 4 to Subpart DDDDD of Part 63--Operating Limits for Boilers and Process Heaters With Hydrogen Chloride Emission Limits
Table 5 to Subpart DDDDD of Part 63--Performance Testing Requirements
Table 6 to Subpart DDDDD of Part 63--Fuel Analysis Requirements
Table 7 to Subpart DDDDD of Part 63--Establishing Operating Limits
Table 8 to Subpart DDDDD of Part 63--Demonstrating Continuous Compliance
Table 9 to Subpart DDDDD of Part 63--Reporting Requirements
Table 10 to Subpart DDDDD of Part 63--Applicability of General Provisions to Subpart DDDDD (See Appendix B)

Appendices to Subpart DDDDD

Appendix A to Subpart DDDDD--Methodology and Criteria for Demonstrating Eligibility for the Health-Based Compliance Alternatives Specified for the Large Solid Fuel Subcategory
Appendix B to Subpart DDDDD--Applicability of General Provisions to Subpart DDDDD

APPENDIX ZZZZ

NESHAPS REQUIREMENTS FOR STATIONARY RECIPROCATING INTERNAL COMBUSTION ENGINES

The diesel emergency generator (EU 009) is subject to the applicable requirements of this 40 CFR 63, Subpart ZZZZ. The provisions of this Subpart may be provided in full upon request.

Source: Federal Register dated 6/15/04; Effective Date 8/16/04

What This Subpart Covers
63.6580 The purpose of subpart ZZZZ
63.6585 Subject to this subpart
63.6590 Parts of my plant does this subpart cover
63.6595 Compliance with this subpart

Emission Limitations
63.6600 Emission limitations and operating limitations

General Compliance Requirements
63.6605 General requirements for complying with this subpart

Testing and Initial Compliance Requirements
63.6610 Dates to conduct the initial performance tests or other initial compliance demonstrations
63.6615 Subsequent performance tests
63.6620 Performance tests and other procedures
63.6625 Monitoring, installation, operation, and maintenance requirements
63.6630 Initial compliance with the emission limitations and operating limitations

Continuous Compliance Requirements
63.6635 Monitoring and collecting data to demonstrate continuous compliance
63.6640 Continuous compliance with the emission limitations and operating limitations

Notification, Reports, and Records
63.6645 Notifications
63.6650 Reports
63.6655 Records
63.6660 Records form and retention

Other Requirements and Information
63.6665 General Provisions
63.6670 implementation and enforcement
63.6675 Definitions

Tables to Subpart ZZZZ of Part 63
Table 1a to Subpart ZZZZ of Part 63--Emission Limitations for Existing, New, and Reconstructed Spark Ignition, 4SRB Stationary RICE
Table 1b to Subpart ZZZZ of Part 63--Operating Limitations for Existing, New, and Reconstructed Spark Ignition, 4SRB Stationary RICE
Table 2a to Subpart ZZZZ of Part 63--Emission Limitations for New and Reconstructed Lean Burn and Compression Ignition Stationary RICE

Table 2b to Subpart ZZZZ of Part 63--Operating Limitations for New and Reconstructed Lean Burn and Compression Ignition Stationary RICE
Table 3 to Subpart ZZZZ of Part 63--Subsequent Performance Tests
Table 4 to Subpart ZZZZ of Part 63--Requirements for Performance Tests
Table 5 to Subpart ZZZZ of Part 63--Initial Compliance with Emission Limitations and Operating Limitations
Table 6 to Subpart ZZZZ of Part 63--Continuous Compliance with Emission Limitations and Operating Limitations
Table 7 to Subpart ZZZZ of Part 63--Requirements for Reports
Table 8 to Subpart ZZZZ of Part 63--Applicability of General Provisions to Subpart ZZZZ- See Appendix A to Subpart ZZZZ

Appendix A to Subpart ZZZZ of Part 63- Applicability of General Provisions to Subpart ZZZZ