Appendix CP- 2- Compliance Plan

Y1. Compliance Schedule. The facility currently operates a 190 MMBtu/hr, No. 2 Fuel Oil fired boiler. The boiler is operated only when another boiler (either Nos. 5 Power Boiler, 7 Power Boiler, 4 Recovery Boiler, or 5 Recovery Boiler) is operated at a reduced rate or is shutdown. The boiler is subject to the requirements of 40 CFR Part 60, Subpart Db - Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units. The boiler had been included in the initial Title V Operation Permit, No. 0890003-001-AV, but had not been permitted under an air Construction Permit. The facility applied for a construction after-the-fact permit on October 1, 2002. Construction Permit No. 0890003-008-AC, is currently in a pending status.

Because the applicant included this boiler in the Title V Operation Permit Renewal application, a Compliance Plan has been incorporated into this Title V Operation Permit Renewal to address the requirements of the air construction permit. The permittee shall meet the following milestones:

E.U. ID. No.	Milestone	Milestone Date
034	Compliance Testing conducted and test reports submitted pursuant to requirements of air construction permit	Pursuant to the timeframes established in the air construction permit.
034	Responsible Official to submit "Certification of Compliance", addressing this emissions unit, indicating what is not in compliance, when non-compliance started, the degree or amount of non-compliance, the duration of non-compliant operations, steps taken to identify and correct non-compliant conditions, and actions (with time table), to correct any current non-compliant conditions and achieve compliance.	No later than 12 months from the date of issuance of the resulting air construction permit/PSD Determination