

**COMPLIANCE ASSURANCE MONITORING PLAN
(CAM PLAN)**

for

**Osceola Farms Company
Sugar Mill**

RECEIVED

JUN 27 2005

D.E.R. - SCOTT BAKER

TABLE OF CONTENTS

| | | |
|-------|---|-----|
| 1.0 | EMISSION UNITS REQUIRING CAM PLANS..... | 1-1 |
| 1.1 | CAM RULE APPLICABILITY DEFINITION | 1-1 |
| 1.2 | EMISSIONS UNITS REQUIRING CAM PLANS | 1-2 |
| 1.2.1 | BOILER NO. 2 (EU 002) | 1-2 |
| 1.2.2 | BOILER NO. 3 (EU 003) | 1-3 |
| 1.2.3 | BOILER NO. 4 (EU 004) | 1-3 |
| 1.2.4 | BOILER NO. 5 (EU 005) | 1-4 |
| 1.2.5 | BOILER NO. 6 (EU 006) | 1-4 |
| 2.0 | PARTICULATE MATTER EMISSIONS FROM BOILER NO. 2..... | 2-1 |
| 2.1 | EMISSIONS UNIT IDENTIFICATION | 2-1 |
| 2.2 | APPLICABLE REGULATIONS, EMISSIONS LIMITS, AND MONITORING REQUIREMENTS..... | 2-1 |
| 2.3 | CONTROL TECHNOLOGY DESCRIPTION..... | 2-1 |
| 2.4 | MONITORING APPROACH..... | 2-2 |
| 2.5 | JUSTIFICATION..... | 2-2 |
| 3.0 | PARTICULATE MATTER EMISSIONS FROM BOILER NO. 3..... | 3-1 |
| 3.1 | EMISSIONS UNIT IDENTIFICATION | 3-1 |
| 3.2 | APPLICABLE REGULATIONS, EMISSIONS LIMITS, AND MONITORING REQUIREMENTS..... | 3-1 |
| 3.3 | CONTROL TECHNOLOGY DESCRIPTION..... | 3-1 |
| 3.4 | MONITORING APPROACH..... | 3-2 |
| 3.5 | JUSTIFICATION..... | 3-2 |
| 4.0 | PARTICULATE MATTER EMISSIONS FROM BOILER NO. 4..... | 3-4 |
| 4.1 | EMISSIONS UNIT IDENTIFICATION | 4-1 |
| 4.2 | APPLICABLE REGULATIONS, EMISSIONS LIMITS, AND MONITORING REQUIREMENTS..... | 4-1 |
| 4.3 | CONTROL TECHNOLOGY DESCRIPTION..... | 4-1 |
| 4.4 | MONITORING APPROACH..... | 4-2 |
| 4.5 | JUSTIFICATION..... | 4-2 |
| 5.0 | PARTICULATE MATTER EMISSIONS FROM BOILER NO. 5..... | 5-1 |
| 5.1 | EMISSIONS UNIT IDENTIFICATION | 5-1 |
| 5.2 | APPLICABLE REGULATIONS, EMISSIONS LIMITS, AND MONITORING REQUIREMENTS..... | 5-1 |
| 5.3 | CONTROL TECHNOLOGY DESCRIPTION..... | 5-1 |
| 5.4 | MONITORING APPROACH..... | 5-2 |

| | | |
|-----|---|-----|
| 5.5 | JUSTIFICATION..... | 5-2 |
| 6.0 | PARTICULATE MATTER EMISSIONS FROM BOILER NO. 6..... | 6-1 |
| 6.1 | EMISSIONS UNIT IDENTIFICATION | 6-1 |
| 6.2 | APPLICABLE REGULATIONS, EMISSIONS LIMITS, AND MONITORING REQUIREMENTS..... | 6-1 |
| 6.3 | CONTROL TECHNOLOGY DESCRIPTION..... | 6-1 |
| 6.4 | MONITORING APPROACH..... | 6-2 |
| 6.5 | JUSTIFICATION..... | 6-2 |

LIST OF TABLES

| | |
|---------|---|
| Table 1 | CAM Applicability Determination for Osceola Farms Company |
|---------|---|

LIST OF FIGURES

| | |
|------------|---|
| Figure 2-1 | Osceola Farms Boiler No. 2 (South Scrubber); PM vs. Pressure Drop |
| Figure 2-2 | Osceola Farms Boiler No. 2 (North Scrubber); PM vs. Pressure Drop |
| Figure 2-3 | Osceola Farms Boiler No. 2; PM vs. Total Water Flow Rate |
| Figure 3-1 | Osceola Farms Boiler No. 3; PM vs. Pressure Drop |
| Figure 3-2 | Osceola Farms Boiler No. 3; PM vs. Total Water Flow Rate |
| Figure 4-1 | Osceola Farms Boiler No. 4 (North Scrubber); PM vs. Pressure Drop |
| Figure 4-2 | Osceola Farms Boiler No. 4 (South Scrubber); PM vs. Pressure Drop |
| Figure 4-3 | Osceola Farms Boiler No. 4; PM vs. Water Flow Rate |
| Figure 5-1 | Osceola Farms Boiler No. 5 (West Scrubber); PM vs. Pressure Drop |
| Figure 5-2 | Osceola Farms Boiler No. 5 (East Scrubber); PM vs. Pressure Drop |
| Figure 5-3 | Osceola Farms Boiler No. 5; PM vs. Total Water Flow Rate |
| Figure 6-1 | Osceola Farms Boiler No. 6; PM vs. Pressure Drop |
| Figure 6-2 | Osceola Farms Boiler No. 6; PM vs. Water Flow Rate |

LIST OF APPENDICES

| | |
|------------|--|
| Appendix A | Signature Pages |
| Appendix B | Historic PM Compliance Test Data for Boiler Nos. 1-6 |

1.0 EMISSION UNITS REQUIRING CAM PLANS

1.1 CAM RULE APPLICABILITY DEFINITION

On June 15, 1998, the Florida Department of Environmental Protection (FDEP) issued a Title V Air Operation permit (Permit No. 0990019-003-AV) to Osceola Farms Company for operation of its Pahokee sugar mill. This permit expires on October 30, 2005. In order to renew the permit, a renewal application was submitted to the Florida Department of Environmental Protection (FDEP) on May 2, 2005.

As part of the Title V renewal application, a Compliance Assurance Monitoring (CAM) Plan must be submitted as required by regulations adopted in Title 40, Part 64 of the Code of Federal Regulations (40 CFR 64). This regulation has been incorporated by reference in Rule 62-204.800, Florida Administrative Code (F.A.C.), and implemented in Rule 62-213.440, F. A. C.

CAM plans are required for all Title V permitted emissions units using control devices to meet federally enforceable emission limits or standards, and that have pre-control emissions greater than "major" source thresholds. The term "major" is defined as in the Title V regulations (40 CFR 70), but applied on a source-by-source basis. For most non-hazardous pollutants, the major source threshold is 100 tons per year (TPY). For hazardous air pollutants (HAPs), the threshold is 10 TPY for an individual HAP, and 25 TPY for total HAPs combined.

The CAM rules contain specific exemptions from applicability of CAM. Specifically exempted from CAM are emission limitations or standards promulgated under the following: Stratospheric Ozone Regulations contained in 40 CFR 82; the Acid Rain Program contained in 40 CFR 72; or those that are part of an emissions cap included in the Title V Permit. Also exempt are emission limitations or standards proposed after November 15, 1990, under the following: New Source Performance Standards (NSPS) contained in 40 CFR 60; and National Emission Standards for Hazardous Air Pollutants (NESHAPs) promulgated in 40 CFR 63. These limitations and standards have monitoring requirements equivalent to CAM included as part of the standard.

Inherent process equipment (IPE), or equipment that may have the effect of controlling emissions but is installed for the primary purpose of product recovery or raw material recovery, is also exempt from CAM (40 CFR 64.1). In addition, CAM does not apply to any emission limit or standard for which

the Title V permit specifies a continuous compliance determination method [40 CFR 64.2(b)(1)(vi)], provided that the method does not include an assumed control device emission reduction factor that could be affected by the actual operation and maintenance of the control device.

1.2 EMISSIONS UNITS REQUIRING CAM PLANS

A review of emission units at the Osceola Farms sugar mill was conducted to determine the applicability of the CAM rule. This evaluation was conducted for each emissions unit and regulated pollutant. First, the existence of a "control device" as defined by the CAM Rule was determined on a source-by-source basis for each pollutant. Those emissions units without control devices were eliminated from further consideration. The remaining emissions units were then evaluated on a pollutant-by-pollutant basis to determine if a control device was used to meet a federally enforceable emission limit or standard.

Each pollutant without a federally enforceable emission limit or standard, emitted from a given emissions unit, was eliminated from further consideration. Uncontrolled annual emissions were then calculated for each remaining source-pollutant combination. If uncontrolled emissions for a pollutant emitted from a given emissions unit were below major source thresholds, as defined by the CAM rule, that pollutant was not further considered. Specific exemptions to the applicability of the CAM rule were also considered in this evaluation.

A summary of the results of this evaluation process is presented in Table 1. Each pollutant-specific emissions unit at the Osceola Farms sugar mill, and its applicability to CAM, is described in the following sections.

1.2.1 BOILER NO. 2 (EU 002)

Boiler No. 2 is fired by carbonaceous fuel and No. 6 fuel oil. Boiler No. 2 has a maximum capacity of 140,000 pounds per hour (lb/hr) steam (24-hour block average). This corresponds to a maximum heat input rate of 280 million British thermal units per hour (MMBtu/hr) (24-hour average). The boiler can fire No. 6 fuel oil as a supplemental fuel at a maximum heat input rate of 82.5 MMBtu/hr.

Boiler No. 2 has federally enforceable emission limits for particulate matter (PM), nitrogen oxides (NO_x), sulfur dioxide (SO₂), and volatile organic compounds (VOC). Boiler No. 2 utilizes a spray impingement type wet scrubber to control PM emissions. As shown in Table 1, uncontrolled PM

emissions are greater than 100 TPY. Since a federally enforceable emission limit exists for PM, a control device is used to comply with the PM emission limit, and uncontrolled PM emissions are greater than 100 TPY, a CAM plan is required for PM for Boiler No. 2. Since there is no control device controlling NO_x, SO₂, or VOC emissions from Boiler No. 2, CAM plans for NO_x, SO₂, and VOC are not required.

1.2.2 BOILER NO. 3 (EU 003)

Boiler No. 3 is fired by carbonaceous fuel and No. 6 fuel oil. Boiler No. 3 has a maximum capacity of 150,000 lb/hr steam (1-hour average) and a maximum heat input rate of 292 MMBtu/hr (1-hour average). The boiler can fire No. 6 fuel oil as a supplemental fuel at a maximum heat input rate of 75.4 MMBtu/hr.

Boiler No. 3 has federally enforceable emission limits for PM, NO_x, SO₂, VOC, and carbon monoxide (CO). Boiler No. 3 utilizes a spray impingement type wet scrubber to control PM emissions. As shown in Table 1, uncontrolled PM emissions are greater than 100 TPY. Since a federally enforceable emission limit exists for PM, a control device is used to comply with the PM emission limit, and uncontrolled PM emissions are greater than 100 TPY, a CAM plan is required for PM for Boiler No. 3. Since there is no control device controlling NO_x, SO₂, VOC, or CO emissions from Boiler No. 3, CAM plans for NO_x, SO₂, VOC, and CO are not required.

1.2.3 BOILER NO. 4 (EU 004)

Boiler No. 4 is fired by carbonaceous fuel and No. 6 fuel oil. Boiler No. 4 has a maximum capacity of 140,000 lb/hr steam (24-hour average). This corresponds to a maximum heat input rate of 280 MMBtu/hr (24-hour average). The boiler can fire No. 6 fuel oil as a supplemental at a maximum heat input rate of 82.5 MMBtu/hr.

Boiler No. 4 has federally enforceable emission limits for PM, NO_x, SO₂, and VOC. Boiler No. 4 utilizes a spray impingement type wet scrubber to control PM emissions. As shown in Table 1, uncontrolled PM emissions are greater than 100 TPY. Since a federally enforceable emission limit exists for PM, a control device is used to comply with the PM emission limit, and uncontrolled PM emissions are greater than 100 TPY, a CAM plan is required for PM for Boiler No. 4. Since there is no control device controlling NO_x, SO₂, or VOC emissions from Boiler No. 4, CAM plans for NO_x, SO₂, and VOC are not required.

1.2.4 BOILER NO. 5 (EU 005)

Boiler No. 5 is fired by carbonaceous fuel and No. 6 fuel oil. Boiler No. 5 has a maximum capacity of 165,000 lb/hr steam (24-hour average). This corresponds to a maximum heat input rate of 330 MMBtu/hr (24-hour average). The boiler can also fire No. 6 fuel oil as a supplemental fuel at a maximum heat input rate of 82.5 MMBtu/hr.

Boiler No. 5 has federally enforceable emission limits for PM, NO_x, SO₂, and VOC. Boiler No. 5 utilizes a spray impingement type wet scrubber to control PM emissions. As shown in Table 1, uncontrolled PM emissions are greater than 100 TPY. Since a federally enforceable emission limit exists for PM, a control device is used to comply with the PM emission limit, and uncontrolled PM emissions are greater than 100 TPY, a CAM plan is required for PM for Boiler No. 5. Since there is no control device controlling NO_x, SO₂, or VOC emissions from Boiler No. 5, CAM plans for NO_x, SO₂, and VOC are not required.

1.2.5 BOILER NO. 6 (EU 006)

Boiler No. 6 is fired by carbonaceous fuel and No. 6 fuel oil. Boiler No. 6 has a maximum capacity of 195,000 lb/hr (1-hour average), corresponding to a maximum heat input rate of 379 MMBtu/hr (1-hour average). The boiler can fire No. 6 fuel oil as a supplemental fuel at a maximum heat input rate of 75.4 MMBtu/hr (1-hour average).

Boiler No. 6 has federally enforceable emission limits for PM, NO_x, SO₂, VOC, and CO. Boiler No. 6 utilizes a spray impingement type wet scrubber to control PM emissions. As shown in Table 1, uncontrolled PM emissions are greater than 100 TPY. Since a federally enforceable emission limit exists for PM, a control device is used to comply with the PM emission limit, and uncontrolled PM emissions are greater than 100 TPY, a CAM plan is required for PM for Boiler No. 6. Since there is no control device controlling NO_x, SO₂, VOC, or CO emissions from Boiler No. 6, CAM plans for NO_x, SO₂, VOC, and CO are not required.

Table 1. CAM Applicability Determination for Osceola Farms Company

| Emission Source | Title V EU ID | Control Equipment | Pollutants with Emission Limits | Uncontrolled Emission Rate (TPY) | CAM Plan Required? (Yes/No) | Comments |
|-----------------|------------------|----------------------|------------------------------------|--|-----------------------------------|-------------------------------------|
| Boiler No. 2 | 002 | Wet Scrubber | PM | >100 TPY | Yes | PM uncontrolled emissions >100 TPY. |
| | | None | NO _x | -- | No | No control device. |
| | | None | SO ₂ | -- | No | No control device. |
| | | None | VOC | -- | No | No control device. |
| Boiler No. 3 | 003 | Wet Scrubber | PM | >100 TPY | Yes | PM uncontrolled emissions >100 TPY. |
| | | None | NO _x | -- | No | No control device. |
| | | None | CO | -- | No | No control device. |
| | | None | SO ₂ | -- | No | No control device. |
| | | None | VOC | -- | No | No control device. |
| Boiler No. 4 | 004 | Wet Scrubber | PM | >100 TPY | Yes | PM uncontrolled emissions >100 TPY. |
| | | None | NO _x | -- | No | No control device. |
| | | None | SO ₂ | -- | No | No control device. |
| | | None | VOC | -- | No | No control device. |
| Boiler No. 5 | 005 | Wet Scrubber | PM | >100 TPY | Yes | PM uncontrolled emissions >100 TPY. |
| | | None | NO _x | -- | No | No control device. |
| | | None | SO ₂ | -- | No | No control device. |
| | | None | VOC | -- | No | No control device. |
| Boiler No. 6 | 006 | Wet Scrubber | PM | >100 TPY | Yes | PM uncontrolled emissions >100 TPY. |
| | | None | NO _x | -- | No | No control device. |
| | | None | CO | -- | No | No control device. |
| | | None | SO ₂ | -- | No | No control device. |
| | | None | VOC | -- | No | No control device. |

2.0 PARTICULATE MATTER EMISSIONS FROM BOILER NO. 2

2.1 EMISSIONS UNIT IDENTIFICATION

Boiler No. 2—EU ID 002

2.2 APPLICABLE REGULATIONS, EMISSIONS LIMITS, AND MONITORING REQUIREMENTS

Boiler No. 2 has a PM emission limit of 0.2 lb/MMBtu for carbonaceous fuel, plus 0.1 lb/MMBtu for No. 6 fuel oil [Rule 62-296.410(1)(b)2, F.A.C.]. The equivalent potential emissions are 56.0 lb/hr and 108.0 TPY for carbonaceous fuel and 8.3 lb/hr and 9.1 TPY for No. 6 fuel oil. The current visible emissions (VE) limit is 20-percent opacity, with an exception of up to 40-percent opacity for 2 minutes per hour (Permit No. 0990019-003-AV).

PM and VE compliance testing is required annually on Boiler No. 2. In addition, the total pressure drop across the scrubber, the scrubber water inlet pressure, and the scrubber water flow rate must be monitored and recorded at least once per 8-hour shift during each day of operation. The monitors must be properly maintained and functional at all times, except during instrument breakdown, calibration or repair (Permit No. 0990019-003-AV).

2.3 CONTROL TECHNOLOGY DESCRIPTION

PM emissions from Boiler No. 2 are controlled by two identical spray impingement type wet scrubbers operating in parallel. The exhaust gases from the boiler are split, with approximately one-half of the total flow going to one scrubber and one-half going to the other scrubber. Each scrubber exhausts through a separate stack.

The design pressure drop across each scrubber is 4 to 18 inches of water (H₂O). The design scrubber water inlet pressure to each scrubber is 40 to 60 pounds per square inch gauge (psig). The effectiveness of the wet scrubbers is evaluated with an annual stack test and visible emission measurements. A detailed description of the control equipment is included in the Title V renewal application (Attachment OF-EU1-I3).

2.4 MONITORING APPROACH

The monitoring approach is based on monitoring scrubber pressure drop and scrubber water flow rate. The monitoring approach is summarized in the table below:

| Boiler No. 2 | Indicator No. 1 | Indicator No. 2 |
|------------------------------------|---|--|
| Indicator | Pressure drop across each scrubber. | Total water flow rate to both scrubbers. |
| Measurement Approach | Pressure drop is monitored with a manometer. | The scrubber water flow rate is measured using an orifice meter. |
| Indicator Range | An excursion is defined as any pressure drop below 8 in. H ₂ O. Excursions trigger an inspection, corrective action, and a recordkeeping and reporting requirement. | An excursion is defined as any water flow rate below 720 gallons per minute (gpm). Excursions trigger an inspection, corrective action, and a recordkeeping and reporting requirement. |
| Data Representativeness | The monitoring system consists of a manometer which measures the pressure drop across the scrubber. The minimum accuracy of the device is ± 0.1 inches of water gauge pressure. | The scrubber water orifice meter is located on the scrubber liquid supply line. The minimum accuracy of the device is ± 25 gpm of water flow. |
| Verification of Operational Status | NA | NA |
| QA/QC Practices and Criteria | The manometer is maintained in accordance with the manufacturer's recommendations. | The orifice meter is maintained in accordance with the manufacturer's recommendations. |
| Monitoring Frequency | Pressure drop is monitored continuously. | Scrubber water flow rate is monitored continuously. |
| Data Collection Procedures | Reading taken once every eight (8) hours. | Reading taken once every eight (8) hours. |
| Averaging Period | NA | NA |

2.5 JUSTIFICATION

Both pressure drop across the scrubber and water flow rate to the scrubber are recognized parameters for controlling PM emissions with wet scrubbers. The pressure drop is a measure of the energy imparted to the gas stream and therefore the efficiency of the scrubbing process. The water flow rate is a measure of sufficient fresh scrubbing liquid being supplied to the scrubber.

Water delivery pressure is currently monitored, which provides an indication of plugging of the spray nozzles in the scrubber. However, scrubber water flow rate provides a more direct indicator of adequate water supply to the scrubber. Therefore, water delivery pressure is not proposed as a parameter for CAM purposes.

Osceola Farms has sufficient historic test data necessary to establish indicator values for pressure drop and water flow rate to the Boiler No. 2 wet scrubbers. The test data correlating the parameters to the PM emission levels are presented in Figures 2-1 through 2-3. Supporting information is contained in Appendix B.

The proposed parameter minimum values are based on 90 percent of the minimum parameter values recorded during the 1-hour test runs, using the historic test data, when compliance was demonstrated with the PM limit. The calculation of the minimum parameter values are provided below:

Pressure Drop: Minimum test run value = 9 in. H₂O

Minimum parameter value = $9 \times 0.9 = 8.1$ in. H₂O

Water Flow Rate: Minimum test run value = 800 gpm

Minimum parameter value = $800 \times 0.9 = 720$ gpm

Wet scrubber operating parameter values below these minimum parameter values would be indicative of abnormal operation of the wet scrubbers. This methodology is consistent with the establishment of wet scrubber operating limits under 40 CFR 63, Subpart DDDDD, which are the Industrial Boiler/Process Heater maximum achievable control technology (MACT) standards. Boiler No. 2 will be subject to these standards beginning in September 2007.

The CAM regulations generally require that pollutant specific emissions units with the potential to emit greater than 100 TPY collect monitoring data at least four (4) times per hour. However, 40 CFR 63.3(b)(ii) allows the permitting authority to approve a reduced data collection frequency, if appropriate, based on the data collection mechanisms available for a particular parameter.

Osceola has been recording scrubber parameters once per 8-hour shift, according to the current Title V permit conditions. Although Osceola has continuous pressure drop and water flow rate monitors in place, the mechanisms are not in place to continuously record the pressure drop data and create

**Figure 2-2. OFC Boiler No. 2 (North Scrubber)
PM vs. Pressure Drop**





Figure 2-3. OFC Boiler No. 2
PM vs. Total Water Flow Rate



3.0 PARTICULATE MATTER EMISSIONS FROM BOILER NO. 3

3.1 EMISSIONS UNIT IDENTIFICATION

Boiler No. 3—EU ID 003

3.2 APPLICABLE REGULATIONS, EMISSIONS LIMITS, AND MONITORING REQUIREMENTS

Boiler No. 3 has a PM emission limit of 0.2 lb/MMBtu for carbonaceous fuel, plus 0.1 lb/MMBtu for No. 6 fuel oil [Rule 62-296.410(1)(b)2, F.A.C.]. The equivalent potential emissions are 58.4 lb/hr and 112.0 TPY for carbonaceous fuel and 7.5 lb/hr and 5.6 TPY for No. 6 fuel oil. The current VE limit is 20-percent opacity, with an exception of up to 40-percent opacity for 2 minutes per hour (Permit No. 0990019-003-AV).

PM and VE compliance testing is required annually on Boiler No. 3. In addition, the total pressure drop across the scrubber, the scrubber water inlet pressure, and the scrubber water flow rate must be monitored and recorded at least once per 8-hour shift during each day of operation. The monitors must be properly maintained and functional at all times, except during instrument breakdown, calibration, or repair (Permit No. 0990019-003-AV).

3.3 CONTROL TECHNOLOGY DESCRIPTION

PM emissions from Boiler No. 3 are controlled by one spray impingement type wet scrubber. The scrubber exhausts through a single stack. The design pressure drop across the scrubber is 4 to 18 inches H₂O. The design scrubber water inlet pressure is 30 to 60 psig. The design scrubber water flow rate is 300 gallons per minute (gpm), minimum. The effectiveness of the wet scrubbers is evaluated with an annual stack test and visible emission measurements. A detailed description of the control equipment is included in the Title V renewal application (Attachment OF-EU2-I3).

3.4 MONITORING APPROACH

The monitoring approach is based on monitoring scrubber pressure drop and scrubber water flow rate. The monitoring approach is summarized in the table below:

| Boiler No. 3 | Indicator No. 1 | Indicator No. 2 |
|------------------------------------|---|---|
| Indicator | Pressure drop across scrubber. | Total water flow rate to scrubber. |
| Measurement Approach | Pressure drop is monitored with a manometer. | The scrubber water flow rate is measured using an orifice meter. |
| Indicator Range | An excursion is defined as any pressure drop below 10 in. H ₂ O. Excursions trigger an inspection, corrective action, and a recordkeeping and reporting requirement. | An excursion is defined as any water flow rate below 626 gpm. Excursions trigger an inspection, corrective action, and a recordkeeping and reporting requirement. |
| Data Representativeness | The monitoring system consists of a manometer which measures the pressure drop across the scrubber. The minimum accuracy of the device is ± 0.1 inches of water gauge pressure. | The scrubber water orifice meter is located on the scrubber liquid supply line. The minimum accuracy of the device is ± 25 gpm of water flow. |
| Verification of Operational Status | NA | NA |
| QA/QC Practices and Criteria | The manometer is maintained in accordance with the manufacturer's recommendations. | The orifice meter is maintained in accordance with the manufacturer's recommendations. |
| Monitoring Frequency | Pressure drop is monitored continuously. | Scrubber water flow rate is monitored continuously. |
| Data Collection Procedures | Reading taken once every eight (8) hours. | Reading taken once every eight (8) hours. |
| Averaging Period | NA | NA |

3.5 JUSTIFICATION

Both pressure drop across the scrubber and water flow rate to the scrubber are recognized parameters for controlling PM emissions with wet scrubbers. The pressure drop is a measure of the energy imparted to the gas stream and therefore the efficiency of the scrubbing process. The water flow rate is a measure of sufficient fresh scrubbing liquid being supplied to the scrubber.

Water delivery pressure is currently monitored, which provides an indication of plugging of the spray nozzles in the scrubber. However, scrubber water flow rate provides a more direct indicator of adequate water supply to the scrubber. Therefore, water delivery pressure is not proposed as a parameter for CAM purposes.

Osceola Farms has sufficient historic test data necessary to establish indicator values for pressure drop and water flow rate to the Boiler No. 3 wet scrubber. The test data correlating the parameters to the PM emission levels are presented in Figures 3-1 and 3-2. Supporting information is contained in Appendix B.

The proposed parameter minimum values are based on 90 percent of the minimum parameter values recorded during the 1-hour test runs, using the historic test data, when compliance was demonstrated with the PM limit. The calculation of the minimum parameter values are provided below:

Pressure Drop: Minimum test run value = 11 in. H₂O

Minimum parameter value = $11 \times 0.9 = 9.9$ in. H₂O

Water Flow Rate: Minimum test run value = 696 gpm

Minimum parameter value = $696 \times 0.9 = 626$ gpm

Wet scrubber operating parameter values below these minimum parameter values would be indicative of abnormal operation of the wet scrubbers. This methodology is consistent with the establishment of wet scrubber operating limits under 40 CFR 63, Subpart DDDDD, which are the Industrial Boiler/Process Heater MACT standards. Boiler No. 3 will be subject to these standards beginning in September 2007.

The CAM regulations generally require that pollutant specific emissions units with the potential to emit greater than 100 TPY collect monitoring data at least four (4) times per hour. However, 40 CFR 63.3(b)(ii) allows the permitting authority to approve a reduced data collection frequency, if appropriate, based on the data collection mechanisms available for a particular parameter.

Osceola has been recording scrubber parameters once per 8-hour shift, according to the current Title V permit conditions. Although Osceola has continuous pressure drop and water flow rate monitors in place, the mechanisms are not in place to continuously record the pressure drop data and create hourly averages. In addition, the mechanisms are not in place to create hourly averages of the water

flow rate. It is therefore requested that the current recording frequency of once per 8-hour shift be retained for both pressure drop and water flow rate.

Based on collecting data once per 8-hour shift, an excursion would occur whenever any individual reading is below the minimum parameter value. When an excursion occurs, corrective action will be initiated, beginning with an evaluation of the occurrence, to determine the action required (if any) to correct the situation. All excursions will be documented and reported.

Figure 3-1. OFC Boiler No. 3
PM vs. Pressure Drop





Figure 3-2. OFC Boiler No. 3
PM vs. Water Flow Rate



4.0 PARTICULATE MATTER EMISSIONS FROM BOILER NO. 4

4.1 EMISSIONS UNIT IDENTIFICATION

Boiler No. 4—EU ID 004

4.2 APPLICABLE REGULATIONS, EMISSIONS LIMITS, AND MONITORING REQUIREMENTS

Boiler No. 4 has a PM emission limit of 0.3 lb/MMBtu for carbonaceous fuel, plus 0.1 lb/MMBtu for No. 6 fuel oil [Rule 62-296.410(1)(b)2, F.A.C.]. The equivalent potential emissions are 84.0 lb/hr and 161.3 TPY for carbonaceous fuel and 8.3 lb/hr and 9.1 TPY for No. 6 fuel oil. The current VE limit is 30-percent opacity, with an exception of up to 40-percent opacity for 2 minutes per hour (Permit No. 0990019-003-AV).

PM and VE compliance testing is required annually on Boiler No. 4. In addition, the total pressure drop across the scrubber, the scrubber water inlet pressure, and the scrubber water flow rate must be monitored and recorded at least once per 8-hour shift during each day of operation. The monitors must be properly maintained and functional at all times, except during instrument breakdown, calibration, or repair (Permit No. 0990019-003-AV).

4.3 CONTROL TECHNOLOGY DESCRIPTION

PM emissions from Boiler No. 4 are controlled by two identical spray impingement type wet scrubbers operating in parallel. The exhaust gases from the boiler are split, with approximately one-half of the total flow going to one scrubber, and one-half going to the other scrubber. The exhaust gases from each scrubber combine and exhaust through a single stack.

The design pressure drop across each scrubber is 4 to 18 inches H₂O. The design scrubber water inlet pressure to each scrubber is 40 to 60 psig. The effectiveness of the wet scrubbers is evaluated with an annual stack test and visible emission measurements. A detailed description of the control equipment is included in the Title V renewal application (Attachment OF-EU3-I3).

4.4 MONITORING APPROACH

The monitoring approach is based on monitoring scrubber pressure drop and scrubber water flow rate. The monitoring approach is summarized in the table below:

| Boiler No. 4 | Indicator No. 1 | Indicator No. 2 |
|------------------------------------|---|---|
| Indicator | Pressure drop across each scrubber. | Total water flow rate to both scrubbers. |
| Measurement Approach | Pressure drop is monitored with a manometer. | The scrubber water flow rate is measured using an orifice meter. |
| Indicator Range | An excursion is defined as any pressure drop below 12 in. H ₂ O. Excursions trigger an inspection, corrective action, and a recordkeeping and reporting requirement. | An excursion is defined as any water flow rate below 500 gpm. Excursions trigger an inspection, corrective action, and a recordkeeping and reporting requirement. |
| Data Representativeness | The monitoring system consists of a manometer which measures the pressure drop across the scrubber. The minimum accuracy of the device is ± 0.1 inches of water gauge pressure. | The scrubber water orifice meter is located on the scrubber liquid supply line. The minimum accuracy of the device is ± 25 gpm of water flow. |
| Verification of Operational Status | NA | NA |
| QA/QC Practices and Criteria | The manometer is maintained in accordance with the manufacturer's recommendations. | The orifice meter is maintained in accordance with the manufacturer's recommendations. |
| Monitoring Frequency | Pressure drop is monitored continuously. | Scrubber water flow rate is monitored continuously. |
| Data Collection Procedures | Reading taken once every eight (8) hours. | Reading taken once every eight (8) hours. |
| Averaging Period | NA | NA |

4.5 JUSTIFICATION

Both pressure drop across the scrubber and water flow rate to the scrubber are recognized parameters for controlling PM emissions with wet scrubbers. The pressure drop is a measure of the energy imparted to the gas stream and therefore the efficiency of the scrubbing process. The water flow rate is a measure of sufficient fresh scrubbing liquid being supplied to the scrubber.

Water delivery pressure is currently monitored, which provides an indication of plugging of the spray nozzles in the scrubber. However, scrubber water flow rate provides a more direct indicator of adequate water supply to the scrubber. Therefore, water delivery pressure is not proposed as a parameter for CAM purposes.

Osceola Farms has sufficient historic test data necessary to establish indicator values for pressure drop and water flow rate to the Boiler No. 4 wet scrubbers. The test data correlating the parameters to the PM emission levels are presented in Figures 4-1 through 4-3. Supporting information is contained in Appendix B.

The proposed parameter minimum values are based on 90 percent of the minimum parameter values recorded during each one-hour test run, using the historic test data, when compliance was demonstrated with the PM limit. The calculation of the minimum parameter values are provided below:

Pressure Drop: Minimum test run value = 13 in. H₂O

Minimum parameter value = $13 \times 0.9 = 11.7$ in. H₂O

Water Flow Rate: Minimum test run value = 565 gpm

Minimum parameter value = $565 \times 0.9 = 508$ gpm

Wet scrubber operating parameter values below these minimum parameter values would be indicative of abnormal operation of the wet scrubbers. This methodology is consistent with the establishment of wet scrubber operating limits under 40 CFR 63, Subpart DDDDD, which are the Industrial Boiler/Process Heater MACT standards. Boiler No. 4 will be subject to these standards beginning in September 2007.

The CAM regulations generally require that pollutant specific emissions units with the potential to emit greater than 100 TPY collect monitoring data at least four (4) times per hour. However, 40 CFR 63.3(b)(ii) allows the permitting authority to approve a reduced data collection frequency, if appropriate, based on the data collection mechanisms available for a particular parameter.

Osceola has been recording scrubber parameters once per 8-hour shift, according to the current Title V permit conditions. Although Osceola has continuous pressure drop and water flow rate monitors in place, the mechanisms are not in place to continuously record the pressure drop data and create

hourly averages. In addition, the mechanisms are not in place to create hourly averages of the water flow rate. It is therefore requested that the current recording frequency of once per 8-hour shift be retained for both pressure drop and water flow rate.

Based on collecting data once per 8-hour shift, an excursion would occur whenever any individual reading is below the minimum parameter value. When an excursion occurs, corrective action will be initiated, beginning with an evaluation of the occurrence, to determine the action required (if any) to correct the situation. All excursions will be documented and reported.

Figure 4-1. OFC Boiler No. 4 (North Scrubber)
PM vs. Pressure Drop




Figure 4-2. OFC Boiler No. 4 (South Scrubber)
PM vs. Pressure Drop





Figure 4-3. OFC Boiler No. 4
PM vs. Total Water Flow Rate



5.0 PARTICULATE MATTER EMISSIONS FROM BOILER NO. 5

5.1 EMISSIONS UNIT IDENTIFICATION

Boiler No. 5—EU ID 005

5.2 APPLICABLE REGULATIONS, EMISSIONS LIMITS, AND MONITORING REQUIREMENTS

Boiler No. 5 has a PM emission limit of 0.2 lb/MMBtu for carbonaceous fuel, plus 0.1 lb/MMBtu for No. 6 fuel oil [Rule 62-296.410(1)(b)2, F.A.C.]. The equivalent potential emissions are 56.9 lb/hr and 109.0 TPY for carbonaceous fuel and 7.5 lb/hr and 9.1 TPY for No. 6 fuel oil. The current VE limit is 30-percent opacity, with an exception of up to 40-percent opacity for 2 minutes per hour (Permit No. 0990019-003-AV).

PM and VE compliance testing is required annually on Boiler No. 5. In addition, the total pressure drop across the scrubber, the scrubber water inlet pressure, and the scrubber water flow rate must be monitored and recorded at least once per 8-hour shift during each day of operation. The monitors must be properly maintained and functional at all times, except during instrument breakdown, calibration, or repair (Permit No. 0990019-003-AV).

5.3 CONTROL TECHNOLOGY DESCRIPTION

PM emissions from Boiler No. 5 are controlled by two identical spray impingement type wet scrubbers operating in parallel. The exhaust gases from the boiler are split, with approximately one-half of the total flow going to one scrubber, and one-half going to the other scrubber. Each scrubber exhausts through a separate stack.

The design pressure drop across each scrubber is 4 to 18 inches H₂O. The design scrubber water inlet pressure to each scrubber is 40 to 60 psig. The effectiveness of the wet scrubbers is evaluated with an annual stack test and visible emission measurements. A detailed description of the control equipment is included in the Title V renewal application (Attachment OF-EU4-I3).

5.4 MONITORING APPROACH

The monitoring approach is based on monitoring scrubber pressure drop and scrubber water flow rate. The monitoring approach is summarized in the table below:

| Boiler No. 5 | Indicator No. 1 | Indicator No. 2 |
|------------------------------------|---|---|
| Indicator | Pressure drop across each scrubber. | Total water flow rate to both scrubbers. |
| Measurement Approach | Pressure drop is monitored with a manometer. | The scrubber water flow rate is measured using an orifice meter. |
| Indicator Range | An excursion is defined as any pressure drop below 8 in. H ₂ O. Excursions trigger an inspection, corrective action, and a recordkeeping and reporting requirement. | An excursion is defined as any water flow rate below 475 gpm. Excursions trigger an inspection, corrective action, and a recordkeeping and reporting requirement. |
| Data Representativeness | The monitoring system consists of a manometer which measures the pressure drop across the scrubber. The minimum accuracy of the device is ± 0.1 inches of water gauge pressure. | The scrubber water orifice meter is located on the scrubber liquid supply line. The minimum accuracy of the device is ± 25 gpm of water flow. |
| Verification of Operational Status | NA | NA |
| QA/QC Practices and Criteria | The manometer is maintained in accordance with the manufacturer's recommendations. | The orifice meter is maintained in accordance with the manufacturer's recommendations. |
| Monitoring Frequency | Pressure drop is monitored continuously. | Scrubber water flow rate is monitored continuously. |
| Data Collection Procedures | Reading taken once every eight (8) hours. | Reading taken once every eight (8) hours. |
| Averaging Period | NA | NA |

5.5 JUSTIFICATION

Both pressure drop across the scrubber and water flow rate to the scrubber are recognized parameters for controlling PM emissions with wet scrubbers. The pressure drop is a measure of the energy imparted to the gas stream and therefore the efficiency of the scrubbing process. The water flow rate is a measure of sufficient fresh scrubbing liquid being supplied to the scrubber.

Water delivery pressure is currently monitored, which provides an indication of plugging of the spray nozzles in the scrubber. However, scrubber water flow rate provides a more direct indicator of adequate water supply to the scrubber. Therefore, water delivery pressure is not proposed as a parameter for CAM purposes.

Osceola Farms has sufficient historic test data necessary to establish indicator values for pressure drop and water flow rate to the Boiler No. 5 wet scrubbers. The test data correlating the parameters to the PM emission levels are presented in Figures 5-1 through 5-3. Supporting information is contained in Appendix B.

The proposed parameter minimum values are based 90 percent of the minimum parameter values recorded during the 1-hour test runs, using the historic test data, when compliance was demonstrated with the PM limit. The calculation of the minimum parameter values are provided below:

Pressure Drop: Minimum test run value = 9 in. H₂O

Minimum parameter value = $9 \times 0.9 = 8.1$ in. H₂O

Water Flow Rate: Minimum test run value = 527 gpm

Minimum parameter value = $527 \times 0.9 = 475$ gpm

Wet scrubber operating parameter values below these minimum parameter values would be indicative of abnormal operation of the wet scrubbers. This methodology is consistent with the establishment of wet scrubber operating limits under 40 CFR 63, Subpart DDDDD, which are the Industrial Boiler/Process Heater MACT standards. Boiler No. 5 will be subject to these standards beginning in September 2007.

The CAM regulations generally require that pollutant specific emissions units with the potential to emit greater than 100 TPY collect monitoring data at least four (4) times per hour. However, 40 CFR 63.3(b)(ii) allows the permitting authority to approve a reduced data collection frequency, if appropriate, based on the data collection mechanisms available for a particular parameter.

Osceola has been recording scrubber parameters once per 8-hour shift, according to the current Title V permit conditions. Although Osceola has continuous pressure drop and water flow rate monitors in place, the mechanisms are not in place to continuously record the pressure drop data and create hourly averages. In addition, the mechanisms are not in place to create hourly averages of the water

flow rate. It is therefore requested that the current recording frequency of once per 8-hour shift be retained for both pressure drop and water flow rate.

Based on collecting data once per 8-hour shift, an excursion would occur whenever any individual reading is below the minimum parameter value. When an excursion occurs, corrective action will be initiated, beginning with an evaluation of the occurrence, to determine the action required (if any) to correct the situation. All excursions will be documented and reported.

Figure 5-1. OFC Boiler No. 5 (West Scrubber)
PM vs. Pressure Drop




Figure 5-2. OFC Boiler No. 5 (East Scrubber)
PM vs. Pressure Drop





Figure 5-3. OFC Boiler No. 5
PM vs. Total Water Flow Rate



6.0 PARTICULATE MATTER EMISSIONS FROM BOILER NO. 6

6.1 EMISSIONS UNIT IDENTIFICATION

Boiler No. 6—EU ID 006

6.2 APPLICABLE REGULATIONS, EMISSIONS LIMITS, AND MONITORING REQUIREMENTS

Boiler No. 6 has a PM emission limit of 0.15 lb/MMBtu for carbonaceous fuel, plus 0.1 lb/MMBtu for No. 6 fuel oil [Rule 62-296.410(1)(b)2, F.A.C. and Permit No. PSD-FL-134]. The equivalent potential emissions are 56.9 lb/hr and 109.0 TPY for carbonaceous fuel and 7.5 lb/hr and 9.1 TPY for No. 6 fuel oil. The current VE limit is 20-percent opacity, with an exception of up to 40-percent opacity for 2 minutes per hour (Permit No. 0990019-003-AV).

PM and VE compliance testing is required annually on Boiler No. 6. In addition, the total pressure drop across the scrubber, the scrubber water inlet pressure, and the scrubber water flow rate must be monitored and recorded at least once per 8-hour shift during each day of operation. The monitors must be properly maintained and functional at all times, except during instrument breakdown, calibration, or repair (Permit No. 0990019-003-AV).

6.3 CONTROL TECHNOLOGY DESCRIPTION

PM emissions from Boiler No. 6 are controlled by a single spray impingement type wet scrubber. The design pressure drop across the scrubber is 4 to 18 inches H₂O. The design scrubber water inlet pressure to the scrubber is 30 to 60 psig. The effectiveness of the wet scrubbers is evaluated with an annual stack test and visible emission measurements. A detailed description of the control equipment is included in the Title V renewal application (Attachment OF-EU5-I3).

6.4 MONITORING APPROACH

The monitoring approach is based on monitoring scrubber pressure drop and scrubber water flow rate. The monitoring approach is summarized in the table below:

| Boiler No. 6 | Indicator No. 1 | Indicator No. 2 |
|------------------------------------|---|---|
| Indicator | Pressure drop across each scrubber. | Total water flow rate to both scrubbers. |
| Measurement Approach | Pressure drop is monitored with a manometer. | The scrubber water flow rate is measured using an orifice meter. |
| Indicator Range | An excursion is defined as any pressure drop below 12.6 in. H ₂ O. Excursions trigger an inspection, corrective action, and a recordkeeping and reporting requirement. | An excursion is defined as any water flow rate below 650 gpm. Excursions trigger an inspection, corrective action, and a recordkeeping and reporting requirement. |
| Data Representativeness | The monitoring system consists of a manometer which measures the pressure drop across the scrubber. The minimum accuracy of the device is ± 0.1 inches of water gauge pressure. | The scrubber water orifice meter is located on the scrubber liquid supply line. The minimum accuracy of the device is ± 25 gpm of water flow. |
| Verification of Operational Status | NA | NA |
| QA/QC Practices and Criteria | The manometer is maintained in accordance with the manufacturer's recommendations. | The orifice meter is maintained in accordance with the manufacturer's recommendations. |
| Monitoring Frequency | Pressure drop is monitored continuously. | Scrubber water flow rate is monitored continuously. |
| Data Collection Procedures | Reading taken once every eight (8) hours. | Reading taken once every eight (8) hours. |
| Averaging Period | NA | NA |

6.5 JUSTIFICATION

Both pressure drop across the scrubber and water flow rate to the scrubber are recognized parameters for controlling PM emissions with wet scrubbers. The pressure drop is a measure of the energy imparted to the gas stream and therefore the efficiency of the scrubbing process. The water flow rate is a measure of sufficient fresh scrubbing liquid being supplied to the scrubber.

Water delivery pressure is currently monitored, which provides an indication of plugging of the spray nozzles in the scrubber. However, scrubber water flow rate provides a more direct indicator of adequate water supply to the scrubber. Therefore, water delivery pressure is not proposed as a parameter for CAM purposes.

Osceola Farms has sufficient historic test data necessary to establish indicator values for pressure drop and water flow rate to the Boiler No. 6 wet scrubber. The test data correlating the parameters to the PM emission levels are presented in Figures 6-1 and 6-2. Supporting information is contained in Appendix B.

The proposed parameter minimum values are based 90 percent of the minimum parameter values recorded during the 1-hour test runs, using the historic test data, when compliance was demonstrated with the PM limit. The calculation of the minimum parameter values are provided below:

Pressure Drop: Minimum test run value = 14 in. H₂O

Minimum parameter value = $14 \times 0.9 = 12.6$ in. H₂O

Water Flow Rate: Minimum test run value = 725 gpm

Minimum parameter value = $725 \times 0.9 = 652$ gpm

Wet scrubber operating parameter values below these minimum parameter values would be indicative of abnormal operation of the wet scrubbers. This methodology is consistent with the establishment of wet scrubber operating limits under 40 CFR 63, Subpart DDDDD, which are the Industrial Boiler/Process Heater MACT standards. Boiler No. 6 will be subject to these standards beginning in September 2007.

The CAM regulations generally require that pollutant specific emissions units with the potential to emit greater than 100 TPY collect monitoring data at least four (4) times per hour. However, 40 CFR 63.3(b)(ii) allows the permitting authority to approve a reduced data collection frequency, if appropriate, based on the data collection mechanisms available for a particular parameter.

Osceola has been recording scrubber parameters once per 8-hour shift, according to the current Title V permit conditions. Although Osceola has continuous pressure drop and water flow rate monitors in place, the mechanisms are not in place to continuously record the pressure drop data and create hourly averages. In addition, the mechanisms are not in place to create hourly averages of the water

flow rate. It is therefore requested that the current recording frequency of once per 8-hour shift be retained for both pressure drop and water flow rate.

Based on collecting data once per 8-hour shift, an excursion would occur whenever any individual reading is below the minimum parameter value. When an excursion occurs, corrective action will be initiated, beginning with an evaluation of the occurrence, to determine the action required (if any) to correct the situation. All excursions will be documented and reported.

Figure 6-1. OFC Boiler No. 6
PM vs. Pressure Drop





Figure 6-2. OFC Boiler No. 6
PM vs. Water Flow Rate



APPENDIX A

SIGNATURE PAGES

APPLICATION INFORMATION

Professional Engineer Certification

| |
|---|
| 1. Professional Engineer Name: David A. Buff Registration Number: 19011 |
| 2. Professional Engineer Mailing Address... Organization/Firm: Golder Associates Inc.** Street Address: 6241 NW 23rd Street, Suite 500 City: Gainesville State: FL Zip Code: 32653 |
| 3. Professional Engineer Telephone Numbers... Telephone: (352) 336-5600 ext. 545 Fax: (352) 336-6603 |
| 4. Professional Engineer Email Address: dbuff@golder.com |
| 5. Professional Engineer Statement: <i>I, the undersigned, hereby certify, except as particularly noted herein*, that:</i> <i>(1) To the best of my knowledge, there is reasonable assurance that the air pollutant emissions unit(s) and the air pollution control equipment described in this application for air permit, when properly operated and maintained, will comply with all applicable standards for control of air pollutant emissions found in the Florida Statutes and rules of the Department of Environmental Protection; and</i> <i>(2) To the best of my knowledge, any emission estimates reported or relied on in this application are true, accurate, and complete and are either based upon reasonable techniques available for calculating emissions or, for emission estimates of hazardous air pollutants not regulated for an emissions unit addressed in this application, based solely upon the materials, information and calculations submitted with this application.</i> <i>(3) If the purpose of this application is to obtain a Title V air operation permit (check here <input type="checkbox"/>, if so), I further certify that each emissions unit described in this application for air permit, when properly operated and maintained, will comply with the applicable requirements identified in this application to which the unit is subject, except those emissions units for which a compliance plan and schedule is submitted with this application.</i> <i>(4) If the purpose of this application is to obtain an air construction permit (check here <input type="checkbox"/>, if so) or concurrently process and obtain an air construction permit and a Title V air operation permit revision or renewal for one or more proposed new or modified emissions units (check here <input checked="" type="checkbox"/>, if so), I further certify that the engineering features of each such emissions unit described in this application have been designed or examined by me or individuals under my direct supervision and found to be in conformity with sound engineering principles applicable to the control of emissions of the air pollutants characterized in this application.</i> <i>(5) If the purpose of this application is to obtain an initial air operation permit or operation permit revision or renewal for one or more newly constructed or modified emissions units (check here <input type="checkbox"/>, if so), I further certify that, with the exception of any changes detailed as part of this application, each such emissions unit has been constructed or modified in substantial accordance with the information given in the corresponding application for air construction permit and with all provisions contained in such permit.</i> <div style="display: flex; justify-content: space-between;"><div>Signature <u>David A. Buff</u></div><div>Date <u>6/21/05</u></div></div> <div>(seal)</div> |


* Attach any exception to certification statement.

** Board of Professional Engineers Certificate of Authorization #00001670

APPLICATION INFORMATION

Application Responsible Official Certification

Complete if applying for an initial/revised/renewal Title V permit or concurrent processing of an air construction permit and a revised/renewal Title V permit. If there are multiple responsible officials, the "application responsible official" need not be the "primary responsible official."

| |
|--|
| 1. Application Responsible Official Name: Carlos Rionda, Vice President and General Manager |
| 2. Application Responsible Official Qualification (Check one or more of the following options, as applicable): <input checked="" type="checkbox"/> For a corporation, the president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision-making functions for the corporation, or a duly authorized representative of such person if the representative is responsible for the overall operation of one or more manufacturing, production, or operating facilities applying for or subject to a permit under Chapter 62-213, F.A.C. <input type="checkbox"/> For a partnership or sole proprietorship, a general partner or the proprietor, respectively. <input type="checkbox"/> For a municipality, county, state, federal, or other public agency, either a principal executive officer or ranking elected official. <input type="checkbox"/> The designated representative at an Acid Rain source. |
| 3. Application Responsible Official Mailing Address... Organization/Firm: Osceola Farms Company Street Address: U.S. 98 & Hatton Highway City: Pahokee State: FL Zip Code: 33476 |
| 4. Application Responsible Official Telephone Numbers... Telephone: (561) 924-7156 ext. Fax: (561) 924-3246 |
| 5. Application Responsible Official Email Address: |
| 6. Application Responsible Official Certification: <p>I, the undersigned, am a responsible official of the Title V source addressed in this air permit application. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements made in this application are true, accurate and complete and that, to the best of my knowledge, any estimates of emissions reported in this application are based upon reasonable techniques for calculating emissions. The air pollutant emissions units and air pollution control equipment described in this application will be operated and maintained so as to comply with all applicable standards for control of air pollutant emissions found in the statutes of the State of Florida and rules of the Department of Environmental Protection and revisions thereof and all other applicable requirements identified in this application to which the Title V source is subject. I understand that a permit, if granted by the department, cannot be transferred without authorization from the department, and I will promptly notify the department upon sale or legal transfer of the facility or any permitted emissions unit. Finally, I certify that the facility and each emissions unit are in compliance with all applicable requirements to which they are subject, except as identified in compliance plan(s) submitted with this application.</p> <p> Signature</p> <p><u>6/22/03</u> Date</p> |

APPENDIX B

**HISTORIC PM COMPLIANCE TEST DATA
FOR BOILER NOS. 1 -6**

Table B-1. Boiler PM Emission Tests, Osceola Farms Company

| Unit | Run Number | Stack | Boiler Type | Test Date | Stack Gas Flow Rate (scfm) | Stack Gas Flow Rate (acfm) | Steam Rate (lb/hr) | Heat Input Rate (MMBtu/hr) | Bagasse Burning Rate (TPH) | Allowable PM Emissions (EPA Method 5) | | Actual PM Emissions (EPA Method 5) | | Average Liquid Pressure (psig) | Average Water Flow (gpm) | Average Pressure Drop (in. H ₂ O) | |
|----------|------------|-------|----------------|-----------|----------------------------|----------------------------|--------------------|----------------------------|----------------------------|---------------------------------------|----------|------------------------------------|----------|--------------------------------|--------------------------|--|----|
| | | | | | | | | | | lb/hr | lb/MMBtu | lb/hr | lb/MMBtu | | | S | N |
| Boiler 2 | 1 | S | Inclined Grate | 11/15/00 | 37,020 | --- | 131,200 | 255.4 | 35.47 | | | 19.42 | 0.076 | 55 | 800 | 11 | |
| Boiler 2 | 2 | S | Inclined Grate | 11/15/00 | 36,640 | --- | 128,000 | 249.2 | 34.61 | | | 20.71 | 0.083 | 55 | 800 | 11 | |
| Boiler 2 | 3 | S | Inclined Grate | 11/15/00 | 36,740 | --- | 124,800 | 243.2 | 33.78 | | | 17.62 | 0.064 | 55 | 800 | 11 | |
| Boiler 2 | 1 | S | Inclined Grate | 11/20/02 | 38,354 | 61,220 | 126,400 | 248.4 | 34.50 | | | 22.20 | 0.089 | 55 | 800 | 10 | |
| Boiler 2 | 2 | S | Inclined Grate | 11/20/02 | 38,935 | 63,529 | 120,000 | 235.9 | 32.76 | | | 24.05 | 0.102 | 55 | 800 | 10 | |
| Boiler 2 | 3 | S | Inclined Grate | 11/20/02 | 36,963 | 61,436 | 116,800 | 229.6 | 31.89 | | | 25.10 | 0.109 | 55 | 800 | 9 | |
| Boiler 2 | 1 | S | Inclined Grate | 12/11/03 | 32,986 | 47,388 | 113,723 | 223.0 | 30.97 | | | 27.47 | 0.123 | 65 | 800 | 10 | |
| Boiler 2 | 2 | S | Inclined Grate | 12/11/03 | 35,107 | 50,407 | 124,062 | 243.5 | 33.82 | | | 19.48 | 0.080 | 65 | 800 | 10 | |
| Boiler 2 | 3 | S | Inclined Grate | 12/11/03 | 36,867 | 51,943 | 121,108 | 237.4 | 32.97 | | | 22.73 | 0.096 | 65 | 800 | 10 | |
| Boiler 2 | 1 | S | Inclined Grate | 12/01/04 | 29,048 | 46,451 | 112,246 | 220.8 | 30.57 | | | 19.42 | 0.088 | 50 | 1,200 | 10 | |
| Boiler 2 | 2 | S | Inclined Grate | 12/01/04 | 29,890 | 48,086 | 116,677 | 228.5 | 31.74 | | | 17.14 | 0.075 | 50 | 1,200 | 11 | |
| Boiler 2 | 3 | S | Inclined Grate | 12/01/04 | 28,838 | 46,676 | 116,677 | 228.0 | 31.67 | | | 21.65 | 0.095 | 50 | 1,200 | 12 | |
| Boiler 2 | 1 | N | Inclined Grate | 11/15/00 | 40,995 | --- | 128,000 | 249.4 | 34.64 | | | 30.19 | 0.121 | 55 | 800 | | 12 |
| Boiler 2 | 2 | N | Inclined Grate | 11/15/00 | 40,343 | --- | 129,600 | 252.3 | 35.04 | | | 25.22 | 0.100 | 55 | 800 | | 12 |
| Boiler 2 | 3 | N | Inclined Grate | 11/15/00 | 40,417 | --- | 129,600 | 252.6 | 35.08 | | | 18.40 | 0.073 | 55 | 800 | | 12 |
| Boiler 2 | 1 | N | Inclined Grate | 11/20/02 | 39,281 | 62,467 | 123,200 | 241.5 | 33.54 | | | 22.93 | 0.095 | 57 | 800 | | 13 |
| Boiler 2 | 2 | N | Inclined Grate | 11/20/02 | 39,611 | 63,580 | 131,200 | 258.1 | 35.85 | | | 21.13 | 0.082 | 56 | 800 | | 13 |
| Boiler 2 | 3 | N | Inclined Grate | 11/20/02 | 38,051 | 62,195 | 142,400 | 280.1 | 38.90 | | | 21.23 | 0.076 | 55 | 800 | | 13 |
| Boiler 2 | 1 | N | Inclined Grate | 12/11/03 | 44,504 | 64,184 | 123,429 | 242.7 | 33.71 | | | 24.24 | 0.100 | 65 | 800 | | 12 |
| Boiler 2 | 2 | N | Inclined Grate | 12/11/03 | 36,816 | 52,816 | 122,057 | 239.8 | 33.31 | | | 21.33 | 0.089 | 65 | 800 | | 12 |
| Boiler 2 | 3 | N | Inclined Grate | 12/11/03 | 36,806 | 53,563 | 125,538 | 246.2 | 34.19 | | | 21.90 | 0.089 | 65 | 800 | | 12 |
| Boiler 2 | 1 | N | Inclined Grate | 11/30/04 | 29,589 | 47,474 | 116,571 | 228.2 | 31.69 | | | 19.78 | 0.087 | 50 | 1,200 | | 10 |
| Boiler 2 | 2 | N | Inclined Grate | 11/30/04 | 32,210 | 51,021 | 115,200 | 225.9 | 31.38 | | | 18.07 | 0.080 | 50 | 1,200 | | 10 |
| Boiler 2 | 3 | N | Inclined Grate | 11/30/04 | 30,859 | 48,087 | 112,457 | 220.4 | 30.61 | | | 18.70 | 0.085 | 50 | 1,200 | | 10 |
| Boiler 2 | 1 | Total | Inclined Grate | 11/15/00 | 39,007 | --- | 129,600 | 252.4 | 35.06 | | | | | | | | |
| Boiler 2 | 2 | Total | Inclined Grate | 11/15/00 | 38,491 | --- | 128,800 | 250.8 | 34.83 | | | 49.61 | 0.197 | 55 | 800 | | |
| Boiler 2 | 3 | Total | Inclined Grate | 11/15/00 | 38,579 | --- | 127,200 | 247.9 | 34.43 | | | 45.93 | 0.183 | 55 | 800 | | |
| Boiler 2 | 1 | Total | Inclined Grate | 11/20/02 | 38,817 | 61,844 | 124,800 | 245.0 | 34.02 | | | 36.02 | 0.137 | 55 | 800 | | |
| Boiler 2 | 2 | Total | Inclined Grate | 11/20/02 | 39,273 | 63,555 | 125,600 | 247.0 | 34.31 | | | 45.13 | 0.184 | 56 | 800 | | |
| Boiler 2 | 3 | Total | Inclined Grate | 11/20/02 | 37,507 | 61,816 | 129,600 | 254.9 | 35.40 | | | 45.18 | 0.184 | 55 | 800 | | |
| Boiler 2 | 1 | Total | Inclined Grate | 12/11/03 | 38,745 | 55,786 | 118,576 | 232.9 | 32.34 | | | 46.33 | 0.185 | 55 | 800 | | |
| Boiler 2 | 2 | Total | Inclined Grate | 12/11/03 | 35,962 | 51,612 | 123,060 | 241.7 | 33.56 | | | 51.71 | 0.223 | 65 | 800 | | |
| Boiler 2 | 3 | Total | Inclined Grate | 12/11/03 | 36,836 | 52,753 | 123,323 | 241.8 | 33.58 | | | 40.81 | 0.169 | 65 | 800 | | |
| Boiler 2 | 1 | Total | Inclined Grate | 11/30/04 | 29,318 | 46,963 | 114,409 | 224.5 | 31.18 | | | 44.63 | 0.185 | 65 | 800 | | |
| Boiler 2 | 2 | Total | Inclined Grate | 11/30/04 | 31,050 | 49,554 | 115,939 | 227.2 | 31.56 | | | 39.20 | 0.175 | 50 | 1,200 | | |
| Boiler 2 | 3 | Total | Inclined Grate | 11/30/04 | 29,849 | 47,382 | 114,567 | 224.2 | 31.14 | | | 35.21 | 0.155 | 50 | 1,200 | | |
| Boiler 2 | | | | | | | | | | | | 40.35 | 0.180 | 50 | 1,200 | | |

Table B-1. Boiler PM Emission Tests, Osceola Farms Company

| Unit | Run Number | Stack | Boiler Type | Test Date | Stack Gas Flow Rate (dscfm) | Stack Gas Flow Rate (acfm) | Steam Rate (lb/hr) | Heat Input Rate (MMBtu/hr) | Bagasse Burning Rate (TPH) | Allowable PM Emissions (EPA Method 5) | | Actual PM Emissions (EPA Method 5) | Average Liquid Pressure (psig) | Average Water Flow (gpm) | Average Pressure Drop (in H ₂ O) | |
|----------|------------|-------|----------------|-----------|-----------------------------|----------------------------|--------------------|----------------------------|----------------------------|---------------------------------------|----------|------------------------------------|--------------------------------|--------------------------|---|---|
| | | | | | | | | | | lb/hr | lb/MMBtu | lb/MMBtu | | | S | N |
| Boiler 3 | 1 | | Inclined Grate | 11/19/99 | 54,846 | 89,138 | 129,600 | 253.8 | 35.24 | 50.80 | 0.2 | 41.38 | | 800 | | |
| Boiler 3 | 2 | | Inclined Grate | 11/19/99 | 50,363 | 813,969 | 135,000 | 264.5 | 36.74 | 52.90 | 0.2 | 43.68 | | 800 | 11.0 | |
| Boiler 3 | 3 | | Inclined Grate | 11/19/99 | 53,144 | 85,762 | 136,421 | 267.5 | 37.15 | 53.50 | 0.2 | 62.92 | | 800 | 11.8 | |
| Boiler 3 | 1 | | Inclined Grate | 11/21/01 | 67,187 | 102,387 | 140,400 | 276.1 | 38.35 | 55.20 | 0.2 | 45.81 | 70 | 800 | 11.0 | |
| Boiler 3 | 2 | | Inclined Grate | 11/21/01 | 66,289 | 102,611 | 140,400 | 276.5 | 38.40 | 55.30 | 0.2 | 45.80 | 70 | 790 | 10.8 | |
| Boiler 3 | 3 | | Inclined Grate | 11/21/01 | 65,020 | 100,525 | 140,400 | 276.1 | 38.35 | 55.20 | 0.2 | 46.36 | 70 | 800 | 10.8 | |
| Boiler 3 | 1 | | Inclined Grate | 11/14/02 | 65,465 | 101,322 | 131,400 | 257.6 | 35.78 | 51.50 | 0.2 | 28.34 | | 700 | 16.0 | |
| Boiler 3 | 2 | | Inclined Grate | 11/14/02 | 64,933 | 102,091 | 127,938 | 250.9 | 34.85 | 50.20 | 0.2 | 45.16 | 60 | 696 | 15.2 | |
| Boiler 3 | 3 | | Inclined Grate | 11/14/02 | 64,207 | 100,457 | 129,600 | 254.0 | 35.28 | 50.80 | 0.2 | 34.04 | 60 | 700 | 15.0 | |
| Boiler 3 | 4 | | Inclined Grate | 11/14/02 | 63,395 | 99,717 | 131,400 | 258.1 | 35.85 | 51.60 | 0.2 | 38.72 | 60 | 700 | 15.0 | |
| Boiler 3 | 1 | | Inclined Grate | 11/20/03 | 59,482 | 92,418 | 117,969 | 231.9 | 32.21 | 46.40 | 0.2 | 31.00 | 75 | 727 | 17.0 | |
| Boiler 3 | 2 | | Inclined Grate | 11/20/03 | 57,241 | 92,042 | 127,938 | 250.7 | 34.82 | 50.10 | 0.2 | 43.88 | 60 | 738 | 15.6 | |
| Boiler 3 | 3 | | Inclined Grate | 11/20/03 | 55,609 | 88,168 | 132,686 | 261.1 | 36.26 | 52.20 | 0.2 | 44.54 | 60 | 733 | 17.0 | |
| Boiler 3 | 1 | | Inclined Grate | 11/22/04 | 51,186 | 76,171 | 112,985 | 222.6 | 30.92 | 44.50 | 0.2 | 35.81 | 60 | 1,200 | 18.0 | |
| Boiler 3 | 2 | | Inclined Grate | 11/22/04 | 50,572 | 74,446 | 128,250 | 251.9 | 34.99 | 50.40 | 0.2 | 31.67 | 60 | 1,200 | 18.0 | |
| Boiler 3 | 3 | | Inclined Grate | 11/22/04 | 51,535 | 76,584 | 112,629 | 221.1 | 30.71 | 44.20 | 0.2 | 34.59 | 60 | 1,200 | 18.0 | |

Table B-1. Boiler PM Emission Tests, Osceola Farms Company

| Unit | Run Number | Stack | Boiler Type | Test Date | Stack Gas Flow Rate (dscfm) | Stack Gas Flow Rate (acfm) | Steam Rate (lb/hr) | Heat Input Rate (MMBtu/hr) | Bagasse Burning Rate ¹ (TPH) | Allowable PM Emissions (EPA Method 5) lb/hr | Actual PM Emissions (EPA Method 5) | | Average Liquid Pressure (psig) | Average Water Flow (gpm) | Average Pressure Drop (in. H ₂ O) | |
|----------|------------|-------|-------------|-----------|-----------------------------|----------------------------|--------------------|----------------------------|---|---|------------------------------------|----------|--------------------------------|--------------------------|--|------|
| | | | | | | | | | | | lb/hr | lb/MMBtu | | | S | N |
| Boiler 4 | 1 | | Horseshoe | 11/10/99 | 47,279 | 75,473 | 135,000 | 259.0 | 35.97 | 77.70 | 34.18 | 0.132 | | 645 | 15.0 | 16.0 |
| Boiler 4 | 2 | | Horseshoe | 11/10/99 | 55,983 | 88,573 | 138,000 | 264.6 | 36.75 | 79.40 | 38.34 | 0.145 | | 677 | 15.0 | 16.0 |
| Boiler 4 | 3 | | Horseshoe | 11/10/99 | 59,723 | 94,766 | 133,269 | 255.4 | 35.47 | 76.60 | 43.71 | 0.171 | | 675 | 15.0 | 16.0 |
| Boiler 4 | 1 | | Horseshoe | 11/06/00 | 59,127 | --- | 135,000 | 263.4 | 36.58 | 79.00 | 71.03 | 0.270 | | 620 | 14.0 | 14.0 |
| Boiler 4 | 2 | | Horseshoe | 11/06/00 | 58,832 | --- | 136,500 | 266.4 | 37.00 | 79.90 | 54.79 | 0.206 | | 608 | 13.4 | 13.6 |
| Boiler 4 | 3 | | Horseshoe | 11/06/00 | 59,410 | --- | 133,500 | 260.9 | 36.24 | 78.30 | 70.14 | 0.269 | | 600 | 13.4 | 13.4 |
| Boiler 4 | 1 | | Horseshoe | 11/08/02 | 61,959 | 96,079 | 118,500 | 232.9 | 32.35 | 69.90 | 44.99 | 0.193 | | 750 | 13.0 | 14.0 |
| Boiler 4 | 2 | | Horseshoe | 11/08/02 | 62,447 | 99,794 | 115,500 | 226.3 | 31.43 | 67.90 | 42.07 | 0.186 | | 750 | 13.0 | 12.8 |
| Boiler 4 | 3 | | Horseshoe | 11/08/02 | 64,692 | 103,761 | 115,500 | 226.7 | 31.49 | 68.00 | 45.45 | 0.201 | | 750 | 14.0 | 13.8 |
| Boiler 4 | 1 | | Horseshoe | 11/12/03 | 57,721 | 92,037 | 129,600 | 253.0 | 35.14 | 75.90 | 40.82 | 0.161 | 45 | 800 | 13.0 | 14.0 |
| Boiler 4 | 2 | | Horseshoe | 11/12/03 | 60,409 | 95,742 | 122,143 | 238.4 | 33.11 | 71.50 | 41.96 | 0.176 | 45 | 800 | 13.0 | 14.0 |
| Boiler 4 | 3 | | Horseshoe | 11/12/03 | 58,659 | 94,711 | 133,174 | 260.9 | 36.24 | 78.30 | 39.99 | 0.153 | 45 | 800 | 13.0 | 14.0 |
| Boiler 4 | 1 | | Horseshoe | 11/12/04 | 62,245 | 98,250 | 114,923 | 224.9 | 31.24 | 67.30 | 55.27 | 0.246 | 50 | 565 | 14.0 | 14.0 |
| Boiler 4 | 2 | | Horseshoe | 11/12/04 | 67,559 | 103,443 | 111,000 | 217.3 | 30.18 | 65.20 | 54.99 | 0.253 | 50 | 573 | 14.0 | 14.0 |
| Boiler 4 | 3 | | Horseshoe | 11/12/04 | 64,466 | 101,129 | 113,538 | 222.4 | 30.89 | 66.70 | 49.94 | 0.225 | 50 | 568 | 14.0 | 14.0 |

Table B-1. Boiler PM Emission Tests, Osceola Farms Company

| Unit | Run Number | Stack | Boiler Type | Test Date | Stack Gas Flow Rate (dscfm) | Stack Gas Flow Rate (acfm) | Steam Rate (lb/hr) | Heat Input Rate (MMBtu/hr) | Bagasse Burning Rate (TPH) | Allowable PM Emissions (EPA Method 5) | | Actual PM Emissions (EPA Method 5) | | Average Liquid Pressure (psig) | Average Water Flow (gpm) | Average Pressure Drop (in. H ₂ O) | |
|----------|------------|-------|-------------|-----------|-----------------------------|----------------------------|--------------------|----------------------------|----------------------------|---------------------------------------|----------|------------------------------------|----------|--------------------------------|--------------------------|--|---|
| | | | | | | | | | | lb/hr | lb/MMBtu | lb/hr | lb/MMBtu | | | S | N |
| Boiler 5 | 1 | W | Horseshoe | 11/02/00 | 34,710 | | 140,400 | 275.4 | 38.25 | | | 17.32 | 0.063 | 55 | 650 | 9.0 | |
| Boiler 5 | 2 | W | Horseshoe | 11/02/00 | 35,125 | | 145,800 | 285.8 | 39.69 | | | 19.63 | 0.069 | 55 | 650 | 9.0 | |
| Boiler 5 | 3 | W | Horseshoe | 11/02/00 | 35,757 | | 144,000 | 282.2 | 39.19 | | | 23.04 | 0.082 | 55 | 650 | 9.0 | |
| Boiler 5 | 1 | W | Horseshoe | 11/06/02 | 36,003 | 54,985 | 147,600 | 289.6 | 40.22 | | | 22.80 | 0.079 | | 750 | 10.0 | |
| Boiler 5 | 2 | W | Horseshoe | 11/06/02 | 36,779 | 56,806 | 154,800 | 303.9 | 42.21 | | | 21.93 | 0.072 | | 750 | 10.0 | |
| Boiler 5 | 3 | W | Horseshoe | 11/06/02 | 35,544 | 57,397 | 144,000 | 282.6 | 39.25 | | | 20.78 | 0.074 | | 750 | 10.0 | |
| Boiler 5 | 1 | W | Horseshoe | 11/18/03 | 35,892 | 55,554 | 138,857 | 275.1 | 38.21 | | | 18.61 | 0.068 | 75 | 800 | 12.0 | |
| Boiler 5 | 2 | W | Horseshoe | 11/18/03 | 35,849 | 56,548 | 137,908 | 273.4 | 37.97 | | | 18.30 | 0.067 | 75 | 800 | 12.0 | |
| Boiler 5 | 3 | W | Horseshoe | 11/18/03 | 37,386 | 57,797 | 132,686 | 262.8 | 36.50 | | | 20.80 | 0.079 | 75 | 800 | 12.0 | |
| Boiler 5 | 1 | W | Horseshoe | 11/10/04 | 37,281 | 55,432 | 136,246 | 273.4 | 37.97 | | | 25.18 | 0.092 | 70 | 528 | 11.0 | |
| Boiler 5 | 2 | W | Horseshoe | 11/10/04 | 38,377 | 55,600 | 139,569 | 276.3 | 38.38 | | | 20.15 | 0.073 | 70 | 530 | 11.0 | |
| Boiler 5 | 3 | W | Horseshoe | 11/10/04 | 37,670 | 55,632 | 137,314 | 271.9 | 37.76 | | | 20.53 | 0.076 | 70 | 541 | 11.0 | |
| Boiler 5 | 1 | E | Horseshoe | 11/02/00 | 35,470 | | 142,200 | 280.1 | 38.90 | | | 23.61 | 0.084 | 55 | 650 | 11.0 | |
| Boiler 5 | 2 | E | Horseshoe | 11/02/00 | 37,024 | | 145,800 | 286.3 | 39.76 | | | 26.34 | 0.092 | 55 | 650 | 11.0 | |
| Boiler 5 | 3 | E | Horseshoe | 11/02/00 | 36,690 | | 144,000 | 282.6 | 39.25 | | | 22.03 | 0.078 | 55 | 650 | 11.0 | |
| Boiler 5 | 1 | E | Horseshoe | 11/06/02 | 40,636 | 63,148 | 151,200 | 296.5 | 41.18 | | | 18.73 | 0.063 | | 750 | 11.5 | |
| Boiler 5 | 2 | E | Horseshoe | 11/06/02 | 41,382 | 64,971 | 145,800 | 286.0 | 39.72 | | | 20.50 | 0.072 | | 750 | 11.0 | |
| Boiler 5 | 3 | E | Horseshoe | 11/06/02 | 41,971 | 64,236 | 144,000 | 282.6 | 39.25 | | | 20.84 | 0.074 | | 750 | 11.0 | |
| Boiler 5 | 1 | E | Horseshoe | 11/18/03 | 34,837 | 56,347 | 136,800 | 271.1 | 37.65 | | | 22.69 | 0.084 | 75 | 800 | 9.0 | |
| Boiler 5 | 2 | E | Horseshoe | 11/18/03 | 35,905 | 57,018 | 138,600 | 274.6 | 38.14 | | | 22.86 | 0.083 | 75 | 800 | 10.0 | |
| Boiler 5 | 3 | E | Horseshoe | 11/18/03 | 36,477 | 56,899 | 142,200 | 281.8 | 39.14 | | | 20.34 | 0.072 | 75 | 800 | 10.0 | |
| Boiler 5 | 1 | E | Horseshoe | 11/11/04 | 42,035 | 67,016 | 137,908 | 273.3 | 37.96 | | | 26.45 | 0.097 | 70 | 527 | 11.0 | |
| Boiler 5 | 2 | E | Horseshoe | 11/11/04 | 40,470 | 62,452 | 131,262 | 259.8 | 36.08 | | | 22.76 | 0.088 | 70 | 537 | 11.0 | |
| Boiler 5 | 3 | E | Horseshoe | 11/11/04 | 38,977 | 58,705 | 127,938 | 253.3 | 35.18 | | | 23.50 | 0.093 | 70 | 527 | 12.0 | |
| Boiler 5 | 1 | Total | Horseshoe | 11/02/00 | 35,090 | --- | 141,300 | 277.8 | 38.38 | | | 40.93 | 0.147 | 55 | 650 | | |
| Boiler 5 | 2 | Total | Horseshoe | 11/02/00 | 36,075 | --- | 145,800 | 286.1 | 39.73 | | | 55.55 | 0.2 | 55 | 650 | | |
| Boiler 5 | 3 | Total | Horseshoe | 11/02/00 | 36,223 | --- | 144,000 | 282.4 | 39.22 | | | 57.25 | 0.2 | 55 | 650 | | |
| Boiler 5 | 1 | Total | Horseshoe | 11/06/02 | 38,320 | 59,067 | 149,400 | 293.1 | 40.70 | | | 56.45 | 0.2 | 55 | 750 | | |
| Boiler 5 | 2 | Total | Horseshoe | 11/06/02 | 39,080 | 60,889 | 150,300 | 295.0 | 40.97 | | | 58.60 | 0.2 | | 750 | | |
| Boiler 5 | 3 | Total | Horseshoe | 11/06/02 | 38,757 | 60,817 | 144,000 | 282.6 | 39.25 | | | 59.00 | 0.2 | | 750 | | |
| Boiler 5 | 1 | Total | Horseshoe | 11/18/03 | 35,365 | 55,951 | 137,829 | 273.1 | 37.93 | | | 56.50 | 0.2 | 41.62 | 0.148 | | |
| Boiler 5 | 2 | Total | Horseshoe | 11/18/03 | 35,877 | 56,783 | 138,254 | 274.0 | 38.06 | | | 41.30 | 0.152 | 75 | 800 | | |
| Boiler 5 | 3 | Total | Horseshoe | 11/18/03 | 36,932 | 57,348 | 137,443 | 272.3 | 37.82 | | | 41.16 | 0.150 | 75 | 800 | | |
| Boiler 5 | 1 | Total | Horseshoe | 11/11/04 | 39,658 | 61,224 | 137,077 | 273.4 | 37.97 | | | 54.50 | 0.2 | 41.14 | 0.151 | | |
| Boiler 5 | 2 | Total | Horseshoe | 11/11/04 | 39,424 | 59,026 | 135,416 | 268.1 | 37.23 | | | 54.70 | 0.2 | 51.63 | 0.189 | | |
| Boiler 5 | 3 | Total | Horseshoe | 11/11/04 | 38,323 | 57,169 | 132,626 | 262.6 | 36.47 | | | 53.65 | 0.2 | 42.91 | 0.161 | | |
| Boiler 5 | | | | | | | | | | | | 52.55 | 0.2 | 44.03 | 0.169 | | |

Table B-1. Boiler PM Emission Tests, Osceola Farms Company

| Unit | Run Number | Stack | Boiler Type | Test Date | Stack Gas Flow Rate (dscfm) | Stack Gas Flow Rate (acfm) | Steam Rate (lb/hr) | Heat Input Rate (MMBtu/hr) | Bagasse Burning Rate (TPH) | Allowable PM Emissions (EPA Method 5) lb/hr | Actual PM Emissions (EPA Method 5) lb/hr | Average Liquid Pressure (psig) | Average Water Flow (gpm) | Average Pressure Drop (in. H ₂ O) |
|----------|------------|-------|-----------------|-----------|-----------------------------|----------------------------|--------------------|----------------------------|----------------------------|---|--|--------------------------------|--------------------------|--|
| Boiler 6 | 1 | | Traveling Grate | 11/08/00 | 67,899 | --- | 163,000 | 317.1 | 44.04 | 47.60 | 34.78 | --- | 726 | 14.0 |
| Boiler 6 | 2 | | Traveling Grate | 11/08/00 | 68,459 | --- | 160,000 | 326.6 | 45.36 | 49.00 | 30.64 | 55 | 725 | 14.0 |
| Boiler 6 | 3 | | Traveling Grate | 11/08/00 | 68,942 | --- | 170,000 | 307.2 | 42.67 | 46.10 | 23.53 | 55 | 725 | 14.0 |
| Boiler 6 | 1 | | Traveling Grate | 11/12/02 | 69,384 | 105,372 | 147,500 | 289.2 | 40.17 | 43.40 | 37.70 | --- | 800 | 14.0 |
| Boiler 6 | 2 | | Traveling Grate | 11/12/02 | 68,348 | 104,652 | 137,500 | 269.4 | 37.42 | 40.40 | 34.02 | --- | 800 | 14.0 |
| Boiler 6 | 3 | | Traveling Grate | 11/12/02 | 68,174 | 104,894 | 142,500 | 279.2 | 38.78 | 41.90 | 35.23 | --- | 800 | 14.0 |
| Boiler 6 | 1 | | Traveling Grate | 11/14/03 | 59,626 | 90,777 | 147,857 | 290.6 | 40.36 | 43.60 | 33.50 | 70 | 800 | 15.5 |
| Boiler 6 | 2 | | Traveling Grate | 11/14/03 | 59,319 | 91,150 | 143,077 | 281.2 | 39.06 | 42.20 | 33.54 | 70 | 800 | 15.0 |
| Boiler 6 | 3 | | Traveling Grate | 11/14/03 | 60,548 | 92,437 | 141,429 | 277.9 | 38.60 | 41.70 | 37.39 | 70 | 800 | 15.0 |
| Boiler 6 | 1 | | Traveling Grate | 11/17/04 | 64,264 | 100,036 | 152,143 | 301.7 | 41.90 | 45.30 | 43.23 | 60 | 1,200 | 18.0 |
| Boiler 6 | 2 | | Traveling Grate | 11/17/04 | 65,197 | 100,252 | 152,143 | 300.8 | 41.78 | 45.10 | 42.57 | 60 | 1,200 | 18.0 |
| Boiler 6 | 3 | | Traveling Grate | 11/17/04 | 65,965 | 103,257 | 156,923 | 310.3 | 43.10 | 46.60 | 44.99 | 60 | 1,200 | 18.0 |

Note: lb/hr = pounds per hour.

lb/MMBtu = pounds per million British thermal units.

lb/ton = pounds per ton.

MMBtu/hr = million British thermal units per hour.

TPH = tons per hour.

Footnote:

¹ Assumed 3,600 Btu/lb average heat content for wet bagasse, except where noted.