

Table 2-1, Summary of Compliance Requirements

Gilman Building Products Company
GBP Perry Mill

Proposed Permit No.: 1230033-007-AV
Facility ID No.: 1230033

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.
This emission unit shall also comply with the requirements of 40 CFR 63, Subpart DDDDD no later than September 13, 2007

E.U. ID No.	Brief Description
001	Wood-fired Boiler

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS**	See permit condition(s)
Particulate Matter	Dried Wood Waste	EPA Method 5	Before Renewal			Y	III.A.6. & 8.
Visible Emissions	Dried Wood Waste	DEP Method 9	Annually				III.A.7

Notes:

* The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.

**CMS [=] continuous monitoring system

[electronic file name: 12300332.xls]