

NEIGHBORHOODS DEPARTMENT



**NOTICE OF ADMINISTRATIVELY CORRECTED PERMIT**

In the Matter of a Request for Administrative Correction:

Mike Lalli  
Terminal Manager  
BP Products North America, Inc.  
P.O. Box 26038  
Jacksonville, Florida 32226

Project No. 0310179-016-AV  
Administrative Correction to Permit No. 0310179-014-AV  
BP Products North America, Inc.  
Duval County

Enclosed is an Administratively Corrected Facility Description, Emission Unit (EU) Description for EU 032 and Specific Condition No. 2 for Emission Unit No. 032 to Title V Air Operation Permit No. 0310179-014-AV, for the operation of the BP Products North America, Inc. located in Duval County at 2101 Zoo Parkway, Jacksonville, Florida 32226. This correction is issued pursuant to Rule 62-210.360, Florida Administrative Code (F.A.C.), and Chapter 403, Florida Statutes (F.S.). This change is made at the request of Mr. Robert A. Baker, P.E., dated February 22, 2012, to change the size of the 250 KW Cummins Emergency Generator to 500 KW. This corrective action does not alter the effective dates of the existing permit.

The Environmental Quality Division (Permitting Authority) will consider the above-noted action final unless a timely petition for an administrative hearing is filed pursuant to Sections 120.569 and 120.57, F.S. Mediation under Section 120.573, F.S., will not be available for this proposed action.

A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative hearing in accordance with Sections 120.569 and 120.57, F.S. The petition must contain the information set forth below and must be filed (received) with the Office of General Counsel, City of Jacksonville, 117 W. Duval St., Suite 480, Jacksonville, FL 32202 [Telephone: (904) 630-1700; Fax: (904) 630-1731]. Petitions filed by the permit applicant or any of the parties listed below must be filed within 14 (fourteen) days of receipt of this notice. Petitions filed by any other person must be filed within 14 (fourteen) days of receipt of this proposed action. A petitioner must mail a copy of the petition to the applicant at the address indicated above, at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under Sections 120.569 and 120.57, F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention (in a proceeding initiated by another party) will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205, F.A.C.

A petition that disputes the material facts on which the Permitting Authority's action is based must contain the following information: (a) The name and address of each agency affected and each agency's file or identification number, if known; (b) The name, address, and telephone number of the petitioner; the name, address and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests will be affected by the agency determination; (c) A statement of when and how each petitioner received notice of the agency action or proposed decision; (d) A statement of all disputed issues of material fact.

**NOTICE OF ADMINISTRATIVELY CORRECTED PERMIT**

---

If there are none, the petition must so indicate; (e) A concise statement of the ultimate facts alleged, including the specific facts the petitioner contends warrant reversal or modification of the agency's proposed action; (f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the agency's proposed action including an explanation of how the alleged facts relate to the specific rules or statutes; and, (g) A statement of the relief sought by the petitioner, stating precisely the action the petitioner wishes the agency to take with respect to the agency's proposed action.

A petition that does not dispute the material facts upon which the Permitting Authority's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301, F.A.C.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Permitting Authority's final action may be different from the position taken by it in this notice. Persons whose substantial interests will be affected by any such final decision of the Permitting Authority on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

Any party to this order (permit) has the right to seek judicial review of it under Section 120.68, F.S., by the filing of a Notice of Appeal, under Rule 9.110 of the Florida Rules of Appellate Procedure, with the Office of General Counsel, City of Jacksonville, 117 W. Duval St., Suite 480, Jacksonville, FL 32202 [Telephone: (904) 630-1700; Fax: (904) 630-1731]; and, by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal.

The Notice of Appeal must be filed within thirty days from the date this notice is filed with the Clerk of the Permitting Authority.

Executed in Jacksonville, Florida.

**Neighborhoods Department  
Environmental Quality Division**

\_\_\_\_\_  
**Vincent A. Seibold, P.E.**  
**Chief**

\_\_\_\_\_  
**Date**

VAS/HDS

**CERTIFICATE OF SERVICE**

The undersigned duly designated Permitting Authority clerk hereby certifies that this Notice of Administratively Corrected Permit (including the corrected pages) or a link to these documents available electronically on a publicly accessible server, was sent by electronic mail with received receipt requested to the persons listed below:

- Mr. Mike Lalli, BP Products North America, Inc.
- Mr. Robert A. Baker, P.E. (baker@atlantic.net)
- Mr. Radford Murphy, BP Products North America, Inc. (RadfordMurphy@bp.com)
- Ms. Katy Forney, U.S. EPA-Region 4: [forney.kathleen@epamail.epa.gov](mailto:forney.kathleen@epamail.epa.gov)
- Ms. Ana Oquendo, EPA-Region 4: [oquendo.ana@epamail.epa.gov](mailto:oquendo.ana@epamail.epa.gov)
- Ms. Barbara Friday, DEP-BAR: [barbara.friday@dep.state.fl.us](mailto:barbara.friday@dep.state.fl.us) (for posting with U.S. EPA, Region 4)

**NOTICE OF ADMINISTRATIVELY CORRECTED PERMIT**

---

Ms. Rita Felton-Smith, District Air Program Permitting, DEP/NED ([Rita.Felton-Smith@dep.state.fl.us](mailto:Rita.Felton-Smith@dep.state.fl.us))  
Ms. Kathy Parish, EQD  
Mr. Wayne Walker, EQD

**FILING AND ACKNOWLEDGMENT**

**FILED**, on this date, pursuant to Section 120.52(7), Florida Statutes, with the designated Permitting Authority clerk, receipt of which is hereby acknowledged.

\_\_\_\_\_  
(Clerk)

\_\_\_\_\_  
(Date)

Pursuant to the applicant’s request, conditions /requirements contained in permit No. 0310179-014-AV have been corrected as indicated below.

**1. The Table for Emission Unit No. 032 in the Facility Description is hereby changed:**

**FROM:**

Description of Engine
<b>250 KW Cummins Emergency Generator</b>
500 KW Cummins Emergency Generator
800 KW Cummins Emergency Generator
175 HP Clarke Fire Pump

**TO:**

Description of Engine
<b>500 KW Cummins Emergency Generator</b>
500 KW Cummins Emergency Generator
800 KW Cummins Emergency Generator
175 HP Clarke Fire Pump

**NOTICE OF ADMINISTRATIVELY CORRECTED PERMIT**

---

**2. The Emission Unit Description for Emission Unit No. 032 is hereby changed:**

**FROM:**

Description of Engine	Year Built	Displacement/ Horsepower	Rule Applicability
<b>250 KW Cummins Emergency Generator</b>	<b>2010</b>	<b>1.5 Liters/Cylinder &amp; 399 HP</b>	40 CFR Part 60, Subpart IIII
*500 KW Cummins Emergency Generator	2009	2.5 Liters/Cylinder & 755 HP	40 CFR Part 60, Subpart IIII
800 KW Cummins Emergency Generator	2010	2.5 Liters/Cylinder & 1490 HP	40 CFR Part 60, Subpart IIII
175 HP Clarke Fire Pump	2007	1.1 Liters/Cylinder & 175 HP	40 CFR Part 60, Subpart IIII

**\* The 500 KW Cummins Emergency Engine is rated at 755 HP. This converts to 563 KW for use in determining allowable emissions for that engine.**

**To:**

Description of Engine	Year Built	Displacement/ Horsepower	Rule Applicability
<b>*500 KW Cummins Emergency Generator</b>	<b>2007</b>	<b>2.5 Liters/Cylinder &amp; 755 HP</b>	40 CFR Part 60, Subpart IIII
*500 KW Cummins Emergency Generator	2009	2.5 Liters/Cylinder & 755 HP	40 CFR Part 60, Subpart IIII
800 KW Cummins Emergency Generator	2010	2.5 Liters/Cylinder & 1490 HP	40 CFR Part 60, Subpart IIII
175 HP Clarke Fire Pump	2007	1.1 Liters/Cylinder & 175 HP	40 CFR Part 60, Subpart IIII

**\* The 500 KW Cummins Emergency Engines are rated at 755 HP. This converts to 563 KW for use in determining allowable emissions for these engines and places them under the Tier 2 emission standards per 40 CFR 89.112, Table 1.**

**3. Specific Condition No. 2 for Emission Unit No. 032 is hereby changed:**

**From:**

Engine	Non-Methane Hydrocarbon + NO <sub>x</sub>	CO	PM
<b>250 KW Cummins Emergency Generator</b>	<b>4.0 Grams/kW-Hr</b>	3.5 Grams/kW-Hr	0.20 Grams/kW-Hr
500 KW Cummins Emergency Generator	6.4 Grams/kW-Hr	3.5 Grams/kW-Hr	0.20 Grams/kW-Hr
800 KW Cummins Emergency Generator	6.4 Grams/kW-Hr	3.5 Grams/kW-Hr	0.20 Grams/kW-Hr
175 HP (130.5 KW) Clarke Fire Pump	10.5 Grams/kW-Hr	3.5 Grams/kW-Hr	0.54 Grams/kW-Hr

---

**NOTICE OF ADMINISTRATIVELY CORRECTED PERMIT**

---

**To:**

<b>Engine</b>	<b>Non-Methane Hydrocarbon + NO<sub>x</sub></b>	<b>CO</b>	<b>PM</b>
<b>500 KW Cummins Emergency Generator</b>	<b>6.4 Grams/kW-Hr</b>	3.5 Grams/kW-Hr	0.20 Grams/kW-Hr
500 KW Cummins Emergency Generator	6.4 Grams/kW-Hr	3.5 Grams/kW-Hr	0.20 Grams/kW-Hr
800 KW Cummins Emergency Generator	6.4 Grams/kW-Hr	3.5 Grams/kW-Hr	0.20 Grams/kW-Hr
175 HP (130.5 KW) Clarke Fire Pump	10.5 Grams/kW-Hr	3.5 Grams/kW-Hr	0.54 Grams/kW-Hr