



January 31, 2014

Mr. David McNeal  
USEPA, Region 4  
Sam Nunn Federal Center  
61 Forsyth Street, SW  
Atlanta, Georgia USA 30303-3104

**Subject: NOx Analyzer Re-certification – Turkey Point Plant Unit 1 (ORIS code 000621)**

Dear Mr. McNeal:

In compliance with the Acid Rain Continuous Emission Monitoring Program (40 CFR Part 75.63), Florida Power & Light Company (FPL) is submitting the Continuous Emissions Monitoring System Re-certification Application for the NOx analyzer replacement on Turkey Point Unit 1. In order to continue to ensure CEMS data integrity and analyzer availability, FPL is currently replacing CEMS NOx and O2 analyzers on thirty-eight units throughout the State.

Turkey Point Unit 1 NOx analyzer, serial number 42C 74775-385 was removed from service on November 12, 2013 and replaced by serial number 1315157764. Re-certification test period requirements and data validation, which includes a probationary calibration error test, in accordance with 40 CFR Part 75.20(b)(3)(ii) were performed to initiate a conditional valid data period.

The re-certification of the NOx System was performed in accordance with 40 CFR Part 75, Appendix A during the period of November 13 – December 18, 2013. Enclosed are the quality assurance audits which include a RATA Report, 7 Day Calibration Error Test, Linearity, and updated Monitoring Plan.

If you have any questions with the attached, please feel free to contact me at (561) 691-2781 or Elisa Ostertag at (561) 691-2341.

I am authorized to make this submission of behalf of the owners and operators of the affected source or affected units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Sincerely,

A handwritten signature in black ink, appearing to read "C. Kiernan", with a long horizontal stroke extending to the right.

Christian Kiernan

Florida Power & Light Company

700 Universe Blvd., Juno Beach, FL 33408

Designated Representative

Attachment

cc: Jeff Koerner –Division of Air Resource Management, FDEP Tallahassee  
Patricia Tampas - FDEP Southeast District  
Ray Gordon – Dade County Department of Environmental Resources  
Rudy Sanchez - Plant General Manager  
Gary Andersen - Environmental Specialist



# ECMPS Client Tool

Version 1.0.2013 Q3

# Monitoring Plan Printout Report

January 31, 2014 10:26 AM

## Facility Name: Turkey Point

### Facility Details

Facility ID (ORISPL): 621  
 Monitoring Plan Location IDs: PTP1  
 State: FL  
 County: Miami-Dade  
 Latitude: 25.4356  
 Longitude: -80.3308

### Reporting Frequency

Monitoring Plan Location IDs	Reporting Frequency	Begin Quarter	End Quarter
PTP1	Q - Quarterly	1995 QTR 1	

### Monitoring Location Attributes

Unit/Stack/Pipe Identifier	Duct Indicator	Ground Elevation	Stack Height	Gross Area Exit	Gross Area Flow	Material Code	Shape Code	Begin Date	End Date
PTP1		19	397	257				01/01/1995	

### Unit Operation Information

Unit Identifier	Non-Load Base Id	Commence Operation Date	Commence Commercial Operation Date	Code	Boiler/Turbine Type		Value (mmBtu)	Max Heat Input
					Begin Date	End Date		
PTP1		04/22/1967	04/22/1967	DB	04/22/1967	04/22/1967	4150.0	04/22/1967

Unit Type Codes: DB - Dry bottom wall-fired boiler

### Unit Program Information

Unit Identifier	Program Code	Unit Class	Unit Monitor Certification Begin Date	Unit Monitor Certification Deadline
PTP1	ARP	P2	01/01/1995	01/01/1995
	CAIRNOX	A	01/01/2008	01/01/2008
	CAIROS	A	05/01/2008	05/01/2008
	CAIRSO2	A	01/01/2009	01/01/2009
	TRNOXOS	A	05/01/2012	05/01/2012

**Monitoring Plan Printout Report**  
January 31, 2014 10:26 AM

**Facility Name:** Turkey Point

**Facility ID (ORISPL):** 621

**Unit Fuel**

Unit Identifier	Fuel Type	Fuel Indicator	Demonstration Method for GCV	Demonstration Method for Daily Sulfur	Ozone Season Indicator	Begin Date	End Date
PTP1	OIL	S				01/01/1995	
	PNG	P				01/01/1995	

Fuel Type Codes: PNG - Pipeline Natural Gas

OIL - Residual Oil

S - Secondary

P - Primary

Fuel Indicator Codes:

**Unit Controls**

Unit Identifier	Parameter	Control Equipment	Original Ind	Seasonal Ind	Installation Date	Optimization Date	Retirement Date
PTP1	PART	C	Y				
	NOX	LNB			05/31/1995		

Control Equipment Descriptions: LNB - Low NOx Burner Technology (Dry Bottom only)

C - Cyclone

Facility Name: Turkey Point  
Facility ID (ORISPL): 621

Monitoring Method

Unit/Stack/Pipe Identifier	Parameter	Methodology	Substitute Data Approach	Bypass Approach Code	Begin Date/Hour	End Date/Hour
PTP1	CO2M	FSA	SPTS		01/01/2000 00	
	HI	AD	SPTS		01/01/2000 00	
	NOX	NOXR			01/01/2008 00	
	NOXR	CEM	SPTS		01/01/1995 00	
	OP	COM			01/01/1995 00	
	SO2	AD	SPTS		01/01/2000 00	

- Parameter Codes:
- SO2 - SO2 Hourly Mass Rate (lb/hr)
  - OP - Opacity
  - NOXR - NOx Emission Rate (lb/mmBtu)
  - NOX - NOx Hourly Mass Rate (lb/hr)
  - HI - Heat Input Rate (mmBtu/hr)
  - CO2M - CO2 Mass (ton)
  - NOXR - NOx Mass Calculated from NOx Emission Rate
  - FSA - Fueling Sample and Analysis
  - COM - Continuous Opacity or Particulate Matter Monitor
  - CEM - Continuous Emission Monitor
  - AD - Appendix D
  - SPTS - Standard Part 75 for Missing Data
- Methodology Codes:
- Substitute Data Codes:

Monitoring System / Analytical Components

# Monitoring Plan Printout Report

January 31, 2014 10:26 AM

## Facility Name: Turkey Point

Facility ID (ORISPL): 621

System										Component									
Unit/Stack Identifier	ID	Type	Des	Begin Date/Hour	End Date/Hour	ID	Type	SAM	RAS	Manufacturer	Model or Version	Serial Number	Begin Date/Hour	End Date/Hour					
PTP1	101	SO2	P	01/01/1995 00	12/31/1999 23	001	SO2	DIN	W	TECO	43B	43B-47150-278	01/01/1995 00	12/31/1999 23					
						999	DAHS			BABCOCK & WILCOX	9.0.003	NTDAHS-PTP12	01/01/1995 00	12/31/1999 23					
	102	NOX	P	01/01/1995 00		002	NOX	DIN	W	TEI	42	42-47130-277	01/01/1995 00	01/13/2003 14					
						003	CO2	DIN	W	CALIFORNIA ANALYTICAL	3300	N3K4184T	01/01/1995 00	01/03/2008 11					
						777	PRB	DIN		EPM	PTF1PRB01	PTF1PRB01	01/01/1995 00	09/02/2009 11					
						999	DAHS			BABCOCK & WILCOX	9.0.003	NTDAHS-PTP12	01/01/1995 00						
						A02	NOX	DOU	W	TEI	42C	42C-74776-385	01/13/2003 15	11/12/2013 12					
						A03	CO2	DOU	W	CALIFORNIA ANALYTICAL	600D	U10041	01/03/2008 12						
						A77	PRB	DOU		MC PRODUCTS	SP2006	16504/2001083	09/02/2009 12						
						B02	NOX	DOU	W	THERMO	42I	1315157764	11/12/2013 13						
103	CO2	P	01/01/1995 00	12/31/1999 23	003	CO2	DIN	W	CALIFORNIA ANALYTICAL	3300	N3K4184T	01/01/1995 00	12/31/1999 23						
					999	DAHS			BABCOCK & WILCOX	9.0.003	NTDAHS-PTP12	01/01/1995 00	12/31/1999 23						
104	FLOW	P	01/01/1995 00	12/31/1999 23	004	FLOW	DP	W	AIR MONITOR	MASSTRON	6081D	01/01/1995 00	12/31/1999 23						
					999	DAHS			BABCOCK & WILCOX	9.0.003	NTDAHS-PTP12	01/01/1995 00	12/31/1999 23						
105	OP	P	01/01/1995 00		005	OP	ISC		PHOENIX INSTRUMENTS, INC.	OPAC20/20	OPAC-1065	01/01/1995 00							
					999	DAHS			BABCOCK & WILCOX	9.0.003	NTDAHS-PTP12	01/01/1995 00							
108	GAS	P	01/01/2000 00		008	GFFM	ORF		DANIEL INDUSTRIES INC.	2522	385316	01/01/2000 00	06/30/2010 11						
					999	DAHS			BABCOCK & WILCOX	9.0.003	NTDAHS-PTP12	01/01/2000 00							
					A08	GFFM	ORF		DANIEL INDUSTRIES INC.	2522	385187	06/30/2010 12	02/11/2011 11						
					B08	GFFM	ORF		DANIEL INDUSTRIES INC.	2522	385315	02/11/2011 12							
109	OILM	P	01/01/2000 00		009	OFFM	COR		MICROMOTION	CMF300	300147	01/01/2000 00							
					999	DAHS			BABCOCK & WILCOX	9.0.003	NTDAHS-PTP12	01/01/2000 00							

**Facility Name: Turkey Point**

Facility ID (ORISPL): 621

**System Types Descriptions:**

- SO2 - SO2 Concentration
- NOX - NOx Emission Rate
- CO2 - CO2 Concentration
- FLOW - Stack Flow
- OP - Opacity
- GAS - Gas Fuel Flow
- OILM - Mass of Oil Fuel Flow

**System Designations Descriptions:**

Sample Acquisition Method (SAM):

- P - Primary
- ORF - Orifice
- ISC - Cross Stack In Situ
- DP - Differential Pressure
- DOU - Dilution Out-of-Stack
- DIN - Dilution In-Stack
- COR - Corolls

**Component Types Descriptions:**

- SO2 - SO2 Concentration
- DAHS - Data Acquisition and Handling System
- NOX - NOx Concentration
- CO2 - CO2 Concentration
- PRB - Probe
- FLOW - Stack Flow Analyzer
- OP - Opacity Monitor
- GFFM - Gas Fuel Flowmeter
- OFFM - Oil Fuel Flowmeter

**Monitoring System Fuel Flow**

Unit/Stack/Pipe Identifier	System ID	Fuel Code	Max Fuel Flow Rate	Units of Measure	Source Code	Begin Date/Hour	End Date/Hour
PTP1	108	PNG	42810.0	HSCF	URV	01/01/2000 00	
	109	OIL	228000.0	LBHR	URV	01/01/2000 00	

**System Fuel Codes Descriptions:**

PNG - Pipeline Natural Gas

OIL - Residual Oil

**Units of Measure Descriptions:**

LBHR - Pounds / Hour

HSCF - Hundred Standard Cubic Feet / Hour

**Source Codes Descriptions:**

URV - Upper Range Value

Facility Name: Turkey Point  
Facility ID (ORISPL): 621

Analyzer Range Data

Unit/Stack/Pipe Identifier	Component Type	Component ID	Range Code	Dial Range Indicator	Begin Date/Hour	End Date/Hour
PTP1	CO2	003	High Range		01/01/1995 00	01/03/2008 11
	CO2	A03	High Range		01/03/2008 12	
	NOX	002	High Range		01/01/1995 00	12/31/2003 23
	NOX	A02	High Range		01/13/2003 15	11/12/2013 12
	NOX	B02	High Range		11/12/2013 13	
	SO2	001	High Range		01/01/1995 00	12/31/1999 23

Component Types Descriptions:  
 CO2 - CO2 Concentration  
 NOX - NOx Concentration  
 SO2 - SO2 Concentration



Facility Name: Turkey Point  
Facility ID (ORISPL): 621

Emissions Formulas

Unit/Stack/Pipe Identifier	Parameter	Formula ID	Formula Code	Formula	Begin Date/Hour	End Date/Hour
PTP1	SO2	002	D-2	$2.0 * S\#(009-109) * \%SULFUR\_OIL / 100$	01/01/1995 00	
	NOXR	004	19-7	$1.194 * 10^{**7} * S\#(B02-102) * F\#(010) * (100/S\#(A03-102))$	01/01/1995 00	
	CO2M	006	G-1	$(44 * CARBON\_BURNED\_GAS) / 24000$	01/01/1995 00	
	HI	008	F-19	$S\#(009-109) * GCV\_OIL / 10^{**6}$	01/01/1995 00	
	SO2	009	D-5	$0.0006 * F\#(011)$	01/01/1995 00	
	FC	010	F-8	$X\_OIL * 1420 + X\_GAS * 1040$	01/01/1995 00	
	HI	011	F-20	$S\#(B08-108) * GCV\_GAS / 10^{**6}$	01/01/1995 00	
	CO2M	012	G-1	$(44 * CARBON\_BURNED\_OIL) / 24000$	01/01/1995 00	
	HI	013	D-15A	$(F\#(008) * COMBUSTION\_TIME\_OIL + F\#(011) * COMBUSTION\_TIME\_GAS) / T\_PTP1$	01/01/1995 00	
	NOX	014	F-24A	$NOX\_MASS = F\#(004) * F\#(013) * T\_UNIT$	01/01/2008 00	
	SO2	025	D-12	$SO2\_TOTAL = (F\#(002) * T\_OIL) + (F\#(009) * T\_GAS)$	01/01/1995 00	

Parameter Codes Descriptions: SO2 - SO2 Hourly Mass Rate (lb/hr)

NOXR - NOx Emission Rate (lb/mmBtu)

CO2M - CO2 Mass (ton)

HI - Heat Input Rate (mmBtu/hr)

FC - F-Factor Carbon-based

NOX - NOx Hourly Mass Rate (lb/hr)

G-1 - CO2M (from fuel composition)

F-8 - FD/FC/FW (from multiple fuels)

F-24A - NOX (from NOX rate, HI)

F-20 - HI (same as D-6)

F-19 - HI (same as D-8)

D-5 - SO2 (from gas SO2 emission rate, HI)

D-2 - SO2 (from OILM, oil sulfur content)

D-15A - HI (from HI rate for multiple fuels)

D-12 - SO2 (from SO2 rate for multiple fuels)

19-7 - NOXR/SO2R (same as F-6)

Facility Name: Turkey Point

Facility ID (ORISPL): 621

Span Values

Unit/Stack/Pipe Identifier	Comp Type	Scale	Method	MFC/MPF	MEC	Span Value	Full-Scale Range	Units of Measure	Scale Transition Point	Def. High Range Value	Flow Full Range (SCFH)	Flow Span Value (SCFH)	Begin Date/Hour	End Date/Hour
PTP1	CO2	H	HD	13.0		20.000	20.000	PCT					01/01/1995 00	
	FLOW		TR	56361600		1174.200	1174.200	KSCFM					01/01/1995 00	12/31/1999 23
	NOX	H	TR	790.0		1000.000	1000.000	PPM					01/01/1995 00	09/13/2000 19
	NOX	H	TR	634.0		800.000	800.000	PPM					09/13/2000 19	04/29/2009 09
	NOX	H	HD	481.0		600.000	600.000	PPM					04/29/2009 10	
	SO2	H	F	560.4		800.000	800.000	PPM					01/01/1995 00	12/31/1999 23

Component Types Descriptions:

- CO2 - CO2 Concentration
- FLOW - Stack Flow Analyzer
- NOX - NOx Concentration
- SO2 - SO2 Concentration
- TR - Test Results
- HD - Historical Data
- F - Formula
- PPM - Parts per Million
- PCT - Percentage
- KSCFM - Thousand Standard Cubic Feet of Stack Flow / Minute

Span Method Codes Descriptions:

Units of Measure Descriptions:

Unit/Stack/Pipe Load or Operating Level Information

Unit/Stack/Pipe Identifier	Maximum Hourly Load	Units of Measure	Upper Bound of Range of Operation	Lower Bound of Range of Operation	Designated Normal Op. Level	Second Most Frequently Used Op. Level	Second Normal Indicator	Load Analysis Date	Begin Date/Hour	End Date/Hour
PTP1	440	MW	440	44	High	Low	Yes	03/31/2000	03/31/2000 00	07/12/2011 12
	440	MW	440	44	Low	Mid	Yes	07/12/2011	07/12/2011 13	

Units of Measure Descriptions:

MW - Megawatt

**Monitoring Plan Printout Report**  
January 31, 2014 10:26 AM

**Facility Name:** Turkey Point

Facility ID (ORISPL): 621

**Monitoring Defaults**

Unit/Stack/Pipe Identifier	Parameter	Value	Units of Measure	Purpose Code	Fuel Type	Operating Condition	Source of Value	Begin Date/Hour	End Date/Hour
PTP1	CO2N	5.0000	PCT	DC	NFS	A	DEF	01/01/1995 00	
	NORX	1.0300	LBMMBTU	MD	NFS	A	TEST	01/01/1995 00	09/13/2000 19
	NORX	0.8270	LBMMBTU	MD	NFS	A	TEST	09/13/2000 19	

**Parameter Codes Descriptions:**

NORX - Maximum NOx Emission Rate (lb/mmBtu)

CO2N - CO2 Minimum Concentration (pct)

PCT - Percentage

LBMMBTU - Pounds / mmBtu

MD - Missing Data (or Unmonitored Bypass Stack or Emergency Fuel) Default

DC - Diluent Cap

NFS - Non-Fuel Specific

A - Any Hour

TEST - Unit or Stack Testing

DEF - Default Value from Part 75

**Units of Measure Descriptions:**


**Purpose Codes Descriptions:**

**Fuel Type Codes Descriptions:**


**Operating Conditions Descriptions:**

**Source Codes Descriptions:**

ATTACHMENT #1 - SCHEMATIC DIAGRAM  
 TURKEY POINT PLANT - UNIT 1  
 ORIS CODE: 000621  
 NADB BOILER ID: PTP1



ATTACHMENT #3 - DATA INFORMATION FLOW DIAGRAM  
TURKEY POINT PLANT - UNIT 1  
ORIS CODE: 000621  
NADB BOILER I.D. - PTP1



\*COMMON DAHS FOR PTP1 AND PTP2




CONTINUOUS EMISSION MONITORING SYSTEM  
RELATIVE ACCURACY TEST AUDIT  
FLORIDA POWER & LIGHT COMPANY  
TURKEY POINT POWER PLANT  
UNIT No. 1  
December 18, 2013

TEST PERFORMED BY:  
FLORIDA POWER & LIGHT  
EMISSION TEST GROUP  
700 UNIVERSE BLVD.  
JUNO BEACH, FLORIDA 33408

CERTIFICATION OF VALIDITY

Relative Accuracy Test Audit  
Plant: Turkey Point  
Unit: 1  
Test Date(s): December 18, 2013

I hereby certify the information and data provided in this emission test report for tests conducted at the above facility on the above date are true and correct, to the best of my knowledge.

A handwritten signature in black ink, appearing to read "A. J. Mocha", is written over a horizontal line.

A. J. Mocha

Emission Test Coordinator



**PERSONNEL AND PROCEDURES**

**Turkey Point - 12/18/2013**

**SCOPE OF WORK**

The Emission Test Group of Florida Power & Light conducted a relative accuracy test on the Nitrogen Oxides (NOx) and Carbon Dioxide (CO2) continuous emission monitoring system (CEM) which is installed at the Turkey Point Plant Unit No. 1. Said tests were performed on December 18, 2013 to evaluate the relative accuracy of these analyzers in accordance with EPA 40 CFR 75, Appendix A.

**TEST CREW:**

A. J. Mocha (Test Coordinator)

A. J. De La Vega

S. C. Webb

**REPORT COMPILATION:**

A. J. Mocha

**ANALYZERS**

PARAMETER	INSTRUMENT	TYPE	RANGE
Nox	Thermo	CHEMILUMINESCENCE	0 - 250
	S/N 0335103532		
O2	SERVOMEX 1400B	PARAMAGNETIC	0 - 10
	S/N 1420B701/932		
CO2	SERVOMEX 1400B	INFRARED (NDIR)	0 - 20
	S/N 1410D3453		


### SUMMARY OF RESULTS

	PERFORMANCE REQUIRED	PERFORMANCE DEMONSTRATED
NOx (lb/MMBTU)	< or = 7.5 %	4.19 %

### FIELD PROCEDURES

1. The analyzers are set-up and given a two hour warm-up Period before any calibration procedures are initiated. An interference response test was conducted on each Analyzer prior to initial field use in accordance with 40 CFR, pt. 60, app. A, meth. 20, sec. 5.4.
2. After the completion of the warm-up, calibrations are Performed using EPA Protocol One span gases.
3. Just prior to actual sampling, a system bias check and Response time test is run by injecting an upscale span Gas and a zero gas at the outlet of the sampling probe For each analyzer.
4. Pollutants and diluent were determined using EPA Methods 3A, 6C and 7E.
5. Moisture is continuously drained to minimize contact Between the condensate and sample gas.
6. After each run a system bias check is performed to Calculate system drift on each analyzer.
7. The analog output of the analyzers are data logged onto A computer during sampling.
8. The moisture of the flue gas was determined using the condensed water collected in a separate sampling train along with dry gas meter volumes according to EPA Method 4.

# EPA Method 3A,7E & 10 Sampling Train




1. HEATED STAINLESS STEEL PROBE WITH FILTER
2. THREE WAY VALVE
3. HEATED SAMPLE LINE
4. MOISTURE REMOVAL SAMPLING CHILLER
5. MOISTURE REMOVAL PUMP
6. 3/8" O.D. SAMPLE LINE

7. VACUUM GAUGE
8. VACUUM PUMP
9. SAMPLE VALVE
10. CALIBRATION MANIFOLD
11. CALIBRATION GAS LINE
12. GAS MANIFOLD

13. O<sub>2</sub>/CO<sub>2</sub>, NO<sub>x</sub> & CO ANALYZERS
14. DATA ACQUISITION SYSTEM
15. EPA PROTOCOL 1 CALIBRATION GASES

**FLORIDA POWER & LIGHT CO.  
Stack Diagram and Sampling Points  
Turkey Point Unit 1**

Pollutant, diluent and moisture sampling is conducted at three points 0.4, 1.2, and 2.0 meters from the inner stack wall as per 40 CFR Part 75 App. A, Sec 6.5.6 (b) (2).



FILE: CEMSPTF1

### SAMPLE CALCULATIONS

CORRECTED CONCENTRATIONS, DRY BASIS:

$$\bar{C} = \frac{(C - C_o) * C_{ma}}{(C_m - C_o)}$$

$\bar{C}$  = Average gas concentration indicated by analyzer, dry basis.

$C_o$  = Average of initial and final system calibration bias check responses for the zero gas.

$C_m$  = Average of initial and final system calibration bias check responses for the upscale gas.

$C_{ma}$  = Actual concentration of the upscale gas.  
Pollutant Concentration, LB/DSCF:

$$C \text{ (lb/dscf)} = C \text{ (ppm)} * (2.59 * 10^{-9}) * (\text{molecular wt.})$$

$C$  (ppm) = Corrected concentration dry basis, ppm.

Molecular weight = 46.01 for NO<sub>x</sub>, 64.06 for SO<sub>2</sub>.

EMISSION RATE, LB/MM BTU:

$$E = C \text{ (lb/dscf)} * F_c * \frac{100}{CO_2}$$

$C$  (lb/dscf) = pollutant concentration, lb / dscf.

$F_c$  = 1420 dscf/mmbtu oil.

CO<sub>2</sub> = Percent carbon dioxide by volume, dry basis.

**APPENDIX A**  
**RELATIVE ACCURACY SHEETS**

FLORIDA POWER AND LIGHT COMPANY  
EMISSION TEST GROUP  
700 UNIVERSE BLVD.  
JUNO BEACH, FLORIDA 33408

**NO<sub>x</sub> LB/MMBTU RELATIVE ACCURACY**

PLANT: TURKEY POINT  
UNIT: 1  
LOAD: MID 200 MW  
DATE: 12/18/2013

ANALYZER: TECO 42  
SERIAL # 42I-1315157764

RUN	TIME START	TIME END	REFERENCE METHOD (lb/mmBTU)	CEM RESPONSE (lb/mmBTU)	ARITHMETIC DIFFERENCE	DIFFERENCE SQUARED
1	941	1002	0.222	0.233	-0.011	0.000121
2	1016	1037	0.236	0.239	-0.003	0.000009
3	1045	1106	0.242	0.245	-0.003	0.000009
4	1118	1139	0.237	0.246	-0.009	0.000081
5	1147	1208	0.234	0.243	-0.009	0.000081
6	1218	1239	0.226	0.235	-0.009	0.000081
7	1248	1309	0.228	0.236	-0.008	0.000064
8	1319	1340	0.227	0.235	-0.008	0.000064
9	1350	1411	0.222	0.230	-0.008	0.000064
			AVERAGE	AVERAGE	SUM OF DIFF.	SUM OF THE SQUARES
			0.230	0.238	-0.068	0.0006

\*\*MEAN DIFFERENCE,  $\bar{d}$  (Eq. A-7) -0.008  
 \*\*STANDARD DEVIATION, Sd (Eq. A-8) 0.0027  
 \*\*CONFIDENCE COEFFICIENT, |CC| (Eq. A-9) 0.0021

\*\*PERCENT (%) RELATIVE ACCURACY, RA (Eq. A-10) 4.19

\*\*BIAS ADJUSTMENT FACTOR, BAF (Eq. A-12) 1.000

\*\* 40 CFR 75, Appendix A

\* CEMS NUMBER ROUNDED TO MATCH EDR

APPENDIX B

MOISTURE AND POLLUTANT FIELD DATA SHEETS



**FLORIDA POWER AND LIGHT CO.  
TURKEY POINT 1**

12/18/13

**ANALYZER CALIBRATION ERROR**

RANGE SETTING	GAS UNITS	CERTIFIED GAS VALUE	ANALYZER VALUE	DIFF PPM	% SPAN	ANALYZER SERIAL #
250	ppm NOx	0.0	-0.01	0.0	0.0	0335103532
	ppm NOx	127.5	127.5	0.0	0.0	
	ppm NOx	242.0	244.5	2.5	1.0	
10	% O2	0.00	0.05	0.1	0.5	1420/B701/932
	% O2	5.50	5.53	0.0	0.3	
	% O2	9.74	9.78	0.0	0.4	
20	% CO2	0.00	0.03	0.0	0.2	01415D3453
	% CO2	10.00	10.00	0.0	0.0	
	% CO2	19.40	19.39	0.0	-0.1	

**RUN 1 --- SYSTEM BIAS AND SYSTEM DRIFT DATA**

GAS UNITS	ANALYZER VALUE	PRETEST CHECK	% SPAN	POSTTEST CHECK	% SPAN	% DRIFT
ppm NOx	-0.01	0.00	0.0	-0.02	0.0	0.0
ppm NOx	127.5	127.5	0.0	126.8	-0.3	-0.3
% O2	0.05	0.04	-0.1	0.03	-0.2	-0.1
% O2	5.53	5.53	0.0	5.50	-0.3	-0.3
% CO2	0.03	0.03	0.0	0.00	-0.2	-0.2
% CO2	10.00	10.00	0.0	10.01	0.1	0.1

**RUN 1 --- UNCORRECTED ANALYZER DATA**

Date & Time	NOx PPM	% O2	% CO2
12/18/2013 9:41	146.63	6.49	8.26
12/18/2013 9:42	148.63	6.55	8.22
12/18/2013 9:43	147.25	6.47	8.27
12/18/2013 9:44	146.69	6.48	8.26
12/18/2013 9:45	147.75	6.58	8.20
12/18/2013 9:46	147.88	6.56	8.21
12/18/2013 9:47	144.69	6.37	8.32
12/18/2013 9:48	144.81	6.46	8.27
12/18/2013 9:49	147.31	6.50	8.25
12/18/2013 9:50	149.06	6.50	8.25
12/18/2013 9:51	144.81	6.46	8.27
12/18/2013 9:52	146.63	6.45	8.27
12/18/2013 9:53	148.19	6.61	8.16
12/18/2013 9:54	146.06	6.48	8.23
12/18/2013 9:55	146.44	6.43	8.26
12/18/2013 9:56	145.56	6.42	8.25
12/18/2013 9:57	147.19	6.38	8.26
12/18/2013 9:58	148.25	6.47	8.19
12/18/2013 9:59	144.88	6.37	8.26
12/18/2013 10:00	146.13	6.30	8.30
12/18/2013 10:01	146.88	6.44	8.22
12/18/2013 10:02	146.19	6.32	8.29

**AVERAGES            146.72       6.46       8.25**

<b>FUEL FACTOR</b>	<b>1040</b>
--------------------	-------------

<b>CORRECTED RESULTS</b>	
NOx PPM	147.15
% O2	6.45
% CO2	8.24
LB/MMBTU NOx	0.222

**FLORIDA POWER AND LIGHT CO.  
TURKEY POINT 1**

12/18/13

**ANALYZER CALIBRATION ERROR**

RANGE SETTING	GAS UNITS	CERTIFIED GAS VALUE	ANALYZER VALUE	DIFF PPM	% SPAN	ANALYZER SERIAL #
250	ppm NOx	0.00	-0.01	0.0	0.0	0335103532
	ppm NOx	127.5	127.5	0.0	0.0	
	ppm NOx	242.0	244.5	2.5	1.0	
10	% O2	0.00	0.05	0.1	0.5	1420/B701/932
	% O2	5.50	5.53	0.0	0.3	
	% O2	9.74	9.78	0.0	0.4	
20	% CO2	0.00	0.03	0.0	0.2	01415D3453
	% CO2	10.00	10.00	0.0	0.0	
	% CO2	19.40	19.39	0.0	-0.1	

**RUN 2 -- SYSTEM BIAS AND SYSTEM DRIFT DATA**

GAS UNITS	ANALYZER VALUE	PRETEST CHECK	% SPAN	POSTTEST CHECK	% SPAN	% DRIFT
ppm NOx	-0.01	-0.02	0.0	-0.03	0.0	0.0
ppm NOx	127.5	126.8	-0.3	126.5	-0.4	-0.1
% O2	0.05	0.03	-0.2	0.02	-0.3	-0.1
% O2	5.53	5.50	-0.3	5.47	-0.6	-0.3
% CO2	0.03	0.00	-0.2	0.02	-0.1	0.1
% CO2	10.00	10.01	0.1	10.02	0.1	0.1

**RUN 2 -- UNCORRECTED ANALYZER DATA**

Date & Time	NOx PPM	% O2	% CO2
12/18/2013 10:16	150.38	6.53	8.09
12/18/2013 10:17	150.69	6.49	8.13
12/18/2013 10:18	153.13	6.66	8.04
12/18/2013 10:19	149.63	6.44	8.18
12/18/2013 10:20	150.25	6.54	8.12
12/18/2013 10:21	149.44	6.56	8.11
12/18/2013 10:22	149.44	6.47	8.17
12/18/2013 10:23	149.94	6.53	8.13
12/18/2013 10:24	152.63	6.47	8.16
12/18/2013 10:25	153.81	6.49	8.14
12/18/2013 10:26	153.06	6.56	8.08
12/18/2013 10:27	150.69	6.49	8.11
12/18/2013 10:28	152.81	6.52	8.09
12/18/2013 10:29	152.44	6.40	8.15
12/18/2013 10:30	153.69	6.56	8.05
12/18/2013 10:31	153.63	6.37	8.16
12/18/2013 10:32	155.75	6.44	8.11
12/18/2013 10:33	155.81	6.38	8.13
12/18/2013 10:34	154.69	6.36	8.15
12/18/2013 10:35	158.25	6.56	8.01
12/18/2013 10:36	154.19	6.32	8.16
12/18/2013 10:37	154.81	6.42	8.10

**AVERAGES                    152.69      6.48      8.12**

<b>FUEL FACTOR</b>	<b>1040</b>
--------------------	-------------

<b>CORRECTED RESULTS</b>	
NOx PPM	153.74
% O2	6.50
% CO2	8.10
LB/MMBTU NOx	0.236

**FLORIDA POWER AND LIGHT CO.  
TURKEY POINT 1**

12/18/13

**ANALYZER CALIBRATION ERROR**

RANGE SETTING	GAS UNITS	CERTIFIED GAS VALUE	ANALYZER VALUE	DIFF PPM	% SPAN	ANALYZER SERIAL #
250	ppm NOx	0.00	-0.01	0.0	0.0	0335103532
	ppm NOx	127.5	127.5	0.0	0.0	
	ppm NOx	242.0	244.5	2.5	1.0	
10	% O2	0.00	0.05	0.1	0.5	1420/B701/932
	% O2	5.50	5.53	0.0	0.3	
	% O2	9.74	9.78	0.0	0.4	
20	% CO2	0.00	0.03	0.0	0.2	01415D3453
	% CO2	10.00	10.00	0.0	0.0	
	% CO2	19.40	19.39	0.0	-0.1	

**RUN 3 -- SYSTEM BIAS AND SYSTEM DRIFT DATA**

GAS UNITS	ANALYZER VALUE	PRETEST CHECK	% SPAN	POSTTEST CHECK	% SPAN	% DRIFT
ppm NOx	-0.01	-0.03	0.0	0.20	0.1	0.1
ppm NOx	127.5	126.5	-0.4	128.5	0.4	0.8
% O2	0.05	0.02	-0.3	0.03	-0.2	0.1
% O2	5.53	5.47	-0.6	5.52	-0.1	0.5
% CO2	0.03	0.02	-0.1	0.02	-0.1	0.0
% CO2	10.00	10.02	0.1	9.88	-0.6	-0.7

**RUN 3 --- UNCORRECTED ANALYZER DATA**

Date & Time	NOx PPM	% O2	% CO2
12/18/2013 10:45	157.06	6.38	8.11
12/18/2013 10:46	156.06	6.25	8.18
12/18/2013 10:47	158.19	6.47	8.05
12/18/2013 10:48	159.69	6.35	8.12
12/18/2013 10:49	160.31	6.39	8.10
12/18/2013 10:50	157.00	6.29	8.15
12/18/2013 10:51	158.56	6.45	8.05
12/18/2013 10:52	157.81	6.31	8.14
12/18/2013 10:53	157.13	6.50	8.02
12/18/2013 10:54	160.00	6.38	8.10
12/18/2013 10:55	158.06	6.31	8.14
12/18/2013 10:56	161.19	6.46	8.04
12/18/2013 10:57	158.06	6.35	8.11
12/18/2013 10:58	158.88	6.43	8.06
12/18/2013 10:59	158.44	6.34	8.12
12/18/2013 11:00	153.81	6.34	8.12
12/18/2013 11:01	158.63	6.40	8.08
12/18/2013 11:02	159.31	6.43	8.06
12/18/2013 11:03	157.00	6.24	8.18
12/18/2013 11:04	158.00	6.34	8.12
12/18/2013 11:05	158.38	6.28	8.16
12/18/2013 11:06	159.75	6.54	7.99

**AVERAGES                    158.24    6.37    8.10**

<b>FUEL FACTOR</b>	<b>1040</b>
--------------------	-------------

<b>CORRECTED RESULTS</b>	
NOx PPM	158.26
% O2	6.38
% CO2	8.14
LB/MMBTU NOx	0.242

**FLORIDA POWER AND LIGHT CO.  
TURKEY POINT 1**

12/18/13

**ANALYZER CALIBRATION ERROR**

RANGE SETTING	GAS UNITS	CERTIFIED GAS VALUE	ANALYZER VALUE	DIFF PPM	% SPAN	ANALYZER SERIAL #
250	ppm NOx	0.00	-0.01	0.0	0.0	0335103532
	ppm NOx	127.5	127.5	0.0	0.0	
	ppm NOx	242.0	244.5	2.5	1.0	
10	% O2	0.00	0.05	0.1	0.5	1420/B701/932
	% O2	5.50	5.53	0.0	0.3	
	% O2	9.74	9.78	0.0	0.4	
20	% CO2	0.00	0.03	0.0	0.2	01415D3453
	% CO2	10.00	10.00	0.0	0.0	
	% CO2	19.40	19.39	0.0	-0.1	

**RUN 4 --- SYSTEM BIAS AND SYSTEM DRIFT DATA**

GAS UNITS	ANALYZER VALUE	PRETEST CHECK	% SPAN	POSTTEST CHECK	% SPAN	% DRIFT
ppm NOx	-0.01	0.20	0.1	0.23	0.1	0.0
ppm NOx	127.5	128.5	0.4	128.7	0.5	0.1
% O2	0.05	0.03	-0.2	0.03	-0.2	0.0
% O2	5.53	5.52	-0.1	5.53	0.0	0.1
% CO2	0.03	0.02	-0.1	0.03	0.0	0.1
% CO2	10.00	9.88	-0.6	9.87	-0.7	-0.1

**RUN 4 --- UNCORRECTED ANALYZER DATA**

Date & Time	NOx PPM	% O2	% CO2
12/18/2013 11:18	157.63	6.51	8.08
12/18/2013 11:19	153.38	6.44	8.13
12/18/2013 11:20	157.00	6.62	8.02
12/18/2013 11:21	158.19	6.58	8.04
12/18/2013 11:22	158.00	6.54	8.07
12/18/2013 11:23	157.00	6.46	8.12
12/18/2013 11:24	158.94	6.61	8.03
12/18/2013 11:25	156.56	6.49	8.11
12/18/2013 11:26	155.81	6.45	8.13
12/18/2013 11:27	159.00	6.64	8.02
12/18/2013 11:28	157.44	6.47	8.12
12/18/2013 11:29	158.63	6.46	8.13
12/18/2013 11:30	157.44	6.47	8.12
12/18/2013 11:31	159.44	6.58	8.05
12/18/2013 11:32	156.88	6.46	8.12
12/18/2013 11:33	158.56	6.52	8.09
12/18/2013 11:34	157.44	6.53	8.08
12/18/2013 11:35	157.63	6.44	8.14
12/18/2013 11:36	155.19	6.52	8.08
12/18/2013 11:37	156.63	6.56	8.06
12/18/2013 11:38	156.13	6.47	8.11
12/18/2013 11:39	158.06	6.48	8.10

**AVERAGES                    157.32      6.51      8.09**

FUEL FACTOR	1040
-------------	------

<b>CORRECTED RESULTS</b>	
NOx PPM	156.02
% O2	6.49
% CO2	8.19
LB/MMBTU NOx	0.237

**FLORIDA POWER AND LIGHT CO.  
TURKEY POINT 1**

12/18/13

**ANALYZER CALIBRATION ERROR**

RANGE SETTING	GAS UNITS	CERTIFIED GAS VALUE	ANALYZER VALUE	DIFF PPM	% SPAN	ANALYZER SERIAL #
250	ppm NOx	0.00	-0.01	0.0	0.0	0335103532
	ppm NOx	127.5	127.5	0.0	0.0	
	ppm NOx	242.0	244.5	2.5	1.0	
10	% O2	0.00	0.05	0.1	0.5	1420/B701/932
	% O2	5.50	5.53	0.0	0.3	
	% O2	9.74	9.78	0.0	0.4	
20	% CO2	0.00	0.03	0.0	0.2	01415D3453
	% CO2	10.00	10.00	0.0	0.0	
	% CO2	19.40	19.39	0.0	-0.1	

**RUN 5 --- SYSTEM BIAS AND SYSTEM DRIFT DATA**

GAS UNITS	ANALYZER VALUE	PRETEST CHECK	% SPAN	POSTTEST CHECK	% SPAN	% DRIFT
ppm NOx	-0.01	0.23	0.1	0.25	0.1	0.0
ppm NOx	127.5	128.7	0.5	129.0	0.6	0.1
% O2	0.05	0.03	-0.2	0.05	0.0	0.2
% O2	5.53	5.53	0.0	5.49	-0.4	-0.4
% CO2	0.03	0.03	0.0	0.02	-0.1	-0.1
% CO2	10.00	9.87	-0.7	9.87	-0.7	0.0

**RUN 5 --- UNCORRECTED ANALYZER DATA**

Date & Time	NOx PPM	% O2	% CO2
12/18/2013 11:47	153.25	6.42	8.14
12/18/2013 11:48	155.63	6.45	8.12
12/18/2013 11:49	158.69	6.56	8.05
12/18/2013 11:50	157.25	6.45	8.12
12/18/2013 11:51	156.19	6.56	8.05
12/18/2013 11:52	155.94	6.50	8.09
12/18/2013 11:53	153.63	6.39	8.16
12/18/2013 11:54	148.94	6.36	8.18
12/18/2013 11:55	158.81	6.59	8.03
12/18/2013 11:56	158.31	6.45	8.12
12/18/2013 11:57	154.94	6.35	8.18
12/18/2013 11:58	157.81	6.53	8.07
12/18/2013 11:59	159.56	6.53	8.07
12/18/2013 12:00	158.13	6.51	8.08
12/18/2013 12:01	156.44	6.52	8.08
12/18/2013 12:02	154.44	6.36	8.17
12/18/2013 12:03	156.13	6.51	8.08
12/18/2013 12:04	156.13	6.30	8.21
12/18/2013 12:05	158.50	6.58	8.03
12/18/2013 12:06	155.25	6.38	8.16
12/18/2013 12:07	156.69	6.46	8.11
12/18/2013 12:08	155.00	6.43	8.13

**AVERAGES                      156.17           6.46           8.11**

FUEL FACTOR	1040
-------------	------

CORRECTED RESULTS	
NOx PPM	154.58
% O2	6.46
% CO2	8.21
LB/MMBTU NOx	0.234

FLORIDA POWER AND LIGHT CO.  
TURKEY POINT 1

12/18/13

ANALYZER CALIBRATION ERROR

RANGE SETTING	GAS UNITS	CERTIFIED GAS VALUE	ANALYZER VALUE	DIFF PPM	% SPAN	ANALYZER SERIAL #
250	ppm NOx	0.00	-0.01	0.0	0.0	0335103532
	ppm NOx	127.5	127.5	0.0	0.0	
	ppm NOx	242.0	244.5	2.5	1.0	
10	% O2	0.00	0.05	0.1	0.5	1420/B701/932
	% O2	5.50	5.53	0.0	0.3	
	% O2	9.74	9.78	0.0	0.4	
20	% CO2	0.00	0.03	0.0	0.2	01415D3453
	% CO2	10.00	10.00	0.0	0.0	
	% CO2	19.40	19.39	0.0	-0.1	

RUN 6 -- SYSTEM BIAS AND SYSTEM DRIFT DATA

GAS UNITS	ANALYZER VALUE	PRETEST CHECK	% SPAN	POSTTEST CHECK	% SPAN	% DRIFT
ppm NOx	-0.01	0.25	0.1	0.26	0.1	0.0
ppm NOx	127.5	129.0	0.6	129.0	0.6	0.0
% O2	0.05	0.05	0.0	0.04	-0.1	-0.1
% O2	5.53	5.49	-0.4	5.44	-0.9	-0.5
% CO2	0.03	0.02	-0.1	0.03	0.0	0.1
% CO2	10.00	9.87	-0.7	9.88	-0.6	0.1

RUN 6 -- UNCORRECTED ANALYZER DATA

Date & Time	NOx PPM	% O2	% CO2
12/18/2013 12:18	147.38	6.47	8.08
12/18/2013 12:19	152.50	6.41	8.12
12/18/2013 12:20	150.63	6.41	8.12
12/18/2013 12:21	152.00	6.34	8.17
12/18/2013 12:22	151.75	6.40	8.13
12/18/2013 12:23	147.63	6.37	8.16
12/18/2013 12:24	149.13	6.35	8.17
12/18/2013 12:25	152.31	6.38	8.15
12/18/2013 12:26	153.19	6.41	8.13
12/18/2013 12:27	153.25	6.48	8.09
12/18/2013 12:28	152.94	6.35	8.17
12/18/2013 12:29	151.69	6.44	8.11
12/18/2013 12:30	149.19	6.31	8.19
12/18/2013 12:31	151.38	6.48	8.09
12/18/2013 12:32	151.63	6.47	8.09
12/18/2013 12:33	152.56	6.40	8.13
12/18/2013 12:34	150.94	6.39	8.14
12/18/2013 12:35	150.56	6.26	8.22
12/18/2013 12:36	152.63	6.46	8.09
12/18/2013 12:37	152.56	6.39	8.14
12/18/2013 12:38	153.50	6.39	8.13
12/18/2013 12:39	151.31	6.34	8.17

AVERAGES                      151.39      6.40      8.14

FUEL FACTOR	1040
-------------	------

CORRECTED RESULTS	
NOx PPM	149.68
% O2	6.44
% CO2	8.23
LB/MMBTU NOx	0.226

**FLORIDA POWER AND LIGHT CO.  
TURKEY POINT 1**

12/18/13

**ANALYZER CALIBRATION ERROR**

RANGE SETTING	GAS UNITS	CERTIFIED GAS VALUE	ANALYZER VALUE	DIFF PPM	% SPAN	ANALYZER SERIAL #
250	ppm NOx	0.00	-0.01	0.0	0.0	0335103532
	ppm NOx	127.5	127.5	0.0	0.0	
	ppm NOx	242.0	244.5	2.5	1.0	
10	% O2	0.00	0.05	0.1	0.5	1420/B701/932
	% O2	5.50	5.53	0.0	0.3	
	% O2	9.74	9.78	0.0	0.4	
20	% CO2	0.00	0.03	0.0	0.2	01415D3453
	% CO2	10.00	10.00	0.0	0.0	
	% CO2	19.40	19.39	0.0	-0.1	

**RUN 7 -- SYSTEM BIAS AND SYSTEM DRIFT DATA**

GAS UNITS	ANALYZER VALUE	PRETEST CHECK	% SPAN	POSTTEST CHECK	% SPAN	% DRIFT
ppm NOx	-0.01	0.26	0.1	0.25	0.1	0.0
ppm NOx	127.5	129.0	0.6	129.0	0.6	0.0
% O2	0.05	0.04	-0.1	0.04	-0.1	0.0
% O2	5.53	5.44	-0.9	5.45	-0.8	0.1
% CO2	0.03	0.03	0.0	0.04	0.1	0.1
% CO2	10.00	9.88	-0.6	9.88	-0.6	0.0

**RUN 7 -- UNCORRECTED ANALYZER DATA**

Date & Time	NOx PPM	% O2	% CO2
12/18/2013 12:48	151.94	6.34	8.15
12/18/2013 12:49	152.19	6.37	8.13
12/18/2013 12:50	153.44	6.37	8.14
12/18/2013 12:51	151.94	6.32	8.17
12/18/2013 12:52	153.50	6.45	8.09
12/18/2013 12:53	150.50	6.34	8.16
12/18/2013 12:54	154.00	6.53	8.04
12/18/2013 12:55	151.81	6.28	8.19
12/18/2013 12:56	151.25	6.41	8.11
12/18/2013 12:57	154.25	6.36	8.14
12/18/2013 12:58	151.88	6.32	8.17
12/18/2013 12:59	152.75	6.38	8.13
12/18/2013 13:00	157.06	6.54	8.03
12/18/2013 13:01	155.25	6.50	8.06
12/18/2013 13:02	150.38	6.24	8.22
12/18/2013 13:03	153.13	6.49	8.07
12/18/2013 13:04	151.88	6.40	8.11
12/18/2013 13:05	153.06	6.44	8.09
12/18/2013 13:06	150.75	6.28	8.19
12/18/2013 13:07	155.00	6.57	8.01
12/18/2013 13:08	152.44	6.28	8.19
12/18/2013 13:09	152.63	6.48	8.06

**AVERAGES                    152.77      6.40      8.12**

FUEL FACTOR	1040
-------------	------

CORRECTED RESULTS	
NOx PPM	151.04
% O2	6.47
% CO2	8.21
LB/MMBTU NOx	0.228

**FLORIDA POWER AND LIGHT CO.  
TURKEY POINT 1**

12/18/13

**ANALYZER CALIBRATION ERROR**

RANGE SETTING	GAS UNITS	CERTIFIED GAS VALUE	ANALYZER VALUE	DIFF PPM	% SPAN	ANALYZER SERIAL #
250	ppm NOx	0.00	-0.01	0.0	0.0	0335103532
	ppm NOx	127.5	127.5	0.0	0.0	
	ppm NOx	242.0	244.5	2.5	1.0	
10	% O2	0.00	0.05	0.1	0.5	1420/B701/932
	% O2	5.50	5.53	0.0	0.3	
	% O2	9.74	9.78	0.0	0.4	
20	% CO2	0.00	0.03	0.0	0.2	01415D3453
	% CO2	10.00	10.00	0.0	0.0	
	% CO2	19.40	19.39	0.0	-0.1	

**RUN 8 --- SYSTEM BIAS AND SYSTEM DRIFT DATA**

GAS UNITS	ANALYZER VALUE	PRETEST CHECK	% SPAN	POSTTEST CHECK	% SPAN	% DRIFT
ppm NOx	-0.01	0.25	0.1	0.27	0.1	0.0
ppm NOx	127.5	129.0	0.6	129.1	0.7	0.0
% O2	0.05	0.04	-0.1	0.03	-0.2	-0.1
% O2	5.53	5.45	-0.8	5.46	-0.7	0.1
% CO2	0.03	0.04	0.1	0.04	0.1	0.0
% CO2	10.00	9.88	-0.6	9.88	-0.6	0.0

**RUN 8 -- UNCORRECTED ANALYZER DATA**

Date & Time	NOx PPM	% O2	% CO2
12/18/2013 13:19	149.81	6.37	8.13
12/18/2013 13:20	150.63	6.47	8.07
12/18/2013 13:21	149.56	6.42	8.10
12/18/2013 13:22	153.00	6.35	8.15
12/18/2013 13:23	152.00	6.47	8.07
12/18/2013 13:24	154.31	6.43	8.09
12/18/2013 13:25	151.31	6.33	8.15
12/18/2013 13:26	148.75	6.35	8.14
12/18/2013 13:27	153.25	6.44	8.09
12/18/2013 13:28	151.56	6.29	8.17
12/18/2013 13:29	153.25	6.40	8.10
12/18/2013 13:30	152.69	6.40	8.11
12/18/2013 13:31	148.75	6.34	8.15
12/18/2013 13:32	152.50	6.43	8.09
12/18/2013 13:33	151.31	6.29	8.18
12/18/2013 13:34	152.19	6.37	8.12
12/18/2013 13:35	153.00	6.36	8.13
12/18/2013 13:36	151.75	6.37	8.13
12/18/2013 13:37	153.06	6.30	8.17
12/18/2013 13:38	152.50	6.36	8.13
12/18/2013 13:39	149.44	6.37	8.13
12/18/2013 13:40	152.44	6.34	8.15

**AVERAGES                    151.68       6.38       8.13**

<b>FUEL FACTOR</b>	<b>1040</b>
--------------------	-------------

<b>CORRECTED RESULTS</b>	
NOx PPM	149.91
% O2	6.43
% CO2	8.22
LB/MMBTU NOx	0.227



**FLORIDA POWER AND LIGHT CO.  
TURKEY POINT 1**

12/18/13

**ANALYZER CALIBRATION ERROR**

RANGE SETTING	GAS UNITS	CERTIFIED GAS VALUE	ANALYZER VALUE	DIFF PPM	% SPAN	ANALYZER SERIAL #
250	ppm NOx	0.00	-0.01	0.0	0.0	0335103532
	ppm NOx	127.5	127.5	0.0	0.0	
	ppm NOx	242.0	244.5	2.5	1.0	
10	% O2	0.00	0.05	0.1	0.5	1420/B701/932
	% O2	5.50	5.53	0.0	0.3	
	% O2	9.74	9.78	0.0	0.4	
20	% CO2	0.00	0.03	0.0	0.2	01415D3453
	% CO2	10.00	10.00	0.0	0.0	
	% CO2	19.40	19.39	0.0	-0.1	

**RUN 9 -- SYSTEM BIAS AND SYSTEM DRIFT DATA**

GAS UNITS	ANALYZER VALUE	PRETEST CHECK	% SPAN	POSTTEST CHECK	% SPAN	% DRIFT
ppm NOx	-0.01	0.27	0.1	0.25	0.1	0.0
ppm NOx	127.5	129.1	0.7	128.9	0.6	-0.1
% O2	0.05	0.03	-0.2	0.03	-0.2	0.0
% O2	5.53	5.46	-0.7	5.45	-0.8	-0.1
% CO2	0.03	0.04	0.1	0.03	0.0	-0.1
% CO2	10.00	9.88	-0.6	9.87	-0.7	-0.1

**RUN 9 -- UNCORRECTED ANALYZER DATA**

Date & Time	NOx PPM	% O2	% CO2
12/18/2013 13:50	146.19	6.37	8.13
12/18/2013 13:51	152.31	6.48	8.07
12/18/2013 13:52	151.13	6.31	8.17
12/18/2013 13:53	152.69	6.52	8.04
12/18/2013 13:54	151.69	6.42	8.10
12/18/2013 13:55	150.69	6.29	8.18
12/18/2013 13:56	149.25	6.40	8.11
12/18/2013 13:57	147.94	6.31	8.17
12/18/2013 13:58	148.00	6.35	8.16
12/18/2013 13:59	148.88	6.37	8.13
12/18/2013 14:00	150.06	6.29	8.18
12/18/2013 14:01	150.44	6.42	8.10
12/18/2013 14:02	150.25	6.41	8.10
12/18/2013 14:03	148.13	6.35	8.14
12/18/2013 14:04	146.63	6.31	8.17
12/18/2013 14:05	151.06	6.48	8.06
12/18/2013 14:06	143.63	6.27	8.19
12/18/2013 14:07	146.31	6.25	8.20
12/18/2013 14:08	148.63	6.33	8.15
12/18/2013 14:09	148.81	6.28	8.18
12/18/2013 14:10	147.75	6.34	8.14
12/18/2013 14:11	146.94	6.47	8.07

**AVERAGES                      148.97      6.36      8.13**

FUEL FACTOR	1040
-------------	------

CORRECTED RESULTS	
NOx PPM	147.28
% O2	6.42
% CO2	8.23
LB/MMBTU NOx	0.222

**APPENDIX C**

**PROTOCOL GAS CERTIFICATIONS**



Air Liquide America  
Specialty Gases LLC



# RATA CLASS

Dual-Analyzed Calibration Standard

6141 EASTON ROAD, BLDG 1, PLUMSTEADVILLE, PA 18949-0310 Phone: 800-331-4953 Fax: 215-766-7226

## CERTIFICATE OF ACCURACY: Interference Free™ Multi-Component EPA Protocol Gas

**Assay Laboratory - PGVP Vendor ID: A12013**  
AIR LIQUIDE AMERICA SPECIALTY GASES LLC  
6141 EASTON ROAD, BLDG 1  
PLUMSTEADVILLE, PA 18949-0310

P.O. No.: CEM6035  
Document #: 49987543-003

**Customer**  
FLORIDA POWER & LIGHT - EMISSIONS T  
  
14925 SW 67TH AVENUE  
ATTN: ARTURO MOCHA  
MIAMI FL 33158  
US

### ANALYTICAL INFORMATION Gas Type : NO,SO2,BALN

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.  
Cylinder Number: ALM028914 Certification Date: 29Mar2013 Exp. Date: 30Mar2021  
Cylinder Pressure\*\*\*: 1939 PSIG Batch No: PLU0176655

COMPONENT	CERTIFIED CONCENTRATION (Moles)	ACCURACY**	TRACEABILITY
SULFUR DIOXIDE *	251 PPM	+/- 1%	Direct NIST and VSL
NITRIC OXIDE	127.5 PPM	+/- 1%	Direct NIST and VSL
NITROGEN - OXYGEN FREE	BALANCE		
TOTAL OXIDES OF NITROGEN	127.5 PPM		Reference Value Only

\*\*\* Do not use when cylinder pressure is below 150 psig.  
\*\* Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

### REFERENCE STANDARD

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM 0260	05Jan2018	KAL003815	255.5 PPM	SULFUR DIOXIDE
NTRM 1684	22Jul2017	KAL003769	97.60 PPM	NITRIC OXIDE

### INSTRUMENTATION

INSTRUMENT/MODEL/SERIAL#	DATE LAST CALIBRATED	ANALYTICAL PRINCIPLE
FTIR//000928781	28Mar2013	FTIR
FTIR//000928781	15Mar2013	FTIR

### ANALYZER READINGS

(Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

#### First Triad Analysis

**SULFUR DIOXIDE \***  
Date: 22Mar2013 Response Unit:PPM  
Z1=-0.01011 R1=255.1858 T1=250.8078  
R2=255.2113 Z2=0.03562 T2=250.9901  
Z3=0.18876 T3=251.0411 R3=255.5482  
Avg. Concentration: 251.1 PPM

#### Second Triad Analysis

Date: 29Mar2013 Response Unit: PPM  
Z1=-0.01430 R1=254.8857 T1=249.7746  
R2=254.8242 Z2=0.02138 T2=249.8522  
Z3=0.19240 T3=250.1729 R3=255.2560  
Avg. Concentration: 250.5 PPM

#### Calibration Curve

Concentration = A + Bx + Cx2 + Dx3 + Ex4  
r = 9.99999E-1  
Constants: A = 0.00000E + 0  
B = 9.99088E-1 C = 1.20000E-5  
D = 0.00000E + 0 E = 0.00000E + 0

#### NITRIC OXIDE

Date: 22Mar2013 Response Unit:PPM  
Z1=-0.10166 R1=97.44502 T1=128.6164  
R2=97.65139 Z2=0.26252 T2=128.8044  
Z3=0.37472 T3=128.9785 R3=97.66701  
Avg. Concentration: 128.0 PPM

Date: 29Mar2013 Response Unit: PPM  
Z1=-0.04195 R1=97.00639 T1=127.1225  
R2=97.07788 Z2=-0.00408 T2=127.5245  
Z3=0.08192 T3=127.5292 R3=97.23310  
Avg. Concentration: 128.0 PPM

Concentration = A + Bx + Cx2 + Dx3 + Ex4  
r = 9.99996E-1  
Constants: A = 0.00000E + 0  
B = 9.09194E-1 C = 1.59000E-4  
D = 0.00000E + 0 E = 0.00000E + 0

APPROVED BY:   
Michael A. Kuhns



AIR LIQUIDE

Air Liquide America  
Specialty Gases LLC



Scott™

**RATA CLASS**

*Dual-Analyzed Calibration Standard*

6141 EASTON ROAD, BLDG 1, PLUMSTEADVILLE, PA 18949-0310 Phone: 800-331-4953 Fax: 215-766-7226

**CERTIFICATE OF ACCURACY: Interference Free™ Multi-Component EPA Protocol Gas**

Assay Laboratory - PGVP Vendor ID: A12012

AIR LIQUIDE AMERICA SPECIALTY GASES LLC  
6141 EASTON ROAD, BLDG 1  
PLUMSTEADVILLE, PA 18949-0310

P.O. No.: CEM6035  
Document #: 48178486-008

Customer

FLORIDA POWER & LIGHT - EMISSIONS T

14925 SW 67TH AVENUE  
ATTN: ARTURO MOCHA  
MIAMI FL 33158  
US

**ANALYTICAL INFORMATION Gas Type : SN**

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: ALM001969 Certification Date: 01Nov2012 Exp. Date: 02Nov2020  
Cylinder Pressure\*\*\*: 1931 PSIG Batch No: PLU0140075

COMPONENT	CERTIFIED CONCENTRATION (Moles)	ACCURACY**	TRACEABILITY
NITRIC OXIDE	242 PPM	+/- 1%	Direct NIST and VSL
SULFUR DIOXIDE *	480 PPM	+/- 1%	Direct NIST and VSL
NITROGEN - OXYGEN FREE	BALANCE		
TOTAL OXIDES OF NITROGEN	242. PPM		Reference Value Only

\*\*\* Do not use when cylinder pressure is below 150 psig.

\*\* Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

**REFERENCE STANDARD**

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM 1885	04Jan2018	KAL004337	242.0 PPM	NITRIC OXIDE
NTRM 1881	07Feb2018	KAL004420	501.3 PPM	SULFUR DIOXIDE

**INSTRUMENTATION**

INSTRUMENT/MODEL/SERIAL#	DATE LAST CALIBRATED	ANALYTICAL PRINCIPLE
FTIR//000928781	28Oct2012	FTIR
FTIR//000928781	12Oct2012	FTIR

**ANALYZER READINGS**

(Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

**First Triad Analysis**

**NITRIC OXIDE**

Date: 23Oct2012 Response Unit:PPM  
Z1=0.05513 R1=241.8580 T1=242.0341  
R2=241.9930 Z2=0.10308 T2=242.4282  
Z3=0.19554 T3=242.8875 R3=242.2102  
Avg. Concentration: 242.4 PPM

**Second Triad Analysis**

Date: 01Nov2012 Response Unit: PPM  
Z1=-0.07918 R1=241.7314 T1=241.8032  
R2=241.9333 Z2=-0.05929 T2=242.2890  
Z3=0.14887 T3=242.5074 R3=242.0391  
Avg. Concentration: 242.3 PPM

**Calibration Curve**

Concentration = A + Bx + Cx<sup>2</sup> + Dx<sup>3</sup> + Ex<sup>4</sup>  
r = 9.99999E-1  
Constants: A = 0.00000E+0  
B = 9.89818E-1 C = 4.40000E-5  
D = 0.00000E+0 E = 0.00000E+0

**SULFUR DIOXIDE \***

Date: 23Oct2012 Response Unit:PPM  
Z1=-0.31551 R1=500.2749 T1=478.9885  
R2=500.3613 Z2=0.07883 T2=479.2470  
Z3=0.11184 T3=480.2228 R3=500.4024  
Avg. Concentration: 480.4 PPM

Date: 01Nov2012 Response Unit: PPM  
Z1=0.09345 R1=500.4293 T1=478.8182  
R2=500.4344 Z2=0.44479 T2=479.3505  
Z3=0.48881 T3=479.8089 R3=500.8243  
Avg. Concentration: 479.9 PPM

Concentration = A + Bx + Cx<sup>2</sup> + Dx<sup>3</sup> + Ex<sup>4</sup>  
r = 9.99984E-1  
Constants: A = 0.00000E+0  
B = 9.86831E-1 C = 4.00000E-8  
D = 0.00000E+0 E = 0.00000E+0

APPROVED BY:

*Michael A. Kuhns*  
Michael A. Kuhns

6141 EASTON ROAD, BLDG 1, PLUMSTEADVILLE, PA 18949-0310 Phone: 800-331-4953 Fax: 215-766-7226

**CERTIFICATE OF ACCURACY: EPA Protocol Gas**

Assay Laboratory - PGVP Vendor ID: A12013

AIR LIQUIDE AMERICA SPECIALTY GASES LLC  
6141 EASTON ROAD, BLDG 1  
PLUMSTEADVILLE, PA 18949-0310

P.O. No.: CEM6035  
Document #: 48971265-002

Customer  
FLORIDA PDWER & LIGHT - EMISSIDNS

14925 SW 67TH AVENUE  
ATTN: ARTURO MOCHA  
MIAMI FL 33158  
US

**ANALYTICAL INFORMATION Gas Type : CO2,O2,BALN**

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: ALM047324 Certification Date: 07Jan2013 Exp. Date: 08Jan2021  
Cylinder Pressure\*\*\*: 2000 PSIG Batch No: PLU0157505

COMPONENT	CERTIFIED CONCENTRATION (Moles)	ACCURACY**	TRACEABILITY
OXYGEN	5.50 %	+/- 1%	Direct NIST and VSL
CARBON DIOXIDE	10.0 %	+/- 1%	Direct NIST and VSL
NITROGEN	BALANCE		

\*\*\* Do not use when cylinder pressure is below 150 psig.  
\*\* Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

**REFERENCE STANDARD**

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM 2658	15May2018	ALM066268	9.930 %	OXYGEN
NTRM 1675	05Jan2018	K014964	13.94 %	CARBON DIOXIDE

**INSTRUMENTATION**

INSTRUMENT/MODEL/SERIAL#	DATE LAST CALIBRATED	ANALYTICAL PRINCIPLE
MTI/M200/170927	03Jan2013	GC-TCD
MTI/M200/170927	21Dec2012	GC-TCD

**ANALYZER READINGS**

(Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

**First Triad Analysis**

**Second Triad Analysis**

**Calibration Curve**

**OXYGEN**

Date: 07Jan2013 Response Unit:AREA  
Z1=0.00000 R1=158224.0 T1=87570.00  
R2=158221.0 Z2=0.00000 T2=87539.00  
Z3=0.00000 T3=87442.00 R3=158136.0  
Avg. Concentration: 5.500 %


Concentration = A + Bx + Cx2 + Dx3 + Ex4  
r = .99998275 2350  
Constants: A = 0.0034238  
B = 6.2709E-05 C =  
D = E =

**CARBON DIOXIDE**

Date: 07Jan2013 Response Unit:AREA  
Z1=0.00000 R1=426073.0 T1=305878.0  
R2=426210.0 Z2=0.00000 T2=305913.0  
Z3=0.00000 T3=305810.0 R3=425955.0  
Avg. Concentration: 10.00 %

Concentration = A + Bx + Cx2 + Dx3 + Ex4  
r = .99999488 1800  
Constants: A = 0.00478417  
B = 3.28108E-05 C =  
D = E =

APPROVED BY:

  
JOHN G. FITZ



Air Liquide America  
Specialty Gases LLC



# RATA CLASS

Dual-Analyzed Calibration Standard

6141 EASTON ROAD, BLDG 1, PLUMSTEADVILLE, PA 18949-0310

Phone: 800-331-4953

Fax: 215-766-7226

## CERTIFICATE OF ACCURACY: EPA Protocol Gas

Assay Laboratory - PGVP Vendor ID: A12013

AIR LIQUIDE AMERICA SPECIALTY GASES LLC  
6141 EASTON ROAD, BLDG 1  
PLUMSTEADVILLE, PA 18949-0310

P.O. No.: CEM6035  
Document #: 49987543-005

Customer  
FLORIDA POWER & LIGHT - EMISSIONS

14925 SW 67TH AVENUE  
ATTN: ARTURO MOCHA  
MIAMI FL 33158  
US

### ANALYTICAL INFORMATION Gas Type : CO2,O2,BALN

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: CC203126 Certification Date: 02Apr2013 Exp. Date: 03Apr2021  
Cylinder Pressure\*\*\*: 2000 PSIG Batch No: FLU0178700

COMPONENT	CERTIFIED CONCENTRATION (Moles)	ACCURACY**	TRACEABILITY
OXYGEN	9.74 %	+/- 1%	Direct NIST and VSL
CARBON DIOXIDE	19.4 %	+/- 1%	Direct NIST and VSL
NITROGEN	BALANCE		

\*\*\* Do not use when cylinder pressure is below 150 psig.

\*\* Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

### REFERENCE STANDARD

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM 2859 O2	14May2018	K019475	20.85 %	OXYGEN
NTRM 1875	05Jan2018	K014984	13.94 %	CARBON DIOXIDE

### INSTRUMENTATION

INSTRUMENT/MODEL/SERIAL#	DATE LAST CALIBRATED	ANALYTICAL PRINCIPLE
MTI/M200/170927	26Mar2013	GC-TCD
MTI/M200/170927	01Apr2013	GC-TCD

### ANALYZER READINGS

(Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

#### First Triad Analysis

##### OXYGEN

Date: 02Apr2013 Response Unit:AREA  
Z1=0.00000 R1=180108.0 T1=156908.0  
R2=180008.0 Z2=0.00000 T2=156892.0  
Z3=0.00000 T3=156815.0 R3=159877.0  
Avg. Concentration: 9.740 %

#### Second Triad Analysis

##### CARBON DIOXIDE

Date: 02Apr2013 Response Unit:AREA  
Z1=0.00000 R1=428939.0 T1=594981.0  
R2=427122.0 Z2=0.00000 T2=595081.0  
Z3=0.00000 T3=595249.0 R3=428853.0  
Avg. Concentration: 19.40 %

#### Calibration Curve

Concentration = A + Bx + Cx2 + Dx3 + Ex4  
r = .999999185 2858  
Constants: A = -0.00317034  
B = 6.11784E-05 C =  
D = E =

Concentration = A + Bx + Cx2 + Dx3 + Ex4  
r = .999999304 2859  
Constants: A = 0.003722548  
B = 3.2803E-05 C =  
D = E =

APPROVED BY:

JOSEPH C. FITZ



Air Liquide America  
Specialty Gases LLC



Shipped 6141 EASTON ROAD, BLDG 1 PO BOX 310  
From: PLUMSTEADVILLE PA 18949-0310  
Phone: 800-331-4953 Fax: 215-766-7226

C E R T I F I C A T E O F A N A L Y S I S

FLORIDA POWER & LIGHT - EMISSIONS T DOCUMENT#:48971265 -001  
14925 SW 67TH AVENUE PO#: CEM6035  
ATTN: ARTURO MOCHA ITEM #: P841-30AL  
MIAMI FL 33158 DATE: 08Jan2013  
US

CYLINDER #: ALM9852  
FILL PRESSURE: 02000 PSIG PRODUCT EXPIRATION: 08Jan2016

PURE MATERIAL: NITROGEN CAS# 7727-37-9  
GRADE: ACID RAIN CEM 0  
PURITY: 99.9995%

<u>IMPURITY</u>	<u>MAXIMUM CONCENTRATIONS</u>	<u>ACTUAL CONCENTRATIONS</u>
SOX	0.1 PPM	< 0.1 PPM
NOX	0.1 PPM	< 0.1 PPM
CO	0.5 PPM	< 0.5 PPM
CO2	1 PPM	< 1 PPM
THC	0.1 PPM	< 0.1 PPM
H2O	2 PPM	< 2 PPM
O2	0.5 PPM	< 0.5 PPM

QC# 26023

LOT # : PLU0158593

ANALYST:

  
JOHN C. FITZ

**APPENDIX D**  
**CALIBRATION SHEETS**



FLORIDA POWER & LIGHT

Unit PTFL

Date 12/18/13

SYSTEM RESPONSE TIME

Analyzer Type: <u>NO<sub>x</sub></u>	Span Gas value: <u>127.5</u>
Serial Number: <u>0335103532</u>	Analyzer Range: <u>0-250</u>
Method: <u>7E</u>	Sampling Train Length: <u>225</u>
Upscale Response Time: <u>121</u> seconds (high or mid level gas)	
Low-Level Response Time: <u>119</u> seconds (zero gas)	
System Response Time: <u>121</u> seconds (longer time interval)	

Method 6C, 7E, 10 & 20 system response procedure:

Introduce the upscale calibration gas until stable reading is achieved, record value.  
Next introduce low level zero gas until stable reading is achieved, record value.  
The longer interval is the response time.

## FLORIDA POWER & LIGHT

Unit: PTF 1  
 Technician: Arturo Mocha

Test Date: 12/18/2013  
 Check Date: 12/18/2013

### NO<sub>2</sub> to NO Converter Efficiency Check

Analyzer:	Thermo 42CLS	NO <sub>2</sub> Audit Gas Value (C <sub>v</sub> ):	51.6
		Serial #	ALM039021
Serial Number:	335103532	NO Calibration Gas Value:	127.5
		Serial #	ALM028914
Method:	7E		
Analyzer Range:	0 - 250		

Date & Time	NO <sub>x</sub> ppm	NO <sub>2</sub> to NO Conversion Efficiency Test using Equation 7E-7
12/18/2013 9:06	0.00	
12/18/2013 9:10	127.44	
	NO <sub>2</sub> ppm	$Eff_{NO_2} = \frac{C_{Dir}}{C_v} \times 100$
12/18/2013 9:14	53.00	
12/18/2013 9:15	53.06	
12/18/2013 9:16	52.98	
12/18/2013 9:17	53.00	Eff NO <sub>2</sub> = 102.7
AVERAGE	53.01 (C <sub>Dir</sub> )	

**Method 7E NO<sub>2</sub> to NO Conversion Efficiency Test**

8.2.4.1. Introduce NO<sub>2</sub> converter efficiency gas to the analyzer in direct calibration mode and record the NO<sub>x</sub> concentration displayed by the analyzer. Calculate the converter efficiency using Equation 7E-7 in Section 12.7. The specification for converter efficiency in Section 13.5 must be met. The NO<sub>2</sub> to NO conversion efficiency, calculated according to Equation 7E-7, must be greater than or equal to 90 percent.

Eff<sub>NO<sub>2</sub></sub> = NO<sub>2</sub> to NO converter efficiency, percent.

C<sub>Dir</sub> = Measured concentration of a calibration gas when introduced in direct calibration mode, ppmv.

C<sub>v</sub> = Manufacturer certified concentration of a calibration gas, ppmv.

**APPENDIX E**  
**CEM DATA SHEETS**

Average Values Report  
Generated: 12/18/2013 10:20

Company: Florida Power & Light PTF  
 Plant:  
 City/St: Florida City, FL  
 Source: stack1  
 RUN 1

Period Start: 12/18/2013 09:41  
 Period End: 12/18/2013 10:02  
 Validation Type: 1/1 min  
 Averaging Period: 1 min  
 Type: Block Avg

Period Start:	Average 1CO2 %	Average 1NOx ppm	Average 1NOx#M #/M	Average 1MW MW	Average 1FcFactor scf/M
12/18/2013 09:41	7.39	138.3	0.232	200.3	1040
12/18/2013 09:42	7.45	139.2	0.232	199.8	1040
12/18/2013 09:43	7.43	140.5	0.235	199.6	1040
12/18/2013 09:44	7.34	139.8	0.237	199.3	1040
12/18/2013 09:45	7.43	140.3	0.234	200.0	1040
12/18/2013 09:46	7.41	139.7	0.234	199.4	1040
12/18/2013 09:47	7.38	140.4	0.236	200.4	1040
12/18/2013 09:48	7.36	139.9	0.236	200.8	1040
12/18/2013 09:49	7.48	137.0	0.227	199.9	1040
12/18/2013 09:50	7.44	138.2	0.231	198.7	1040
12/18/2013 09:51	7.43	140.1	0.234	199.6	1040
12/18/2013 09:52	7.41	141.4	0.237	199.7	1040
12/18/2013 09:53	7.41	136.1	0.228	199.5	1040
12/18/2013 09:54	7.43	139.9	0.234	200.7	1040
12/18/2013 09:55	7.36	140.3	0.237	199.2	1040
12/18/2013 09:56	7.39	138.4	0.233	200.0	1040
12/18/2013 09:57	7.40	138.0	0.232	200.4	1040
12/18/2013 09:58	7.45	138.9	0.232	200.3	1040
12/18/2013 09:59	7.42	139.8	0.234	199.2	1040
12/18/2013 10:00	7.37	140.0	0.236	200.5	1040
12/18/2013 10:01	7.45	138.7	0.231	200.6	1040
12/18/2013 10:02	7.46	138.7	0.231	201.5	1040
<b>Daily Average*</b>	<b>7.41</b>	<b>139.3</b>	<b>0.233</b>	<b>200.0</b>	<b>1040</b>

Average Values Report  
Generated: 12/18/2013 10:38

Company: Florida Power & Light ETF  
Plant:  
City/St: Florida City, FL  
Source: stack1  
RUN 2

Period Start: 12/18/2013 10:16  
Period End: 12/18/2013 10:37  
Validation Type: 1/1 min  
Averaging Period: 1 min  
Type: Block Avg

Period Start:	Average 1CO2 %	Average 1NOx ppm	Average 1NOx#M #/M	Average 1MW MW	Average 1FcFactor scf/M
12/18/2013 10:16	7.46	141.0	0.235	200.6	1040
12/18/2013 10:17	7.43	138.4	0.231	201.7	1040
12/18/2013 10:18	7.36	141.9	0.239	200.8	1040
12/18/2013 10:19	7.48	143.6	0.238	200.8	1040
12/18/2013 10:20	7.34	145.1	0.245	201.3	1040
12/18/2013 10:21	7.43	140.6	0.235	201.7	1040
12/18/2013 10:22	7.43	142.6	0.238	200.4	1040
12/18/2013 10:23	7.40	141.6	0.238	201.0	1040
12/18/2013 10:24	7.41	139.2	0.233	201.1	1040
12/18/2013 10:25	7.46	143.9	0.240	201.5	1040
12/18/2013 10:26	7.45	143.3	0.239	200.3	1040
12/18/2013 10:27	7.43	145.5	0.243	201.5	1040
12/18/2013 10:28	7.41	144.0	0.241	200.5	1040
12/18/2013 10:29	7.39	142.5	0.239	201.4	1040
12/18/2013 10:30	7.38	143.9	0.242	200.5	1040
12/18/2013 10:31	7.46	143.1	0.238	200.9	1040
12/18/2013 10:32	7.36	143.6	0.242	200.8	1040
12/18/2013 10:33	7.43	141.2	0.236	200.6	1040
12/18/2013 10:34	7.45	144.6	0.241	200.9	1040
12/18/2013 10:35	7.41	142.5	0.239	200.9	1040
12/18/2013 10:36	7.40	141.9	0.238	200.8	1040
12/18/2013 10:37	7.39	147.2	0.247	201.6	1040
Daily Average*	7.42	142.8	0.239	201.0	1040

Average Values Report  
Generated: 12/18/2013 11:20

Company: Florida Power & Light PTF  
Plant:  
City/St: Florida City, FL  
Source: stack1  
RUN 3

Period Start: 12/18/2013 10:45  
Period End: 12/18/2013 11:06  
Validation Type: 1/1 min  
Averaging Period: 1 min  
Type: Block Avg

Period Start:	Average lCO2 %	Average lNOx ppm	Average lNOx#M #/M	Average lMW MW	Average lFcFactor scf/M
12/18/2013 10:45	7.32	144.9	0.246	200.5	1040
12/18/2013 10:46	7.47	144.9	0.241	201.8	1040
12/18/2013 10:47	7.43	145.1	0.243	201.2	1040
12/18/2013 10:48	7.43	143.5	0.240	201.4	1040
12/18/2013 10:49	7.44	147.5	0.246	201.4	1040
12/18/2013 10:50	7.44	147.7	0.247	201.0	1040
12/18/2013 10:51	7.40	147.0	0.247	200.7	1040
12/18/2013 10:52	7.48	145.3	0.241	201.2	1040
12/18/2013 10:53	7.37	146.8	0.247	200.4	1040
12/18/2013 10:54	7.37	143.5	0.242	200.5	1040
12/18/2013 10:55	7.38	146.5	0.247	201.1	1040
12/18/2013 10:56	7.41	147.8	0.248	200.7	1040
12/18/2013 10:57	7.41	146.1	0.245	200.5	1040
12/18/2013 10:58	7.40	148.7	0.250	200.6	1040
12/18/2013 10:59	7.42	145.9	0.244	200.9	1040
12/18/2013 11:00	7.41	147.7	0.248	201.5	1040
12/18/2013 11:01	7.47	144.9	0.241	200.5	1040
12/18/2013 11:02	7.46	144.8	0.241	200.7	1040
12/18/2013 11:03	7.39	146.3	0.246	201.6	1040
12/18/2013 11:04	7.44	147.1	0.246	201.1	1040
12/18/2013 11:05	7.49	146.0	0.242	201.1	1040
12/18/2013 11:06	7.42	146.1	0.245	201.0	1040
Daily Average*	7.42	146.1	0.245	201.0	1040

Average Values Report  
Generated: 12/18/2013 12:21

Company: Florida Power & Light PTF  
Plant:  
City/St: Florida City, FL  
Source: stack1  
RUN 4

Period Start: 12/18/2013 11:18  
Period End: 12/18/2013 11:39  
Validation Type: 1/1 min  
Averaging Period: 1 min  
Type: Block Avg

Period Start:	Average 1CO2 %	Average 1NOx ppm	Average 1NOx#M #/M	Average 1MW MW	Average 1FcFactor scf/M
12/18/2013 11:18	7.38	146.4	0.246	201.3	1040
12/18/2013 11:19	7.37	149.1	0.251	200.9	1040
12/18/2013 11:20	7.46	147.8	0.246	200.6	1040
12/18/2013 11:21	7.43	143.0	0.239	200.2	1040
12/18/2013 11:22	7.40	147.4	0.247	200.6	1040
12/18/2013 11:23	7.41	147.7	0.248	201.2	1040
12/18/2013 11:24	7.40	146.9	0.247	200.3	1040
12/18/2013 11:25	7.47	146.6	0.244	201.1	1040
12/18/2013 11:26	7.40	148.3	0.249	202.0	1040
12/18/2013 11:27	7.43	145.3	0.243	200.8	1040
12/18/2013 11:28	7.46	145.6	0.242	200.5	1040
12/18/2013 11:29	7.40	149.5	0.251	200.4	1040
12/18/2013 11:30	7.40	145.9	0.245	201.2	1040
12/18/2013 11:31	7.45	148.1	0.247	200.6	1040
12/18/2013 11:32	7.48	147.3	0.245	201.8	1040
12/18/2013 11:33	7.37	147.8	0.249	201.3	1040
12/18/2013 11:34	7.46	147.0	0.245	201.8	1040
12/18/2013 11:35	7.45	147.8	0.246	201.0	1040
12/18/2013 11:36	7.42	147.3	0.247	201.7	1040
12/18/2013 11:37	7.46	146.2	0.243	200.2	1040
12/18/2013 11:38	7.46	145.9	0.243	200.1	1040
12/18/2013 11:39	7.38	144.4	0.243	201.0	1040
Daily Average*	7.42	146.9	0.246	200.9	1040

Average Values Report  
Generated: 12/18/2013 12:21

Company: Florida Power & Light PTF  
 Plant:  
 City/St: Florida City, FL  
 Source: stack1  
 RUN 5

Period Start: 12/18/2013 11:47  
 Period End: 12/18/2013 12:08  
 Validation Type: 1/1 min  
 Averaging Period: 1 min  
 Type: Block Avg

Period Start:	Average 1CO2 %	Average 1NOx ppm	Average 1NOx#M #/M	Average 1MW MW	Average 1FcFactor scf/M
12/18/2013 11:47	7.51	146.0	0.241	200.7	1040
12/18/2013 11:48	7.39	147.5	0.248	201.6	1040
12/18/2013 11:49	7.47	141.4	0.235	200.9	1040
12/18/2013 11:50	7.48	146.7	0.244	200.9	1040
12/18/2013 11:51	7.37	147.0	0.248	200.3	1040
12/18/2013 11:52	7.44	146.3	0.244	201.1	1040
12/18/2013 11:53	7.42	146.2	0.245	200.9	1040
12/18/2013 11:54	7.40	145.1	0.243	201.4	1040
12/18/2013 11:55	7.43	139.6	0.233	201.4	1040
12/18/2013 11:56	7.51	141.7	0.234	200.5	1040
12/18/2013 11:57	7.37	148.8	0.251	201.0	1040
12/18/2013 11:58	7.46	146.6	0.244	201.1	1040
12/18/2013 11:59	7.52	145.2	0.240	200.8	1040
12/18/2013 12:00	7.41	147.4	0.247	201.8	1040
12/18/2013 12:01	7.40	148.7	0.250	200.2	1040
12/18/2013 12:02	7.44	147.1	0.246	200.9	1040
12/18/2013 12:03	7.40	145.6	0.244	200.8	1040
12/18/2013 12:04	7.44	142.5	0.238	201.0	1040
12/18/2013 12:05	7.41	145.9	0.244	201.6	1040
12/18/2013 12:06	7.46	144.2	0.240	200.8	1040
12/18/2013 12:07	7.32	146.5	0.249	201.6	1040
12/18/2013 12:08	7.46	144.6	0.241	201.3	1040
Daily Average*	7.43	145.5	0.243	201.0	1040



Average Values Report  
Generated: 12/18/2013 12:51

Company: Florida Power & Light PTF  
 Plant:  
 City/St: Florida City, FL  
 Source: stack1  
 RUN 6

Period Start: 12/18/2013 12:18  
 Period End: 12/18/2013 12:39  
 Validation Type: 1/1 min  
 Averaging Period: 1 min  
 Type: Block Avg

Period Start:	Average 1CO2 %	Average 1NOx ppm	Average 1NOx#M #/M	Average 1MW MW	Average 1FcFactor scf/M
12/18/2013 12:18	7.39	141.5	0.238	201.4	1040
12/18/2013 12:19	7.39	141.4	0.238	200.3	1040
12/18/2013 12:20	7.43	143.6	0.240	200.2	1040
12/18/2013 12:21	7.42	140.4	0.235	200.6	1040
12/18/2013 12:22	7.44	140.2	0.234	201.7	1040
12/18/2013 12:23	7.49	141.6	0.235	200.6	1040
12/18/2013 12:24	7.41	139.8	0.234	201.0	1040
12/18/2013 12:25	7.44	137.1	0.229	201.3	1040
12/18/2013 12:26	7.46	139.0	0.231	200.3	1040
12/18/2013 12:27	7.42	141.6	0.237	201.6	1040
12/18/2013 12:28	7.41	141.2	0.237	200.9	1040
12/18/2013 12:29	7.42	143.7	0.240	200.3	1040
12/18/2013 12:30	7.44	141.8	0.237	201.2	1040
12/18/2013 12:31	7.42	139.4	0.233	200.3	1040
12/18/2013 12:32	7.51	141.3	0.234	201.3	1040
12/18/2013 12:33	7.41	139.9	0.234	201.4	1040
12/18/2013 12:34	7.42	141.8	0.237	201.2	1040
12/18/2013 12:35	7.50	142.0	0.235	201.3	1040
12/18/2013 12:36	7.44	140.0	0.234	201.2	1040
12/18/2013 12:37	7.52	140.1	0.231	200.3	1040
12/18/2013 12:38	7.47	143.1	0.238	200.7	1040
12/18/2013 12:39	7.45	142.0	0.237	201.4	1040
Daily Average*	7.44	141.0	0.235	200.9	1040

Average Values Report  
Generated: 12/18/2013 13:43

Company: Florida Power & Light PTF  
Plant:  
City/St: Florida City, FL  
Source: stack1  
RUN 7

Period Start: 12/18/2013 12:48  
Period End: 12/18/2013 13:09  
Validation Type: 1/1 min  
Averaging Period: 1 min  
Type: Block Avg

Period Start:	Average 1CO2 %	Average 1NOx ppm	Average 1NOx#M #/M	Average 1MW MW	Average 1FcFactor scf/M
12/18/2013 12:48	7.52	141.3	0.233	200.5	1040
12/18/2013 12:49	7.42	143.6	0.240	201.8	1040
12/18/2013 12:50	7.52	143.8	0.237	200.5	1040
12/18/2013 12:51	7.47	141.9	0.236	201.5	1040
12/18/2013 12:52	7.45	142.0	0.237	200.7	1040
12/18/2013 12:53	7.56	142.4	0.234	201.4	1040
12/18/2013 12:54	7.43	142.4	0.238	201.6	1040
12/18/2013 12:55	7.49	140.7	0.233	201.0	1040
12/18/2013 12:56	7.45	143.8	0.240	200.9	1040
12/18/2013 12:57	7.47	139.8	0.232	200.5	1040
12/18/2013 12:58	7.45	141.4	0.236	200.3	1040
12/18/2013 12:59	7.50	143.3	0.237	201.4	1040
12/18/2013 13:00	7.47	140.1	0.233	201.6	1040
12/18/2013 13:01	7.45	142.6	0.238	200.3	1040
12/18/2013 13:02	7.40	146.8	0.246	200.6	1040
12/18/2013 13:03	7.41	143.9	0.241	200.4	1040
12/18/2013 13:04	7.52	138.9	0.229	201.6	1040
12/18/2013 13:05	7.45	143.7	0.240	201.3	1040
12/18/2013 13:06	7.47	141.7	0.236	201.1	1040
12/18/2013 13:07	7.39	141.0	0.237	200.8	1040
12/18/2013 13:08	7.53	141.0	0.233	201.0	1040
12/18/2013 13:09	7.37	145.2	0.245	201.2	1040
Daily Average*	7.46	142.3	0.237	201.0	1040

Average Values Report  
Generated: 12/18/2013 13:43

Company: Florida Power & Light PTF  
Plant:  
City/St: Florida City, FL  
Source: stack1  
RUN 8

Period Start: 12/18/2013 13:19  
Period End: 12/18/2013 13:40  
Validation Type: 1/1 min  
Averaging Period: 1 min  
Type: Block Avg

Period Start:	Average lCO2 %	Average lNOx ppm	Average lNOx#M #/M	Average lMW MW	Average lFcFactor scf/M
12/18/2013 13:19	7.38	143.5	0.241	201.6	1040
12/18/2013 13:20	7.43	141.4	0.236	200.7	1040
12/18/2013 13:21	7.47	139.5	0.232	200.7	1040
12/18/2013 13:22	7.37	140.0	0.236	200.9	1040
12/18/2013 13:23	7.44	140.5	0.235	201.4	1040
12/18/2013 13:24	7.47	141.9	0.236	201.1	1040
12/18/2013 13:25	7.40	142.3	0.239	200.3	1040
12/18/2013 13:26	7.45	143.3	0.239	201.7	1040
12/18/2013 13:27	7.49	140.4	0.233	200.9	1040
12/18/2013 13:28	7.47	139.5	0.232	201.0	1040
12/18/2013 13:29	7.42	142.6	0.239	201.3	1040
12/18/2013 13:30	7.50	140.8	0.233	201.6	1040
12/18/2013 13:31	7.42	142.2	0.238	200.8	1040
12/18/2013 13:32	7.44	141.2	0.236	200.6	1040
12/18/2013 13:33	7.48	137.0	0.227	200.2	1040
12/18/2013 13:34	7.44	142.1	0.237	200.6	1040
12/18/2013 13:35	7.49	139.7	0.232	200.1	1040
12/18/2013 13:36	7.51	141.6	0.234	201.3	1040
12/18/2013 13:37	7.44	141.1	0.236	201.5	1040
12/18/2013 13:38	7.47	141.2	0.235	201.6	1040
12/18/2013 13:39	7.50	141.3	0.234	201.6	1040
12/18/2013 13:40	7.44	140.4	0.234	200.7	1040
Daily Average*	7.45	141.1	0.235	201.0	1040

Average Values Report  
Generated: 12/18/2013 14:22

Company: Florida Power & Light PTF  
 Plant:  
 City/St: Florida City, FL  
 Source: stack1  
 RUN 9

Period Start: 12/18/2013 13:50  
 Period End: 12/18/2013 14:11  
 Validation Type: 1/1 min  
 Averaging Period: 1 min  
 Type: Block Avg

Period Start:	Average lCO2 %	Average lNOx ppm	Average lNOx#M #/M	Average lMW MW	Average lFcFactor scf/M
12/18/2013 13:50	7.43	139.4	0.233	201.5	1040
12/18/2013 13:51	7.55	136.6	0.225	200.2	1040
12/18/2013 13:52	7.45	136.6	0.228	201.6	1040
12/18/2013 13:53	7.40	141.3	0.237	201.1	1040
12/18/2013 13:54	7.51	140.3	0.232	200.1	1040
12/18/2013 13:55	7.39	142.2	0.239	201.3	1040
12/18/2013 13:56	7.43	140.7	0.235	201.0	1040
12/18/2013 13:57	7.53	139.6	0.230	200.3	1040
12/18/2013 13:58	7.44	138.4	0.231	200.5	1040
12/18/2013 13:59	7.48	136.4	0.226	201.1	1040
12/18/2013 14:00	7.47	140.5	0.234	201.1	1040
12/18/2013 14:01	7.45	137.8	0.230	201.0	1040
12/18/2013 14:02	7.47	138.3	0.230	200.8	1040
12/18/2013 14:03	7.46	140.3	0.234	200.6	1040
12/18/2013 14:04	7.44	139.0	0.232	201.0	1040
12/18/2013 14:05	7.41	136.1	0.228	200.9	1040
12/18/2013 14:06	7.51	136.1	0.225	200.5	1040
12/18/2013 14:07	7.41	139.6	0.234	200.6	1040
12/18/2013 14:08	7.48	132.1	0.219	200.6	1040
12/18/2013 14:09	7.55	135.8	0.223	201.5	1040
12/18/2013 14:10	7.45	137.4	0.229	201.9	1040
12/18/2013 14:11	7.48	137.2	0.228	200.5	1040
<b>Daily Average*</b>	<b>7.46</b>	<b>138.3</b>	<b>0.230</b>	<b>200.9</b>	<b>1040</b>





---

To: **Gary Andersen**

Date: **November 25, 2013**

From: **Arturo Mocha**

Department: **Emissions Test Group**

Subject: **NOx/SO2/CO2 Linearity Check  
4th Quarter 2013  
Turkey Point Unit No. 1**

A NOx/SO2/CO2 Linearity Check was conducted at Turkey Point Unit No. 1 CEM system on November 25, 2013 by the Emission Test Group. EPA Methods according to 40 CFR 75 Appendix A were used for accuracy determination.

A summary of the pertinent data and condition assessment of the CEM shelter is attached.

If you have any questions regarding this test, please contact me at the Emissions Office, 228-5089.

A handwritten signature in black ink, appearing to read "Arturo Mocha", is written above the typed name.

**Arturo J. Mocha**  
**Florida Power & Light**  
**Emission Technician**

Plant PTC

Unit 1

Date 11/25/13

### CEMS Condition Assessment Worksheet

- |   | YES                                 | NO                                  |
|---|-------------------------------------|-------------------------------------|
| 1. Was the control room notified prior to performing audit?<br>Comments _____   | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| 2. SO2 analyzer operating properly and Span factor between 0.9 and 1.2?<br>Comments _____   | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| 3. NOx analyzer operating properly and Span factor between 0.9 and 1.2?<br>Comments _____   | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| 4. CO2 analyzer operating properly?<br>Comments _____   | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| 5. Is dilution air set at 40 psi and vacuum set at 20 in. Hg?<br>Comments _____   | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| 6. Is shelter clear of dirt, debris and trash?<br>Comments _____  | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| 7. Are Span gas cylinders data entered correctly in the Netdahs?<br>Comments _____  | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| 8. Are Span gas cylinders properly secured and pressures > 250 psi?<br>Comments _____   | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| 9. Calibration Span gas values (CO2, NOx, and SO2) within analyzer range (85 to 90%)?<br>Comments _____                                     | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| 10. Is the Zero/Span gas certification of analysis available?<br>Comments _____   | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| 11. Is plant calibration Zero/Span gas expired?<br>Comments _____   | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |
| 12. Does the Zero calibration gas meet Part 72 requirements?<br>(CO<0.5ppm, CO2<1ppm, NOx<0.1ppm, SO2<0.1ppm, THC<0.1ppm)<br>Comments _____ | <input checked="" type="checkbox"/> | <input type="checkbox"/>            |
| 13. Are any alarm or out-of-control conditions shown on the DAHS summary screen?<br>Comments _____  | <input type="checkbox"/>            | <input checked="" type="checkbox"/> |

14. Overall, is the outside of shed in good condition (i.e. door operates, water leaks, regulators)?

Comments \_\_\_\_\_

15. Is shed free of ozone odor?

Comments \_\_\_\_\_

16. On completion of Linearity Audit, is regulator output (calibration gas) set to 20-30 psi?

Comments \_\_\_\_\_



**FLORIDA POWER & LIGHT  
CONTINUOUS EMISSION MONITORS  
LINEARITY CHECK WORKSHEET**

Plant \_\_\_\_\_ Turkey Point  
Unit \_\_\_\_\_ 1

Date 11/25/2013 Quarter 4th 2013  
Technician A. Mocha

<b>SO2</b>	
<b>ANALYZER</b>	
Manufacturer	TECO
Serial #	43I-0734726456
Span Setting	0 - 800 ppm
Component ID	A01
Monitoring Sys. ID	A01
Unit/Stack ID	PTP 1

<b>NOx</b>	
<b>ANALYZER</b>	
Manufacturer	TECO
Serial #	42I-1315157764
Span Setting	0 - 600 ppm
Component ID	A02
Monitoring Sys. ID	102
Unit/Stack ID	PTP 1

<b>CO2</b>	
<b>ANALYZER</b>	
Manufacturer	Cal Inst.
Serial #	600D/U10041
Span Setting	0 - 20 %
Component ID	A03
Monitoring Sys. ID	A03
Unit/Stack ID	PTP 1

	Time (EST)	Reference Value	Monitor Value	PPM Difference	Linearity Error	PROTOCOL 1 TANK SERIAL #	Pass/Fail
Low	1315	199.4	204.7	-5.30	5%	ALM038004	PASS
	1326	199.4	205.6	-6.20			
	1345	199.4	209.2	-9.80			
Mid	1320	439.0	448.8	-9.80	2.0	CC279379	PASS
	1333	439.0	446.1	-7.10			
	1351	439.0	447.9	-8.90			
High	1303	701.0	676.0	25.00	0.0	ALM001219	PASS
	1340	701.0	712.7	-11.70			
	1358	701.0	714.3	-13.30			

	Time (EST)	Reference Value	Monitor Value	PPM Difference	Linearity Error	PROTOCOL 1 TANK SERIAL #	Pass/Fail
Low	1315	153.3	157.9	-4.60	5%	ALM038004	PASS
	1326	153.3	157.6	-4.30			
	1345	153.3	155.1	-1.80			
Mid	1320	332.0	335.2	-3.20	0.6	CC279379	PASS
	1333	332.0	330.9	1.10			
	1351	332.0	335.7	-3.70			
High	1303	525.0	546.9	-21.90	0.5	ALM001219	PASS
	1340	525.0	517.2	7.80			
	1358	525.0	519.4	5.60			

	Time (EST)	Reference Value	Monitor Value	PPM Difference	Linearity Error	PROTOCOL 1 TANK SERIAL #	Pass/Fail
Low	1315	5.00	5.03	-0.03	5%	ALM038004	PASS
	1326	5.00	5.11	-0.11			
	1345	5.00	5.09	-0.09			
Mid	1320	11.03	11.24	-0.21	1.4	CC279379	PASS
	1333	11.03	11.10	-0.07			
	1351	11.03	11.21	-0.18			
High	1303	16.81	16.71	0.10	0.5	ALM001219	PASS
	1340	16.81	16.94	-0.13			
	1358	16.81	17.01	-0.20			



AIR LIQUIDE

Air Liquide America  
Specialty Gases LLC



Scott

RATA CLASS

Dual-Analyzed Calibration Standard

6141 EASTON ROAD, BLDG 1, PLUMSTEADVILLE, PA 18949-0310

Phone: 800-331-4953

Fax: 215-766-7226

**CERTIFICATE OF ACCURACY: Interference Free™ Multi-Component EPA Protocol Gas**

Assay Laboratory - PGVP Vendor ID: A12012

AIR LIQUIDE AMERICA SPECIALTY GASES LLC  
6141 EASTON ROAD, BLDG 1  
PLUMSTEADVILLE, PA 18949-0310

P.O. No.: CEM6035  
Document #: 48178486-003

Customer

FLORIDA POWER & LIGHT - EMISSIONS T

14925 SW 67TH AVENUE  
ATTN: ARTURO MOCHA  
MIAMI FL 33158  
US

**ANALYTICAL INFORMATION**

Gas Type : SNC2

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: ALM038004  
Cylinder Pressure\*\*\*: 1888 PSIG

Certification Date: 01Nov2012

Exp. Date: 02Nov2020  
Batch No: PLU0140319

COMPONENT	CERTIFIED CONCENTRATION (Moles)	ACCURACY**	TRACEABILITY
NITRIC OXIDE	153.3 PPM	+/- 1%	Direct NIST and VSL
SULFUR DIOXIDE *	159.4 PPM	+/- 1%	Direct NIST and VSL
CARBON DIOXIDE	5.00 %	+/- 1%	Direct NIST and VSL
NITROGEN - OXYGEN FREE	BALANCE		
TOTAL OXIDES OF NITROGEN	153.3 PPM		Reference Value Only

\*\*\* Do not use when cylinder pressure is below 150 psig.

\*\* Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

**REFERENCE STANDARD**

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM 1885	04Jan2018	KAL004337	242.0 PPM	NITRIC OXIDE
NTRM 0280	06Jan2018	KAL003815	255.5 PPM	SULFUR DIOXIDE
NTRM 2000	01Jun2013	K026813	5.008 %	CARBON DIOXIDE

**INSTRUMENTATION**

INSTRUMENT/MODEL/SERIAL#	DATE LAST CALIBRATED	ANALYTICAL PRINCIPLE
FTIR//000928781	26Oct2012	FTIR
FTIR//000928781	11Oct2012	FTIR
FTIR//000928781	18Oct2012	FTIR

**ANALYZER READINGS**

(Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

**First Triad Analysis**

**NITRIC OXIDE**

Date: 24Oct2012 Response Unit:PPM  
Z1=-0.28984 R1=241.3709 T1=153.2106  
R2=241.8581 Z2=-0.23151 T2=153.2422  
Z3=0.39449 T3=153.3558 R3=241.9482  
Avg. Concentration: 153.5 PPM

**Second Triad Analysis**

Date: 01Nov2012 Response Unit: PPM  
Z1=-0.33282 R1=241.3897 T1=152.5705  
R2=241.4245 Z2=0.06258 T2=152.8284  
Z3=0.28882 T3=152.8308 R3=241.5992  
Avg. Concentration: 153.1 PPM

**Calibration Curve**

Concentration = A + Bx + Cx2 + Dx3 + Ex4  
r = 9.99999E-1  
Constants: A = 0.00000E+0  
B = 9.89816E-1 C = 4.40000E-5  
D = 0.00000E+0 E = 0.00000E+0

**SULFUR DIOXIDE \***

Date: 24Oct2012 Response Unit:PPM  
Z1=0.00252 R1=254.0588 T1=197.9875  
R2=254.1038 Z2=0.01300 T2=198.2547  
Z3=0.18538 T3=198.3984 R3=254.1843  
Avg. Concentration: 199.3 PPM

Date: 01Nov2012 Response Unit: PPM  
Z1=-0.01184 R1=253.9498 T1=198.4452  
R2=254.1091 Z2=-0.00578 T2=198.4551  
Z3=0.03324 T3=198.4920 R3=254.3212  
Avg. Concentration: 199.5 PPM

Concentration = A + Bx + Cx2 + Dx3 + Ex4  
r = 9.99994E-1  
Constants: A = 0.00000E+0  
B = 9.99080E-1 C = 8.00000E-8  
D = 0.00000E+0 E = 0.00000E+0

**CARBON DIOXIDE**

Date: 24Oct2012 Response Unit:%  
Z1=0.00205 R1=4.99487 T1=4.98568  
R2=4.98821 Z2=0.00253 T2=4.98909  
Z3=0.00489 T3=4.99908 R3=5.00308  
Avg. Concentration: 4.999 %

Concentration = A + Bx + Cx2 + Dx3 + Ex4  
r = 9.99995E-1  
Constants: A = 0.00000E+0  
B = 9.53870E-1 C = 1.26100E-2  
D = 5.00000E-8 E = 0.00000E+0

APPROVED BY:

Michael A. Kuhns

6141 EASTON ROAD, BLDG 1, PLUMSTEADVILLE, PA 18949-0310 Phone: 800-331-4953 Fax: 215-766-7226

**CERTIFICATE OF ACCURACY: Interference Free™ Multi-Component EPA Protocol Gas**

**Assay Laboratory - PGVP Vendor ID: A12012**  
AIR LIQUIDE AMERICA SPECIALTY GASES LLC  
6141 EASTON ROAD, BLDG 1  
PLUMSTEADVILLE, PA 18949-0310

P.O. No.: CEM6035  
Document #: 48178486-004

**Customer**  
FLORIDA POWER & LIGHT - EMISSIONS T  
  
14925 SW 67TH AVENUE  
ATTN: ARTURO MOCHA  
MIAMI FL 33158  
US

**ANALYTICAL INFORMATION**

**Gas Type : SNC2**

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: CC279379 Certification Date: 01Nov2012 Exp. Date: 02Nov2020  
Cylinder Pressure\*\*\*: 1887 PSIG Batch No: PLU0140370

COMPONENT	CERTIFIED CONCENTRATION (Moles)	ACCURACY**	TRACEABILITY
NITRIC OXIDE	332 PPM	+/- 1%	Direct NIST and VSL
SULFUR DIOXIDE *	439 PPM	+/- 1%	Direct NIST and VSL
CARBON DIOXIDE	11.03 %	+/- 1%	Direct NIST and VSL
NITROGEN - OXYGEN FREE	BALANCE		
TOTAL OXIDES OF NITROGEN	332. PPM		Reference Value Only

\*\*\* Do not use when cylinder pressure is below 150 psig.  
\*\* Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

**REFERENCE STANDARD**

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM 1688	26Mar2016	KAL003504	490.0 PPM	NITRIC OXIDE
NTRM 1681	07Feb2018	KAL004420	501.3 PPM	SULFUR DIOXIDE
NTRM 1675 B	05Jan2018	K013384	13.94 %	CARBON DIOXIDE

**INSTRUMENTATION**

INSTRUMENT/MODEL/SERIAL#	DATE LAST CALIBRATED	ANALYTICAL PRINCIPLE
FTIR/000928781	26Oct2012	FTIR
FTIR/000928781	12Oct2012	FTIR
FTIR/000928781	18Oct2012	FTIR

**ANALYZER READINGS**

(Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

**First Triad Analysis**

**NITRIC OXIDE**  
Date: 24Oct2012 Response Unit:PPM  
Z1=0.08221 R1=490.7785 T1=332.5822  
R2=491.1018 Z2=0.55710 T2=332.9115  
Z3=0.88223 T3=332.9509 R3=491.1976  
Avg. Concentration: 332.0 PPM

**Second Triad Analysis**

Date: 01Nov2012 Response Unit: PPM  
Z1=-0.02422 R1=490.3830 T1=332.7347  
R2=490.4407 Z2=0.18494 T2=332.9496  
Z3=0.82902 T3=333.3958 R3=490.7983  
Avg. Concentration: 332.6 PPM

**Calibration Curve**

Concentration = A + Bx + Cx<sup>2</sup> + Dx<sup>3</sup> + Ex<sup>4</sup>  
r = 9.99999E-1  
Constants: A = 0.00000E+0  
B = 9.89818E-1 C = 4.40000E-5  
D = 0.00000E+0 E = 0.00000E+0

**SULFUR DIOXIDE \***

Date: 24Oct2012 Response Unit:PPM  
Z1=-0.05517 R1=500.2220 T1=438.1585  
R2=500.8744 Z2=-0.00180 T2=438.3810  
Z3=0.20882 T3=438.4808 R3=500.9882  
Avg. Concentration: 438.9 PPM

Date: 01Nov2012 Response Unit: PPM  
Z1=-0.10496 R1=500.8737 T1=438.5489  
R2=501.0394 Z2=0.00187 T2=438.9007  
Z3=0.28722 T3=439.2344 R3=501.7502  
Avg. Concentration: 439.0 PPM

Concentration = A + Bx + Cx<sup>2</sup> + Dx<sup>3</sup> + Ex<sup>4</sup>  
r = 9.99984E-1  
Constants: A = 0.00000E+0  
B = 9.96831E-1 C = 4.00000E-6  
D = 0.00000E+0 E = 0.00000E+0

**CARBON DIOXIDE**

Date: 24Oct2012 Response Unit:%  
Z1=0.00857 R1=13.86091 T1=10.97269  
R2=13.86363 Z2=0.00743 T2=10.97487  
Z3=0.01189 T3=10.98653 R3=13.88852  
Avg. Concentration: 11.03 %

Z1=0.00000 R1=0.00000 T1=0.00000  
R2=0.00000 Z2=0.00000 T2=0.00000  
Z3=0.00000 T3=0.00000 R3=0.00000  
Avg. Concentration: 0.000

Concentration = A + Bx + Cx<sup>2</sup> + Dx<sup>3</sup> + Ex<sup>4</sup>  
r = 9.99995E-1  
Constants: A = 0.00000E+0  
B = 9.53870E-1 C = 1.26100E-2  
D = 5.00000E-6 E = 0.00000E+0

APPROVED BY:

*Michael A. Kuhns*  
Michael A. Kuhns



8141 EASTON ROAD, BLDG 1, PLUMSTEADVILLE, PA 18949-0310 Phone: 800-331-4953 Fax: 215-766-7226

**RATA CLASS***Dual-Analyzed Calibration Standard***CERTIFICATE OF ACCURACY: Interference Free™ Multi-Component EPA Protocol Gas**

Assay Laboratory - PGVP Vendor ID: A12013  
 AIR LIQUIDE AMERICA SPECIALTY GASES LLC  
 8141 EASTON ROAD, BLDG 1  
 PLUMSTEADVILLE, PA 18949-0310

P.O. No.:  
 Document #: 49695961-004

Customer  
 FLORIDA POWER & LIGHT - TURKEY  
 9700 SW 344 ST  
 HOMESTEAD, FL 33035

**ANALYTICAL INFORMATION Gas Type : CO2,NO,SO2,BALN**

This certification was performed according to EPA Traceability Protocol For Assay &amp; Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: ALM001219  
 Cylinder Pressure\*\*\*: 1965 PSIG

Certification Date: 18Mar2013

Exp. Date: 19Mar2021  
 Batch No: PLU0173311

COMPONENT	CERTIFIED CONCENTRATION (Moles)	ACCURACY**	TRACEABILITY
CARBON DIOXIDE	16.81 %	+/- 1%	Direct NIST and VSL
NITRIC OXIDE	525 PPM	+/- 1%	Direct NIST and VSL
SULFUR DIOXIDE *	701 PPM	+/- 1%	Direct NIST and VSL
NITROGEN - OXYGEN FREE	BALANCE		
TOTAL OXIDES OF NITROGEN	525. PPM		Reference Value Only

\*\*\* Do not use when cylinder pressure is below 150 psig.

\*\* Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

**REFERENCE STANDARD**

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM 1675 B	05Jan2018	K013384	13.94 %	CARBON DIOXIDE
NTRM 1686	26Mar2016	KAL003523	490.0 PPM	NITRIC OXIDE
NTRM 1661	07Feb2018	KAL004420	501.3 PPM	SULFUR DIOXIDE

**INSTRUMENTATION**

INSTRUMENT/MODEL/SERIAL#	DATE LAST CALIBRATED	ANALYTICAL PRINCIPLE
FTIR//000928781	08Mar2013	FTIR
FTIR//000928781	15Mar2013	FTIR
FTIR//000928781	01Mar2013	FTIR

**ANALYZER READINGS**

(Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

**First Triad Analysis****CARBON DIOXIDE**

Date: 11Mar2013 Response Unit: %  
 Z1=0.00212 R1=13.84327 T1=16.68364  
 R2=13.85260 Z2=0.00479 T2=16.69558  
 Z3=0.01630 T3=16.72632 R3=13.85917  
 Avg. Concentration: 16.81 %

**NITRIC OXIDE**

Date: 11Mar2013 Response Unit: PPM  
 Z1=0.09467 R1=489.5246 T1=523.9475  
 R2=489.6883 Z2=0.04870 T2=524.6114  
 Z3=0.20741 T3=525.1303 R3=490.3930  
 Avg. Concentration: 524.7 PPM

**SULFUR DIOXIDE\***

Date: 11Mar2013 Response Unit: PPM

**Second Triad Analysis**

Z1=0.00000 R1=0.00000 T1=0.00000  
 R2=0.00000 Z2=0.00000 T2=0.00000  
 Z3=0.00000 T3=0.00000 R3=0.00000  
 Avg. Concentration: 0.000

Date: 18Mar2013 Response Unit: PPM  
 Z1=0.14236 R1=490.1644 T1=525.3974  
 R2=490.1801 Z2=0.22803 T2=525.5099  
 Z3=0.98641 T3=525.7501 R3=490.3845  
 Avg. Concentration: 525.3 PPM


Date: 18Mar2013 Response Unit: PPM

**Calibration Curve**

Concentration=A+Bx+Cx2+Dx3+Ex4  
 r=9.99996E-1  
 Constants: A=0.00000E+0  
 B=9.14785E-1 C=1.17570E-2  
 D=1.00000E-6 E=0.00000E+0

Concentration=A+Bx+Cx2+Dx3+Ex4  
 r=9.99999E-1  
 Constants: A=0.00000E+0  
 B=9.90869E-1 C=4.60000E-5  
 D=0.00000E+0 E=0.00000E+0

Concentration=A+Bx+Cx2+Dx3+Ex4



**TURKEY POINT PLANT UNIT 1**  
**Seven Day Calibration Error Test**

Plant PTP  
Unit 1  
Oris Code 621

Parameter NOx  
Instrument Span 600  
Serial # 1315157764

Day	Level	Date	Calibration End Time	Reference/Cylinder Value (ppm)	Monitor Value (ppm)	Calibration Error (%)	Adjustment made? up/down/none	New monitor value
<b>Calibrate monitors, begin test, collect and calculate drift in 24 hours.</b> (see 40 CFR 75, App. A, sec. 6.3.1)								
0	zero	12/3/2013	3:19 PM	0.0	0.1	0.0%	None	NA
0	span	12/3/2013	3:19 PM	525.0	538.2	2.2%	None	NA
1	zero	12/4/2013	7:42 AM	0.0	0.1	0.0%	None	NA
1	span	12/4/2013	7:42 AM	525.0	537.0	2.0%	None	NA
2	zero	12/5/2013	7:42 AM	0.0	0.1	0.0%	None	NA
2	span	12/5/2013	7:42 AM	525.0	538.6	2.3%	Down	525.8
3	zero	12/6/2013	7:42 AM	0.0	0.0	0.0%	None	NA
3	span	12/6/2013	7:42 AM	525.0	528.0	0.5%	None	NA
4	zero	12/7/2013	7:42 AM	0.0	0.0	0.0%	None	NA
4	span	12/7/2013	7:42 AM	525.0	534.4	1.6%	None	NA
5	zero	12/8/2013	11:39 AM	0.0	0.0	0.0%	None	NA
5	span	12/8/2013	11:39 AM	525.0	530.8	1.0%	None	NA
6	zero	12/10/2013	3:17 AM	0.0	0.1	0.0%	None	NA
6	span	12/10/2013	3:17 AM	525.0	525.2	0.0%	None	NA
7	zero	12/11/2013	7:42 AM	0.0				
7	span	12/11/2013	7:42 AM	525.0				

Notes:

$$\text{Calibration Error} = \frac{|\text{Reference} - \text{Monitor}|}{\text{Instrument Span}} \times 100 \quad \text{Eq. A-5}$$

For NOx, the calibration error is acceptable if  $\leq 2.5\%$ .



6141 EASTON ROAD, BLDG 1, PLUMSTEADVILLE, PA 18949-0310 Phone: 800-331-4953 Fax: 215-766-7226

**RATA CLASS**

*Dual-Analyzed Calibration Standard*

**CERTIFICATE OF ACCURACY: Interference Free™ Multi-Component EPA Protocol Gas**

Assay Laboratory - PGVP Vendor ID: A12013  
 AIR LIQUIDE AMERICA SPECIALTY GASES LLC  
 6141 EASTON ROAD, BLDG 1  
 PLUMSTEADVILLE, PA 18949-0310

P.O. No.:  
 Document #: 49695961-004

Customer  
 FLORIDA POWER & LIGHT - TURKEY  
 9700 SW 344 ST

HOMESTEAD, FL 33035

**ANALYTICAL INFORMATION Gas Type : CO2,NO,SO2,BALN**

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: ALM001219  
 Cylinder Pressure\*\*\*: 1965 PSIG

Certification Date: 18Mar2013

Exp. Date: 19Mar2021  
 Batch No: PLU0173311

COMPONENT	CERTIFIED CONCENTRATION (Moles)	ACCURACY**	TRACEABILITY
CARBON DIOXIDE	16.81 %	+/- 1%	Direct NIST and VSL
NITRIC OXIDE	525 PPM	+/- 1%	Direct NIST and VSL
SULFUR DIOXIDE *	701 PPM	+/- 1%	Direct NIST and VSL
NITROGEN - OXYGEN FREE	BALANCE		
TOTAL OXIDES OF NITROGEN	525. PPM		Reference Value Only

\*\*\* Do not use when cylinder pressure is below 150 psig.

\*\* Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

**REFERENCE STANDARD**

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM 1675 B	05Jan2018	K013384	13.94 %	CARBON DIOXIDE
NTRM 1686	26Mar2016	KAL003523	490.0 PPM	NITRIC OXIDE
NTRM 1661	07Feb2018	KAL004420	501.3 PPM	SULFUR DIOXIDE

**INSTRUMENTATION**

INSTRUMENT/MODEL/SERIAL#	DATE LAST CALIBRATED	ANALYTICAL PRINCIPLE
FTIR//000928781	08Mar2013	FTIR
FTIR//000928781	15Mar2013	FTIR
FTIR//000928781	01Mar2013	FTIR

**ANALYZER READINGS**

(Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

**First Triad Analysis CARBON DIOXIDE**

Date: 11Mar2013 Response Unit: %  
 Z1=0.00212 R1=13.84327 T1=16.68364  
 R2=13.85260 Z2=0.00479 T2=16.69558  
 Z3=0.01630 T3=16.72632 R3=13.85917  
 Avg. Concentration: 16.81 %

**Second Triad Analysis**

Z1=0.00000 R1=0.00000 T1=0.00000  
 R2=0.00000 Z2=0.00000 T2=0.00000  
 Z3=0.00000 T3=0.00000 R3=0.00000  
 Avg. Concentration: 0.000

**Calibration Curve**

Concentration=A+Bx+Cx2+Dx3+Ex4  
 r=9.99999E-1  
 Constants: A=0.00000E+0  
 B=9.14785E-1 C=1.17570E-2  
 D=1.00000E-6 E=0.00000E+0

**NITRIC OXIDE**

Date: 11Mar2013 Response Unit: PPM  
 Z1=-0.09467 R1=489.5246 T1=523.9475  
 R2=489.6883 Z2=-0.04870 T2=524.6114  
 Z3=0.20741 T3=525.1303 R3=490.3930  
 Avg. Concentration: 524.7 PPM

Date: 18Mar2013 Response Unit: PPM  
 Z1=0.14236 R1=490.1644 T1=525.3974  
 R2=490.1801 Z2=0.22803 T2=525.5099  
 Z3=0.98641 T3=525.7501 R3=490.3845  
 Avg. Concentration: 525.3 PPM

Concentration=A+Bx+Cx2+Dx3+Ex4  
 r=9.99999E-1  
 Constants: A=0.00000E+0  
 B=9.90869E-1 C=4.60000E-5  
 D=0.00000E+0 E=0.00000E+0

**SULFUR DIOXIDE \***

Date: 11Mar2013 Response Unit: PPM

Date: 18Mar2013 Response Unit: PPM

Concentration=A+Bx+Cx2+Dx3+Ex4







# ECMPS Client Tool

Version 1.0 2013 Q3

## Facility Name: Turkey Point

### Facility Details

Facility ID (ORISPL): 621

State: FL

County: Miami-Dade

Unit/Stack/Pipe ID: PTP1

7-Day Calibration

Component ID: B02

Component Type: NOX

Test Completion: 12/11/2013 07:51

Test Number: 7DAY-Q42013-B02-23 Reason for Test: RECERT

Reported Test Results: PASSED

Span Scale Level: High

EPA Calculated Result: PASSED

Evaluation Status: No Errors

Submission Status: Data loaded on EPA Host System

Submission Date/Time: 01/23/2014 10:13:00 AM

Injection Date/Hour	Gas Level	Reference Value	Reference Value % of Span	Measured Value	Reported		Recalculated	
					Results	APS	Results	APS
12/04/2013 07	ZERO	0.000	0	0.100	0.00		0.00	
12/04/2013 07	HIGH	525.000	87.5	538.200	2.20		2.20	
12/05/2013 07	ZERO	0.000	0	0.100	0.00		0.00	
12/05/2013 07	HIGH	525.000	87.5	537.000	2.00		2.00	
12/06/2013 07	ZERO	0.000	0	0.100	0.00		0.00	
12/06/2013 07	HIGH	525.000	87.5	538.600	2.30		2.30	
12/07/2013 07	ZERO	0.000	0	0.000	0.00		0.00	
12/07/2013 07	HIGH	525.000	87.5	528.000	0.50		0.50	
12/08/2013 11	ZERO	0.000	0	0.000	0.00		0.00	
12/08/2013 11	HIGH	525.000	87.5	534.400	1.60		1.60	
12/10/2013 03	ZERO	0.000	0	0.000	0.00		0.00	
12/10/2013 03	HIGH	525.000	87.5	530.800	1.00		1.00	
12/11/2013 07	ZERO	0.000	0	0.100	0.00		0.00	
12/11/2013 07	HIGH	525.000	87.5	525.200	0.00		0.00	

### Additional Information:

No comment.

\*Performance Spec: CE <= 2.5% of Span Alternate Performance Spec: |R-A| <= 5 ppm (Appendix A & 3.1)

Facility Name: Turkey Point  
Facility ID (ORISPL): 621

Unit/Stack/Pipe ID: PTP1  
7-Day Calibration

Component ID: A03  
Test Number: 7DAY-Q42013-A03-22  
Span Scale Level: High  
Component Type: CO2  
Reason for Test: RECERT  
Span Value: 20.000  
Test Completion: 12/11/2013 07:51  
Reported Test Results: PASSED  
EPA Calculated Result: PASSED  
Submission Status: Data loaded on EPA Host System  
Submission Date/Time: 01/14/2014 1:50:00 PM

Evaluation Status: Informational Message

Injection Date/Hour	Gas Level	Reference Value	Reference Value % of Span	Measured Value	Reported		Recalculated	
					Results	APS	Results	APS
12/04/2013 07	ZERO	0.000	0	0.000	0.00		0.00	
12/04/2013 07	HIGH	16.800	84	16.880	0.10		0.10	
12/05/2013 07	ZERO	0.000	0	0.000	0.00		0.00	
12/05/2013 07	HIGH	16.800	84	16.770	0.00		0.00	
12/06/2013 07	ZERO	0.000	0	0.000	0.00		0.00	
12/06/2013 07	HIGH	16.800	84	16.910	0.10		0.10	
12/07/2013 07	ZERO	0.000	0	0.000	0.00		0.00	
12/07/2013 07	HIGH	16.800	84	16.950	0.20		0.20	
12/08/2013 11	ZERO	0.000	0	0.000	0.00		0.00	
12/08/2013 11	HIGH	16.800	84	17.000	0.20		0.20	
12/10/2013 03	ZERO	0.000	0	0.000	0.00		0.00	
12/10/2013 03	HIGH	16.800	84	16.900	0.10		0.10	
12/11/2013 07	ZERO	0.000	0	0.000	0.00		0.00	
12/11/2013 07	HIGH	16.800	84	16.830	0.00		0.00	

Additional Information:  
No comment.

\*Performance Spec: CE <= 2.5% of Span    Alternate Performance Spec: |R-A| <= 5 ppm (Appendix A & 3.1)

Facility Name: Turkey Point  
Facility ID (CRISPL): 621

Unit/Stack/Pipe ID: PTP1  
7-Day Calibration

Component ID: A02  
Test Number: 7DAY-Q42013-A02-23  
Span Scale Level: High  
Evaluation Status: No Errors

Component Type: NOX  
Reason for Test: RECERT  
Span Value: 600.000

Test Completion: 12/11/2013 07:51  
Reported Test Results: PASSED  
EPA Calculated Result: PASSED

Submission Status: Data loaded on EPA Host System  
Submission Date/Time: 01/14/2014 1:50:00 PM

Injection Date/Hour	Gas Level	Reference Value	Reference Value % of Span	Measured Value	Reported		Recalculated	
					Results	APS	Results	APS
12/04/2013 07	ZERO	0.000	0	0.100	0.00		0.00	
12/04/2013 07	HIGH	525.000	87.5	538.200	2.20		2.20	
12/05/2013 07	ZERO	0.000	0	0.100	0.00		0.00	
12/05/2013 07	HIGH	525.000	87.5	537.000	2.00		2.00	
12/06/2013 07	ZERO	0.000	0	0.100	0.00		0.00	
12/06/2013 07	HIGH	525.000	87.5	538.600	2.30		2.30	
12/07/2013 07	ZERO	0.000	0	0.000	0.00		0.00	
12/07/2013 07	HIGH	525.000	87.5	528.000	0.50		0.50	
12/08/2013 11	ZERO	0.000	0	0.000	0.00		0.00	
12/08/2013 11	HIGH	525.000	87.5	534.400	1.60		1.60	
12/10/2013 03	ZERO	0.000	0	0.000	0.00		0.00	
12/10/2013 03	HIGH	525.000	87.5	530.800	1.00		1.00	
12/11/2013 07	ZERO	0.000	0	0.100	0.00		0.00	
12/11/2013 07	HIGH	525.000	87.5	525.200	0.00		0.00	

Additional Information:  
No comment.

\*Performance Spec: CE <= 2.5% of Span    Alternate Performance Spec: |R-A| <= 5 ppm (Appendix A & 3.1)

**QA/Cert Test Detail Report**  
January 31, 2014 12:42 PM

**Facility Name:** Turkey Point  
**Facility ID (ORISPL):** 621

**Unit/Stack/Pipe ID:** PTP1  
**Fuel Flow-to-Load Test**  
**System ID:** 109 **System Type:** OILM  
**Test Number:** GHRL-Q42013-009-1 **Reason for Test:** QA  
**Evaluation Status:** No Errors  
**Calendar Quarter/Year:** 2013 QTR 4  
**Reported Test Results:** FEW168H  
**Submission Status:** Data loaded on EPA Host System  
**Submission Date/Time:** 01/15/2014 10:03:00 AM

Test Basis	Avg. Absolute Percent Difference	Hours Used in Analysis	Hours Excluded for Co-Firing	Hours Excluded for Ramping	Hours Excluded for Low Range
		0	0	0	0

**Additional Information:**  
No comment.

**Unit/Stack/Pipe ID:** PTP1  
**Linearity Check**  
**Component ID:** A03 **Component Type:** CO2 **Test Completion:** 11/25/2013 13:58  
**Test Number:** LINE-Q42013-A03-2 **Reason for Test:** QA **Reported Test Results:** PASSED  
**Span Scale Level:** High **Span Value:** 20.000 **EPA Calculated Result:** PASSED  
**Evaluation Status:** Informational Message **Submission Status:** Data loaded on EPA Host System  
**Grace period Tested?** **Submission Date/Time:** 01/14/2014 1:50:00 PM

**Protocol Gas Data:**

Gas Level/Code	Gas Type Code	Vendor Identifier	Cylinder Identifier	Expiration Date
High	CO2,NO,SO2,BALN	A12013	ALM001219	03/19/2021
Mid	CO2,NO,SO2,BALN	A12012	CC279379	11/02/2020
Low	CO2,NO,SO2,BALN	A12012	ALM038004	11/02/2020

**Summary Statistics:**

	High		Mid		Low	
	Reported	Recalculated	Reported	Recalculated	Reported	Recalculated
Reference Value	16.810	16.810	11.030	11.030	5.000	5.000
Mass CEM Value	16.887	16.887	11.183	11.183	5.077	5.077
Alt. Perf. Indicator						
Results	0.5	0.5	1.4	1.4	1.5	1.5

**Facility Name:** Turkey Point

Facility ID (ORISPL): 621

**QA/Cert Test Detail Report**

January 31, 2014 12:42 PM

Injection Statistics	Date	Gas Level	Measured Value	Reference Value	Reference Value as % of Span
	11/25/2013 13:12	MID	11.240	11.030	55.2%
	11/25/2013 13:52	MID	11.210	11.030	55.2%
	11/25/2013 13:34	MID	11.100	11.030	55.2%
	11/25/2013 13:45	LOW	5.090	5.000	25.0%
	11/25/2013 13:26	LOW	5.110	5.000	25.0%
	11/25/2013 13:03	LOW	5.030	5.000	25.0%
	11/25/2013 13:40	HIGH	16.940	16.810	84.1%
	11/25/2013 13:58	HIGH	17.010	16.810	84.1%
	11/25/2013 13:20	HIGH	16.710	16.810	84.1%

**Additional Information:**

No comment.

\*Performance Spec: LE <= 5.0% of Reference Value; Alternate Performance Spec: [R-A] <= 5ppm (Appendix A & 3.2)

Unit/Stack/Pipe ID: PTP1

Linearity Check

Component ID: B02 Component Type: NOX Test Completion: 11/25/2013 13:58

Test Number: LINE-Q42013-B02-10 Reason for Test: INITIAL Reported Test Results: PASSED

Span Scale Level: High Span Value: 600.000 EPA Calculated Result: PASSED

Evaluation Status: Informational Message Submission Status: Data loaded on EPA Host System

Grace period Tested? Submission Date/Time: 01/14/2014 1:50:00 PM

**Protocol Gas Data:**

Gas Level Code	Gas Type Code	Vendor Identifier	Cylinder Identifier	Expiration Date
High	CO2,NO,SO2,BALN	A12013	ALM001219	03/19/2021
Mid	CO2,NO,SO2,BALN	A12012	CC279379	11/02/2020
Low	CO2,NO,SO2,BALN	A12012	ALM038004	11/02/2020

**Summary Statistics:**

**QA/Cert Test Detail Report**  
January 31, 2014 12:42 PM

**Facility Name:** Turkey Point  
**Facility ID (ORISPL):** 621

	High		Mid		Low	
	Reported	Recalculated	Reported	Recalculated	Reported	Recalculated
Reference Value	525.000	525.000	332.000	332.000	153.300	153.300
Mass CEM Value	527.833	527.833	333.933	333.933	156.867	156.867
Alt. Perf. Indicator						
Results	0.5	0.5	0.6	0.6	2.3	2.3

**Injection Statistics:**

Date	Gas Level	Measured Value	Reference Value	Reference Value as % of Span
11/25/2013 13:26	LOW	157.600	153.300	25.6%
11/25/2013 13:03	LOW	157.900	153.300	25.6%
11/25/2013 13:45	LOW	155.100	153.300	25.6%
11/25/2013 13:40	HIGH	517.200	525.000	87.5%
11/25/2013 13:20	HIGH	546.900	525.000	87.5%
11/25/2013 13:58	HIGH	519.400	525.000	87.5%
11/25/2013 13:34	MID	330.900	332.000	55.3%
11/25/2013 13:52	MID	335.700	332.000	55.3%
11/25/2013 13:12	MID	335.200	332.000	55.3%

**Additional Information:**

No comment.

\*Performance Spec: LE <= 5.0% of Reference Value; Alternate Performance Spec: |R-A| <= 5ppm (Appendix A & 3.2)

**Unit/Stack/Pipe ID:** PTP1

**Relative Accuracy Test**

**System ID:** 102 **System Parameter:** NOX

**Test Number:** RATA-Q42013-102-1 **Reason for Test:** QA

**# of Op. Levels:** 1 **Grace Period Test?**

**Evaluation Status:** Informational Message

**Submission Status:** Data loaded on EPA Host System

**Submission Date:** 01/14/2014 1:50:00 PM

**Air Emissions Testing Data**

**Test Completion:** 12/18/2013 14:10

**Reported Test Results:** PASSED

**EPA Calculated Result:** PASSED

**Reported BAF:** 1.000

**EPA Calculated BAF:** 1.000

**RATA Frequency:** 4QTRS

**QI Name:** Mocha, Arturo J

**Exam Date:** 10/06/2011

**AETB Name:** FPL Emission Test Group

**AETB Phone Number:** 305-228-5089

**Facility Name:** Turkey Point

Facility ID (ORISPL): 621

Provider Name: Eastern Technical Associates (ETA)

Provider Email: Sherril@smokeschool.com

AETB Email: Arturo.Mocha@FPL.com

**Protocol Gas Data:**

Gas Level Code	Gas Type Code	Vendor Identifier	Cylinder Identifier	Expiration Date
High	CO2,O2,BALN	A12013	CC203126	04/03/2021
Mid	CO2,O2,BALN	A12013	ALM047324	01/08/2021
High	NO,SO2,BALN	A12012	ALM001989	11/02/2020
Mid	NO,SO2,BALN	A12013	ALM028914	03/30/2021
Low	ZERO			

Operating Level: Mid  
Reference Method Used: 7E,3A: NOX RM 7E and CO2/O2 RM 3A

**Summary Statistics:**

	Reported	Recalculated	Reported	Recalculated
Mean of Monitoring System	0.238	0.238	4.19	4.19
Mean of Reference Method Values	0.230	0.230	1.000	1.000
Mean of Difference	-0.008	-0.008		
Standard Deviation of Difference	0.003	0.003	2.306	2.306
Confidence Coefficient	0.002	0.002	200	201
		Relative Accuracy		
		Bias Adjustment Factor		
		APS Indicator		
		T-Value		
		Gross Unit Load or Velocity		

Facility Name: Turkey Point

Facility ID (ORISPL): 621

Run Data:

Run	Start Date	End Date	Run Status	Monitoring System Value	Reference Method Value	Gross Load or Velocity
1	12/18/2013 09:41	12/18/2013 10:01	RUNUSED	0.233	0.222	200
2	12/18/2013 10:16	12/18/2013 10:36	RUNUSED	0.239	0.236	201
3	12/18/2013 10:45	12/18/2013 11:05	RUNUSED	0.245	0.242	201
4	12/18/2013 11:18	12/18/2013 11:38	RUNUSED	0.246	0.237	201
5	12/18/2013 11:47	12/18/2013 12:07	RUNUSED	0.243	0.234	201
6	12/18/2013 12:18	12/18/2013 12:38	RUNUSED	0.235	0.226	201
7	12/18/2013 12:48	12/18/2013 13:08	RUNUSED	0.236	0.228	201
8	12/18/2013 13:19	12/18/2013 13:39	RUNUSED	0.235	0.227	201
9	12/18/2013 13:50	12/18/2013 14:10	RUNUSED	0.230	0.222	201

Additional Information:

No comment.

\*Performance Spec: RA <= 10% or Mean Difference <= +/- 2.0fps:

Reduced Frequency Spec: RA <= 7.5% or Mean Difference +/- 1.5 fps (Appendix A & 3.3.4)





# ECMPS Client Tool

Version 1.0 2013 Q3

# QA/Cert Events Printout Report

January 31, 2014 12:44 PM

Facility Name: Turkey Point

## Facility Details

Facility ID (ORISPL): 621  
State: FL  
County: Miami-Dade

## QA Certification Events Details

Unit/Stack Identifier	Event Code	Event Date/Hour	System ID / Type	Component ID / Type	Required Tests	Conditional Data Begin Date/Hour	Last Test Completed Date/Hour	Submitted?
FTP1	100	11/12/2013 12	102/NOX	B02/NOX	11	11/13/2013 15	12/18/2013 12	Already Submitted

Event Codes: 100 - Permanent Gas Analyzer Replacement (Like-kind Analyzer)  
Required Test Codes: 11 - Normal Load RATA, 7-day Calibration Error Test, Linearity Check